

ROSEWORTHY, Australia

WMO: 956710

Lat: 34.5106S

Lon: 138.6764E

Elev: 66

StdP: 100.54

Time Zone: 9.50 (AUA)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.5	2.8	-6.0	2.3	27.0	-3.9	2.8	25.7	13.4	15.2	12.4	15.1	2.8	50	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.2	39.7	18.6	37.2	18.2	34.8	17.6	21.6	29.3	20.4	29.5	19.5	29.4	6.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	14.7	23.6	18.1	13.1	22.6	16.6	11.9	21.9	63.2	28.6	58.8	29.1	55.7	29.4	36.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	10.9	9.5	DB	-0.6	43.3	0.9	1.6	-1.2	44.5	-1.7	45.5	-2.2	46.4	-2.8	47.6	(4)
(5)			WB	-1.1	24.2	0.8	4.1	-1.7	27.1	-2.1	29.5	-2.6	31.8	-3.1	34.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	22.8	22.4	20.4	17.5	14.1	11.1	10.5	10.6	12.5	15.5	18.6	20.7	(6)	
	DBStd	5.88	4.77	4.61	4.37	3.77	2.93	2.18	2.10	2.53	3.10	4.41	4.96	5.04	(7)	
	HDD10.0	64	0	0	0	0	2	12	20	22	7	2	0	0	(8)	
	HDD18.3	1313	7	9	25	59	136	217	244	240	177	114	58	27	(9)	
	CDD10.0	2386	398	346	322	226	129	46	34	40	82	173	257	333	(10)	
	CDD18.3	593	147	122	88	36	5	0	0	0	2	27	65	101	(11)	
	CDH23.3	8277	2083	1612	1087	376	37	1	0	4	64	463	1013	1537	(12)	
(13)	CDH26.7	4368	1196	874	533	141	6	0	0	1	14	205	529	871	(13)	
(14)	Wind	WSAvg	4.8	4.9	4.7	4.6	4.6	4.7	4.6	5.0	4.7	4.6	5.0	4.9	5.1	(14)
(15) Precipitation	PrecAvg	446	22	21	21	37	46	45	54	54	50	43	27	21	(15)	
	PrecMax	642	110	92	74	114	106	95	107	117	92	106	68	96	(16)	
	PrecMin	215	0	0	0	0	5	6	13	11	9	1	0	1	(17)	
	PrecStd	98	22	23	20	29	27	26	22	28	22	30	17	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	40.9	38.8	34.8	27.2	20.7	19.8	23.4	28.7	35.6	38.8	41.7	(19)	
		MCWB	19.7	19.6	18.2	19.9	14.5	12.8	12.3	13.6	14.5	16.0	17.8	18.9	(20)	
	2%	DB	40.3	37.6	35.0	30.4	23.7	18.2	17.3	20.0	24.9	31.8	35.6	38.6	(21)	
		MCWB	18.7	19.0	17.9	15.9	13.9	11.8	11.6	12.7	14.1	15.1	17.1	17.9	(22)	
	5%	DB	36.7	35.2	32.4	27.5	21.3	16.7	15.9	17.6	22.1	28.6	32.8	35.1	(23)	
		MCWB	18.3	18.5	17.5	14.9	13.4	11.9	11.6	12.2	13.4	14.4	16.2	17.3	(24)	
	10%	DB	33.2	32.3	29.4	24.9	19.2	15.3	14.6	15.6	19.2	25.1	29.5	31.7	(25)	
		MCWB	17.5	17.8	16.6	14.3	13.0	11.5	11.1	11.4	12.7	14.1	15.7	16.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	23.9	21.6	21.5	16.7	15.0	14.7	15.1	17.6	18.8	21.2	25.6	(27)	
		MCDB	26.5	34.6	28.0	23.5	21.4	17.3	16.6	19.5	22.5	27.9	28.9	26.4	(28)	
	2%	WB	21.0	21.0	20.2	17.7	15.4	13.5	13.1	13.8	15.3	16.9	19.0	20.2	(29)	
		MCDB	30.0	29.1	27.6	24.2	20.1	16.2	15.4	18.3	21.8	25.5	27.8	30.0	(30)	
	5%	WB	20.1	19.9	19.0	16.6	14.6	12.6	12.2	12.6	14.1	15.8	17.9	18.9	(31)	
		MCDB	31.6	28.9	27.4	23.7	18.9	15.4	14.7	16.4	20.2	24.2	28.2	29.6	(32)	
	10%	WB	19.1	18.9	17.9	15.6	13.8	11.9	11.4	11.8	13.1	14.8	16.7	17.7	(33)	
		MCDB	30.9	29.3	28.0	22.3	17.8	14.6	13.9	15.3	18.2	23.3	26.7	28.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	15.2	14.6	13.7	12.4	9.8	8.7	8.5	10.5	12.7	15.2	15.8	15.3	(35)	
		MCDBR	19.7	18.2	17.2	15.8	12.5	10.1	9.8	13.3	17.2	20.1	19.6	19.7	(36)	
		MCWBR	6.5	6.7	6.1	6.4	5.8	5.9	5.9	7.7	8.0	7.6	7.1	7.1	(37)	
	5% WB	MCDBR	14.6	14.1	13.4	12.2	9.8	8.3	8.3	11.4	14.5	16.0	16.1	14.7	(38)	
		MCWBR	6.5	6.2	6.1	6.5	5.6	5.3	5.8	7.4	8.2	7.6	6.8	7.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.340	0.323	0.316	0.305	0.293	0.294	0.306	0.332	0.342	0.346	0.337	(40)	
	taud		2.492	2.521	2.555	2.559	2.572	2.594	2.579	2.522	2.445	2.425	2.446	2.497	(41)	
	Ebn at Noon		994	976	957	907	862	849	867	903	930	961	983	1003	(42)	
	Edh at Noon		115	107	96	85	74	68	72	87	106	117	119	115	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.93	7.02	5.73	4.16	2.88	2.36	2.56	3.47	4.75	6.14	7.22	7.76	(44)	
	RadStd		0.40	0.33	0.27	0.21	0.13	0.14	0.10	0.23	0.37	0.39	0.35	0.29	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (28 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-89	+152	+69	(47)

Nomenclature: See separate page