

ADELAIDE EDINBURGH, Australia

WMO: 956760

Lat: 34.7111S

Lon: 138.6222E

Elev: 56

StdP: 14.67

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.5	39.6	24.3	18.5	79.7	28.0	21.9	76.9	28.8	54.4	25.9	56.5	4.9	50	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	101.3	66.1	97.2	65.0	93.1	64.1	70.9	86.0	69.1	85.1	67.4	84.4	14.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.1	100.0	75.2	64.4	90.6	74.5	61.8	82.8	72.5	34.8	85.6	33.2	84.9	31.8	84.2	88.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.6	23.5	21.1	DB	33.6	108.4	1.5	3.1	32.5	110.6	31.6	112.4	30.8	114.1	29.7	116.4	(4)
(5)			WB	32.8	74.3	1.7	3.7	31.6	77.0	30.6	79.2	29.6	81.2	28.4	83.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	74.1	73.8	68.9	63.4	57.5	52.5	51.3	52.4	56.4	61.3	66.7	70.2	(6)	
	DBStd	10.25	7.98	8.05	7.24	6.14	4.74	3.74	3.52	4.08	5.33	7.10	7.98	8.07	(7)	
	HDD50	65	0	0	0	0	1	16	27	18	3	0	0	0	(8)	
	HDD65	2110	5	6	32	101	241	376	425	392	268	166	71	27	(9)	
	CDD50	4550	747	665	586	402	232	90	67	91	194	349	501	626	(10)	
	CDD65	1122	287	252	153	53	7	0	0	0	10	50	122	188	(11)	
	CDH74	13778	3593	3066	1727	505	42	1	0	6	101	647	1593	2497	(12)	
	CDH80	6868	1961	1607	794	158	5	0	0	1	21	256	747	1318	(13)	
(14) Wind	WSAvg	10.0	10.5	9.9	9.5	8.8	8.7	8.6	9.8	10.0	10.8	11.1	11.0	11.1	(14)	
(15) Precipitation	PrecAvg	16.9	0.9	0.6	1.0	1.2	1.7	2.1	2.2	2.0	1.9	1.7	1.0	0.8	(15)	
	PrecMax	24.6	3.6	3.0	5.5	3.1	3.5	4.0	4.3	4.1	4.6	3.6	3.5	2.7	(16)	
	PrecMin	9.9	0.0	0.0	0.0	0.1	0.4	0.4	0.6	0.4	0.6	0.3	0.0	0.1	(17)	
	PrecStd	3.6	0.9	0.7	1.3	0.9	0.9	1.0	1.0	1.1	0.9	1.0	0.7	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.5	104.0	100.4	91.3	79.2	69.3	66.9	73.5	82.8	94.0	100.1	104.9	(19)	
		MCWB	67.3	67.5	65.0	62.3	58.3	57.1	54.4	56.6	57.9	60.3	64.6	66.2	(20)	
	2%	DB	101.5	99.1	93.5	84.2	73.2	64.0	62.9	68.0	76.3	86.9	93.5	98.8	(21)	
		MCWB	66.3	67.1	64.6	60.2	57.2	54.6	53.2	54.7	57.4	58.6	62.4	63.9	(22)	
	5%	DB	96.3	94.7	88.8	79.5	69.2	61.6	60.3	64.0	71.6	81.1	88.5	93.1	(23)	
		MCWB	65.4	65.7	63.5	59.1	56.2	54.2	52.5	53.3	56.2	58.3	61.6	62.8	(24)	
	10%	DB	90.8	89.8	83.6	75.4	65.9	59.5	58.2	60.4	67.2	75.6	83.4	87.4	(25)	
		MCWB	64.6	64.8	62.1	58.0	55.9	53.3	51.8	52.3	55.3	56.9	60.4	61.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.3	74.6	70.2	65.8	62.2	59.9	57.3	58.6	63.0	64.7	68.8	70.7	(27)	
		MCDB	82.8	91.7	84.5	75.7	69.0	64.0	61.8	67.6	74.7	78.4	84.1	84.2	(28)	
	2%	WB	70.9	71.1	68.1	63.7	60.0	56.9	55.3	56.4	59.8	62.2	66.2	68.0	(29)	
		MCDB	87.1	85.6	81.5	74.0	67.1	61.3	59.8	64.2	70.8	75.5	82.3	84.4	(30)	
	5%	WB	68.8	69.1	66.2	62.1	58.5	55.5	53.9	54.7	57.8	60.4	64.4	66.0	(31)	
		MCDB	87.2	84.6	81.5	73.5	65.4	59.6	58.2	61.2	67.2	74.2	81.0	84.1	(32)	
	10%	WB	66.9	67.1	64.2	60.3	57.2	54.1	52.7	53.3	56.1	58.7	62.4	64.0	(33)	
		MCDB	86.1	84.5	80.2	71.4	64.2	58.3	57.0	59.1	64.7	72.2	79.5	81.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	22.6	21.5	20.3	18.8	15.7	14.4	14.3	16.3	18.0	20.8	21.6	22.0	(35)	
		MCDBR	31.0	27.7	27.5	25.6	20.7	17.0	16.8	22.4	26.4	30.6	30.0	31.6	(36)	
	5% WB	MCWBR	10.2	9.9	9.8	10.2	9.9	10.4	10.2	12.5	12.2	11.4	10.4	10.8	(37)	
		MCWBR	23.1	21.3	21.8	19.2	15.7	13.9	14.1	18.2	21.6	23.7	24.5	23.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.345	0.343	0.326	0.319	0.308	0.298	0.298	0.310	0.335	0.348	0.349	0.340	(40)	
		taud	2.507	2.533	2.568	2.572	2.586	2.600	2.589	2.535	2.460	2.430	2.459	2.508	(41)	
	Ebn at Noon		314	308	302	286	272	267	273	285	294	303	311	317	(42)	
		Edh at Noon	36	34	30	27	23	21	23	27	33	37	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2496	2201	1793	1301	895	736	798	1088	1490	1932	2276	2447	(44)	
	RadStd		125	103	82	68	39	45	33	71	115	122	108	93	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+234	+130
(47) Regional (25 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-166	+283	+126

Nomenclature: See separate page