

ADELAIDE EDINBURGH, Australia

WMO: 956760

Lat: 34.7111S

Lon: 138.6222E

Elev: 17

StdP: 101.12

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 3.1	(c) 4.2	(d) -4.3	(e) 2.6	(f) 26.5	(g) -2.2	(h) 3.1	(i) 24.9	(j) 12.9	(k) 12.4	(l) 11.6	(m) 13.6	(n) 2.2	(o) 50	(p) 0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	38.5	18.9	36.2	18.3	33.9	17.8	21.6	30.0	20.6	29.5	19.7	29.1	6.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	14.3	24.0	18.0	12.9	23.6	16.6	11.8	22.5	63.1	29.8	59.3	29.4	56.2	29.0	31.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.9	(b) 10.5	(c) 9.4	(e) 0.9	(f) 42.5	(g) 0.8	(h) 1.7	(i) 0.3	(j) 43.7	(k) -0.2	(l) 44.7	(m) -0.7	(n) 45.6	(o) -1.3	(p) 46.9		
(a) 11.9	(b) 10.5	(c) 9.4	(e) 0.9	(f) 42.5	(g) 0.8	(h) 1.7	(i) 0.3	(j) 43.7	(k) -0.2	(l) 44.7	(m) -0.7	(n) 45.6	(o) -1.3	(p) 46.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	23.4	23.2	20.5	17.4	14.1	11.4	10.7	11.3	13.5	16.3	19.3	21.2
	DBStd	5.69	4.43	4.47	4.02	3.41	2.63	2.08	1.96	2.27	2.96	3.95	4.43	4.48
	HDD10.0	36	0	0	0	0	1	9	15	10	2	0	0	0
	HDD18.3	1172	3	3	18	56	134	209	236	218	149	92	39	15
	CDD10.0	2528	415	369	326	223	129	50	37	51	108	194	278	348
	CDD18.3	623	159	140	85	29	4	0	0	0	6	28	68	104
	CDH23.3	7654	1996	1703	959	281	23	1	0	3	56	359	885	1387
	CDH26.7	3816	1089	893	441	88	3	0	0	1	12	142	415	732
Wind	WSAvg	4.5	4.7	4.4	4.3	3.9	3.9	3.9	4.4	4.5	4.8	5.0	4.9	4.9
Precipitation	PrecAvg	429	23	15	25	30	44	53	56	51	49	43	25	21
	PrecMax	624	92	76	140	79	88	101	109	103	117	91	89	69
	PrecMin	252	0	0	0	2	9	9	14	10	15	7	1	3
	PrecStd	92	23	19	32	22	23	26	26	29	23	25	19	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	40.0	38.0	33.0	26.2	20.7	19.4	23.1	28.2	34.4	37.8	40.5
		MCWB	19.6	19.7	18.3	16.8	14.6	13.9	12.5	13.7	14.4	15.7	18.1	19.0
	2%	DB	38.6	37.3	34.1	29.0	22.9	17.8	17.2	20.0	24.6	30.5	34.1	37.1
		MCWB	19.1	19.5	18.1	15.6	14.0	12.6	11.8	12.6	14.1	14.8	16.9	17.7
	5%	DB	35.7	34.8	31.6	26.4	20.7	16.5	15.7	17.8	22.0	27.3	31.4	34.0
		MCWB	18.5	18.7	17.5	15.0	13.5	12.3	11.4	11.9	13.5	14.6	16.5	17.1
	10%	DB	32.7	32.1	28.7	24.1	18.8	15.3	14.6	15.8	19.6	24.2	28.5	30.8
		MCWB	18.1	18.2	16.7	14.5	13.3	11.9	11.0	11.3	12.9	13.8	15.8	16.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	23.7	21.2	18.8	16.8	15.5	14.0	14.8	17.2	18.2	20.4	21.5
		MCDB	28.2	33.2	29.2	24.3	20.5	17.8	16.5	19.8	23.7	25.8	28.9	29.0
	2%	WB	21.6	21.7	20.1	17.6	15.5	13.8	13.0	13.6	15.4	16.8	19.0	20.0
		MCDB	30.6	29.8	27.5	23.4	19.5	16.3	15.4	17.9	21.5	24.2	28.0	29.1
	5%	WB	20.5	20.6	19.0	16.7	14.7	13.0	12.2	12.6	14.3	15.8	18.0	18.9
		MCDB	30.6	29.2	27.5	23.0	18.5	15.3	14.5	16.2	19.6	23.5	27.2	28.9
	10%	WB	19.4	19.5	17.9	15.7	14.0	12.3	11.5	11.8	13.4	14.8	16.9	17.8
		MCDB	30.1	29.2	26.8	21.9	17.9	14.6	13.9	15.1	18.1	22.3	26.4	27.4
Mean Daily Temperature Range	5% DB	MDBR	12.5	11.9	11.3	10.4	8.7	8.0	7.9	9.1	10.0	11.5	12.0	12.2
		MCDBR	17.2	15.4	15.3	14.2	11.5	9.5	9.3	12.4	14.7	17.0	16.7	17.6
		MCWBR	5.7	5.5	5.4	5.7	5.5	5.8	5.7	6.9	6.8	6.4	5.8	6.0
	5% WB	MCDBR	12.8	11.8	12.1	10.7	8.7	7.7	7.8	10.1	12.0	13.2	13.6	13.2
		MCWBR	5.5	5.5	5.4	5.5	5.1	5.4	5.4	6.3	6.6	5.8	5.7	6.0
Clear-Sky Solar Irradiance	taub	0.345	0.343	0.326	0.319	0.308	0.298	0.298	0.310	0.335	0.348	0.349	0.340	
	taud	2.507	2.533	2.568	2.572	2.586	2.600	2.589	2.535	2.460	2.430	2.459	2.508	
	Ebn at Noon	991	972	953	903	859	843	862	899	927	956	980	1000	
	Edh at Noon	113	106	95	84	73	67	72	85	104	116	118	114	
All-Sky Solar Radiation	RadAvg	7.87	6.94	5.65	4.10	2.82	2.32	2.52	3.43	4.70	6.09	7.17	7.71	
	RadStd	0.40	0.33	0.26	0.21	0.12	0.14	0.10	0.22	0.36	0.38	0.34	0.29	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	+72
(47) Regional (25 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-92	+157	+70

Nomenclature: See separate page