

ADELAIDE PARAFIELD, Australia

WMO: 956770

Lat: 34.7978S

Lon: 138.6281E

Elev: 34

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.6	38.9	26.0	20.0	78.9	29.2	23.3	74.0	25.3	54.6	23.2	55.2	2.5	40	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.5	102.0	67.3	97.8	66.1	93.6	64.9	71.8	87.8	69.7	87.1	67.9	85.8	12.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	101.2	76.4	64.7	91.5	74.9	62.0	83.2	73.4	35.5	87.6	33.7	86.5	32.2	86.1	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.5	21.1	19.1	DB	32.4	108.9	1.7	3.0	31.2	111.0	30.2	112.8	29.3	114.5	28.1	116.6	(4)
(5)			WB	31.9	74.5	1.7	2.4	30.6	76.3	29.6	77.7	28.7	79.1	27.4	80.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	74.3	73.9	69.1	63.4	57.4	52.4	51.3	52.4	56.6	61.4	66.9	70.4	(6)	
	DBStd	10.43	8.29	8.31	7.47	6.20	4.96	3.97	3.87	4.36	5.56	7.21	8.22	8.33	(7)	
	HDD50	75	0	0	0	0	2	19	31	20	3	0	0	0	(8)	
	HDD65	2108	6	8	32	101	244	377	423	390	263	164	72	28	(9)	
	CDD50	4600	752	669	593	402	231	92	72	96	201	354	506	632	(10)	
	CDD65	1158	293	257	160	54	8	0	0	1	11	52	127	195	(11)	
	CDH74	14403	3727	3173	1815	535	43	1	0	6	114	693	1670	2626	(12)	
	CDH80	7249	2059	1699	841	169	5	0	0	1	22	268	792	1393	(13)	
(14) Wind	WSAvg	9.4	10.3	9.8	9.2	8.2	7.9	7.8	8.9	9.1	9.9	10.2	10.3	10.6	(14)	
(15) Precipitation	PrecAvg	17.9	0.8	0.6	1.0	1.4	2.0	2.2	2.5	2.2	1.8	1.8	0.9	0.9	(15)	
	PrecMax	25.6	2.4	3.0	4.1	3.1	4.1	4.6	4.5	4.7	3.7	4.1	1.7	1.9	(16)	
	PrecMin	12.2	0.0	0.0	0.0	0.0	0.5	0.4	0.7	0.6	0.7	0.3	0.1	0.2	(17)	
	PrecStd	3.7	0.7	0.8	1.1	0.8	0.9	1.2	1.1	1.1	0.8	1.1	0.5	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.6	104.7	100.6	91.5	79.3	69.4	67.6	73.8	83.0	94.2	100.6	105.2	(19)	
		MCWB	67.9	70.7	66.5	62.2	58.5	57.1	55.4	56.7	59.5	61.5	65.8	67.3	(20)	
	2%	DB	102.1	99.8	94.0	84.6	73.6	64.2	63.4	68.6	77.0	87.1	94.0	99.3	(21)	
		MCWB	67.5	68.7	65.2	60.9	57.7	55.0	53.2	54.8	57.8	60.0	63.4	64.8	(22)	
	5%	DB	96.8	95.4	89.2	79.9	69.5	61.9	60.8	64.4	72.4	81.6	88.9	93.6	(23)	
		MCWB	66.7	66.7	63.9	59.5	56.8	54.2	52.8	53.4	56.7	59.1	62.2	63.6	(24)	
	10%	DB	91.3	90.5	84.1	75.8	66.3	59.9	58.7	61.0	68.2	76.4	83.7	87.8	(25)	
		MCWB	65.2	65.8	62.9	58.7	56.3	53.6	52.1	52.5	55.7	57.5	61.1	62.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.3	75.6	71.0	66.5	62.9	59.6	57.4	59.1	64.1	65.5	69.8	71.5	(27)	
		MCDB	87.8	90.8	86.5	76.1	69.9	64.1	61.8	68.3	75.5	81.1	90.0	86.5	(28)	
	2%	WB	71.5	72.5	68.7	64.0	60.4	57.2	55.6	56.5	60.6	62.9	66.8	68.6	(29)	
		MCDB	87.8	89.6	83.0	74.9	68.2	62.1	60.0	64.4	72.0	78.2	84.1	86.4	(30)	
	5%	WB	69.3	69.7	66.6	62.3	58.9	55.7	54.2	54.9	58.3	61.0	64.9	66.3	(31)	
		MCDB	88.8	86.3	81.8	73.8	66.0	60.0	58.6	61.3	68.6	75.8	81.2	85.7	(32)	
	10%	WB	67.2	67.7	64.6	60.7	57.5	54.4	53.0	53.6	56.5	59.1	62.8	64.4	(33)	
		MCDB	87.4	85.9	81.2	72.3	64.3	58.6	57.3	59.3	65.5	72.2	79.5	83.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.5	22.4	20.9	19.6	16.3	14.9	14.7	16.5	18.4	21.5	22.4	22.9	(35)	
		MCDBR	31.3	28.3	27.6	26.3	21.0	17.7	16.9	22.2	26.3	30.6	30.2	31.5	(36)	
	5% WB	MCWBR	10.3	10.0	9.8	10.7	10.3	11.0	10.3	12.4	12.6	11.8	10.7	10.8	(37)	
		MCWBR	24.7	23.0	22.4	19.9	16.4	14.2	14.5	17.9	22.1	25.2	26.0	24.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.346	0.343	0.326	0.320	0.309	0.299	0.299	0.311	0.335	0.349	0.350	0.341	(40)	
		taud	2.511	2.536	2.572	2.576	2.590	2.602	2.591	2.539	2.465	2.433	2.463	2.511	(41)	
	Ebn at Noon		314	308	302	286	272	267	273	285	294	303	311	317	(42)	
		Edh at Noon	36	34	30	27	23	21	23	27	33	37	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2488	2189	1782	1292	888	730	792	1082	1483	1924	2268	2440	(44)	
	RadStd		125	104	82	68	38	45	33	69	114	121	106	93	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	-166	+230	+139	(46)
(47)	Regional (25 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-166	+283	+126	(47)

Nomenclature: See separate page