

ADELAIDE PARAFIELD, Australia

WMO: 956770

Lat: 34.7978S

Lon: 138.6281E

Elev: 10

StdP: 101.20

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.6	3.8	-3.3	2.9	26.0	-1.5	3.3	23.4	11.3	12.5	10.4	12.9	1.1	40	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.1	38.9	19.6	36.5	18.9	34.2	18.3	22.1	31.0	20.9	30.6	19.9	29.9	5.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.5	24.7	18.1	13.1	23.8	16.7	11.9	23.0	64.7	30.9	60.5	30.3	57.1	30.0	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.4	8.5	DB	0.2	42.7	0.9	1.7	-0.4	43.9	-1.0	44.9	-1.5	45.8	-2.2	47.0	(4)
(5)			WB	-0.1	23.6	1.0	1.4	-0.8	24.6	-1.3	25.4	-1.8	26.2	-2.5	27.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	23.5	23.3	20.6	17.4	14.1	11.3	10.7	11.4	13.7	16.3	19.4	21.3	(6)	
	DBStd	5.79	4.60	4.62	4.15	3.44	2.76	2.21	2.15	2.42	3.09	4.00	4.56	4.63	(7)	
	HDD10.0	42	0	0	0	0	1	11	17	11	2	0	0	0	(8)	
	HDD18.3	1171	3	4	18	56	136	209	235	217	146	91	40	16	(9)	
	CDD10.0	2556	418	372	329	223	128	51	40	53	112	197	281	351	(10)	
	CDD18.3	643	163	143	89	30	4	0	0	1	6	29	71	108	(11)	
	CDH23.3	8002	2071	1763	1008	297	24	1	0	3	63	385	928	1459	(12)	
	CDH26.7	4027	1144	944	467	94	3	0	0	1	12	149	440	774	(13)	
(14) Wind	WSAvg	4.2	4.6	4.4	4.1	3.7	3.5	3.5	4.0	4.1	4.4	4.6	4.6	4.7	(14)	
(15) Precipitation	PrecAvg	455	20	14	25	36	50	56	64	57	45	45	22	23	(15)	
	PrecMax	650	62	76	104	80	104	117	115	119	93	103	42	49	(16)	
	PrecMin	309	0	0	0	1	12	11	17	14	17	7	2	4	(17)	
	PrecStd	93	19	20	28	20	24	31	28	29	21	29	12	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.0	40.4	38.1	33.0	26.3	20.8	19.8	23.2	28.3	34.5	38.1	40.7	(19)	
		MCWB	20.0	21.5	19.1	16.8	14.7	14.0	13.0	13.7	15.3	16.4	18.8	19.6	(20)	
	2%	DB	38.9	37.7	34.4	29.2	23.1	17.9	17.5	20.3	25.0	30.6	34.5	37.4	(21)	
		MCWB	19.7	20.4	18.5	16.1	14.3	12.8	11.8	12.7	14.3	15.6	17.4	18.2	(22)	
	5%	DB	36.0	35.2	31.8	26.6	20.8	16.6	16.0	18.0	22.4	27.5	31.6	34.2	(23)	
		MCWB	19.3	19.3	17.7	15.3	13.8	12.3	11.5	11.9	13.7	15.0	16.8	17.6	(24)	
	10%	DB	32.9	32.5	28.9	24.3	19.1	15.5	14.8	16.1	20.1	24.7	28.7	31.0	(25)	
		MCWB	18.5	18.8	17.2	14.8	13.5	12.0	11.2	11.4	13.2	14.2	16.2	16.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	24.2	21.6	19.2	17.1	15.3	14.1	15.1	17.8	18.6	21.0	21.9	(27)	
		MCDB	31.0	32.7	30.3	24.5	21.0	17.8	16.6	20.1	24.2	27.3	32.2	30.3	(28)	
	2%	WB	21.9	22.5	20.4	17.8	15.8	14.0	13.1	13.6	15.9	17.2	19.3	20.3	(29)	
		MCDB	31.0	32.0	28.4	23.8	20.1	16.7	15.6	18.0	22.2	25.7	29.0	30.2	(30)	
	5%	WB	20.7	21.0	19.2	16.8	14.9	13.2	12.4	12.7	14.6	16.1	18.3	19.1	(31)	
		MCDB	31.6	30.2	27.7	23.2	18.9	15.6	14.8	16.3	20.3	24.3	27.3	29.8	(32)	
	10%	WB	19.6	19.8	18.1	15.9	14.2	12.4	11.7	12.0	13.6	15.1	17.1	18.0	(33)	
		MCDB	30.8	29.9	27.3	22.4	18.0	14.8	14.0	15.2	18.6	22.3	26.4	28.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	12.5	11.6	10.9	9.1	8.3	8.2	9.1	10.2	12.0	12.5	12.7	(35)	
		MCDBR	17.4	15.7	15.4	14.6	11.7	9.8	9.4	12.3	14.6	17.0	16.8	17.5	(36)	
	5% WB	MCWBR	5.7	5.6	5.5	5.9	5.7	6.1	5.7	6.9	7.0	6.6	5.9	6.0	(37)	
		MCWBR	13.7	12.8	12.5	11.1	9.1	7.9	8.1	9.9	12.3	14.0	14.4	13.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.346	0.343	0.326	0.320	0.309	0.299	0.299	0.311	0.335	0.349	0.350	0.341	(40)	
		taud	2.511	2.536	2.572	2.576	2.590	2.602	2.591	2.539	2.465	2.433	2.463	2.511	(41)	
	Ebn at Noon		990	971	952	902	858	841	860	897	926	955	980	999	(42)	
		Edh at Noon	112	106	95	84	73	67	71	85	104	116	117	113	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.84	6.90	5.62	4.07	2.80	2.30	2.50	3.41	4.67	6.07	7.15	7.69	(44)	
(45)	RadStd		0.39	0.33	0.26	0.21	0.12	0.14	0.10	0.22	0.36	0.38	0.33	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		+0.47	N/A	N/A	N/A	N/A	N/A	-92	+128	+77	(46)	
(47)	Regional (25 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-92	+157	+70	(47)	

Nomenclature: See separate page