

WILCANNIA, Australia

WMO: 956950

Lat: 31.5194S

Lon: 143.3850E

Elev: 311

StdP: 14.53

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.1	36.4	16.6	12.9	66.3	19.4	14.7	66.8	23.3	63.0	21.2	62.5	6.2	230	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.2	107.8	68.1	104.3	67.4	101.1	66.3	73.8	86.1	71.9	88.7	70.2	89.4	12.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.8	114.7	77.8	67.9	103.7	76.7	65.1	93.9	75.8	37.6	85.1	35.8	87.7	34.3	89.3	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	21.3	18.8	DB	29.6	112.3	1.7	2.9	28.3	114.3	27.3	116.0	26.3	117.6	25.0	119.7	(4)
(5)			WB	28.0	76.2	1.9	2.7	26.6	78.2	25.5	79.8	24.5	81.3	23.1	83.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.2	84.2	81.6	75.0	67.4	58.1	52.5	51.6	54.2	60.7	67.9	74.5	79.4	(6)	
	DBStd	13.07	7.57	7.61	6.99	6.59	5.57	4.90	4.67	5.40	6.60	7.57	8.08	7.60	(7)	
	HDD50	81	0	0	0	0	3	28	34	15	1	0	0	0	(8)	
	HDD65	1642	0	0	7	48	224	377	415	341	164	54	11	1	(9)	
	CDD50	6349	1060	886	775	521	254	102	84	144	322	555	734	912	(10)	
	CDD65	2437	595	466	317	119	10	1	1	4	36	145	295	448	(11)	
	CDH74	34056	8905	6392	3853	1413	144	5	8	81	676	2120	4099	6360	(12)	
	CDH80	19318	5678	3838	1986	530	12	0	0	13	240	1004	2263	3754	(13)	
(14) Wind	WSAvg	10.0	11.2	10.8	10.0	9.0	8.7	8.5	8.7	9.3	10.1	11.0	11.1	11.1	(14)	
(15) Precipitation	PrecAvg	10.4	1.3	0.8	1.0	0.9	0.9	0.7	0.7	0.7	0.6	0.9	0.7	1.0	(15)	
	PrecMax	26.5	8.7	4.7	5.4	7.1	3.6	3.1	2.2	2.8	3.1	3.4	2.2	5.0	(16)	
	PrecMin	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	5.1	2.2	1.1	1.2	1.4	0.9	0.7	0.6	0.7	0.7	0.9	0.7	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	112.7	110.6	103.3	94.7	81.7	73.9	74.9	81.0	92.2	99.1	108.3	108.7	(19)	
		MCWB	69.2	70.8	67.0	63.7	59.5	58.5	55.7	56.2	59.7	62.8	66.9	67.0	(20)	
	2%	DB	108.5	105.9	98.7	89.8	78.3	69.1	69.6	75.6	86.3	94.9	101.8	104.4	(21)	
		MCWB	68.1	68.4	65.7	62.7	58.4	55.0	52.7	54.7	57.6	61.8	64.9	66.5	(22)	
	5%	DB	104.9	101.7	94.5	86.2	74.3	65.7	65.9	71.2	81.9	90.5	96.8	100.9	(23)	
		MCWB	68.0	67.0	64.4	61.5	57.3	53.8	52.0	52.9	56.5	60.3	63.2	65.2	(24)	
	10%	DB	101.1	97.6	90.6	82.3	70.3	62.7	62.6	67.5	76.9	85.7	92.5	96.9	(25)	
		MCWB	67.1	66.5	63.9	60.3	55.7	52.7	51.3	51.5	55.2	59.0	62.5	64.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	78.0	72.8	69.1	64.5	60.9	61.8	60.0	63.5	67.0	70.9	74.6	(27)	
		MCDB	86.4	87.7	83.3	83.6	70.1	68.5	66.2	68.7	76.7	83.5	91.2	86.0	(28)	
	2%	WB	73.3	74.4	70.3	65.8	61.1	58.0	56.2	57.0	60.4	64.7	68.9	71.0	(29)	
		MCDB	87.4	88.0	82.5	78.9	72.2	64.8	64.2	71.4	79.1	82.9	87.4	86.5	(30)	
	5%	WB	71.5	72.2	68.4	63.9	59.0	56.0	53.6	54.7	58.3	62.8	67.0	69.0	(31)	
		MCDB	92.0	87.7	83.4	78.0	69.9	62.4	62.2	68.9	76.7	84.2	85.5	88.8	(32)	
	10%	WB	69.9	70.1	66.5	62.1	57.1	54.2	51.9	52.5	56.4	60.9	65.3	67.2	(33)	
		MCDB	92.9	88.7	84.6	77.9	68.7	60.7	61.1	65.5	74.0	82.3	84.8	89.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	26.2	24.7	24.9	25.4	23.4	20.7	22.3	24.9	27.3	27.7	26.8	26.7	(35)	
		MCDBR	30.7	29.4	30.2	29.6	27.9	24.8	26.7	30.0	34.9	34.4	32.9	30.9	(36)	
	5% WB	MCWBR	11.5	10.7	11.9	13.0	13.3	13.6	14.4	14.9	15.5	14.5	12.8	11.7	(37)	
		MCWBR	23.7	20.9	22.2	23.3	22.4	19.0	22.0	25.9	28.7	27.3	25.0	24.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.335	0.337	0.319	0.306	0.293	0.285	0.285	0.295	0.338	0.331	0.343	0.332	(40)	
		taud	2.516	2.539	2.570	2.577	2.579	2.599	2.580	2.533	2.398	2.444	2.449	2.496	(41)	
	Ebn at Noon		318	312	307	295	283	279	284	294	295	310	314	320	(42)	
		Edh at Noon	36	34	31	27	24	23	24	28	36	37	38	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		2552	2284	1969	1528	1135	929	1040	1349	1786	2182	2381	2571	(44)	
	RadStd		127	137	125	75	65	54	52	74	96	119	160	93	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page