

WHITE CLIFFS, Australia

WMO: 956990

Lat: 30.8517S

Lon: 143.0742E

Elev: 520

StdP: 14.42

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.7	40.5	15.2	12.1	73.3	18.4	14.1	73.5	26.2	64.9	23.4	64.1	7.2	190	0.535

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.1	107.2	67.7	103.7	67.0	100.8	66.1	74.1	85.9	72.3	87.4	70.8	88.2	12.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.5	118.4	77.9	68.6	107.2	77.3	66.0	97.7	76.0	38.1	86.1	36.4	86.7	34.9	88.2	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	22.3	20.1	DB	34.3	111.1	1.3	3.1	33.4	113.4	32.6	115.2	31.9	117.0	31.0	119.3	(4)
(5)			WB	31.1	76.0	1.9	2.4	29.8	77.7	28.7	79.1	27.6	80.5	26.3	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.3	86.4	83.6	77.9	69.0	60.0	53.6	53.2	56.3	63.4	71.1	76.6	81.4	(6)	
	DBStd	13.24	7.20	7.41	7.23	6.54	5.61	4.53	4.81	5.47	6.64	7.81	7.97	7.54	(7)	
	HDD50	37	0	0	0	0	1	15	17	4	0	0	0	0	(8)	
	HDD65	1345	0	0	3	33	176	343	367	279	110	28	5	1	(9)	
	CDD50	7082	1129	942	865	570	311	122	116	199	403	653	797	975	(10)	
	CDD65	2917	664	522	403	154	21	1	1	9	63	216	352	511	(11)	
	CDH74	38588	9969	7207	4708	1434	151	4	11	90	765	2662	4538	7049	(12)	
	CDH80	21678	6361	4326	2402	496	11	0	0	16	259	1250	2444	4113	(13)	
(14) Wind	WSAvg	10.7	11.9	11.7	11.0	9.7	9.2	9.2	9.4	10.1	11.0	11.6	11.6	12.0	(14)	
(15) Precipitation	PrecAvg	10.5	1.5	0.9	1.0	0.7	1.0	0.6	0.7	0.6	0.7	0.9	0.8	0.8	(15)	
	PrecMax	28.4	10.5	5.1	10.0	4.3	3.6	2.6	3.3	3.0	2.9	4.8	3.3	3.7	(16)	
	PrecMin	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	5.2	2.2	1.2	1.7	1.1	0.9	0.6	0.7	0.7	0.7	0.9	0.7	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	112.2	109.8	102.3	94.2	81.6	72.1	75.3	82.1	91.9	99.6	107.7	108.2	(19)	
		MCWB	68.6	68.5	67.0	64.3	59.7	56.9	56.1	57.1	58.0	63.0	66.0	66.5	(20)	
	2%	DB	108.1	105.5	98.7	88.9	78.2	68.3	70.7	76.1	86.2	95.1	101.6	103.5	(21)	
		MCWB	67.9	68.1	65.9	62.9	58.8	54.7	53.6	54.6	57.0	61.7	64.2	65.8	(22)	
	5%	DB	104.4	101.6	95.1	85.7	74.9	65.4	67.0	72.1	82.5	91.6	97.1	100.1	(23)	
		MCWB	67.9	67.0	65.0	61.0	57.6	53.7	52.8	52.8	56.0	60.4	63.3	64.9	(24)	
	10%	DB	101.2	98.0	91.6	82.2	71.0	62.8	63.7	68.4	78.0	87.3	92.7	96.7	(25)	
		MCWB	67.2	66.7	64.7	60.0	56.0	52.8	51.6	51.5	54.9	59.3	62.1	64.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.6	78.0	73.1	69.5	65.6	60.8	63.8	59.4	63.6	68.0	70.9	75.2	(27)	
		MCDB	86.6	89.4	84.5	82.1	70.2	64.9	68.8	68.2	73.7	80.8	89.1	84.5	(28)	
	2%	WB	74.4	73.9	71.1	65.8	61.7	57.9	57.4	56.6	60.3	65.3	69.2	71.9	(29)	
		MCDB	86.2	86.1	85.2	77.5	72.1	63.8	65.3	71.7	78.4	83.3	85.5	84.4	(30)	
	5%	WB	72.4	71.9	69.4	64.1	59.4	56.0	54.5	54.5	58.2	63.2	67.5	69.8	(31)	
		MCDB	89.0	86.9	83.6	76.8	70.9	62.1	63.5	70.0	76.2	83.5	82.2	86.9	(32)	
	10%	WB	70.8	70.1	67.6	62.2	57.6	54.4	52.1	52.6	56.3	61.5	65.9	67.8	(33)	
		MCDB	91.2	88.2	83.4	77.2	69.5	60.8	62.3	66.7	74.3	82.9	82.8	87.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	22.1	21.1	20.1	20.8	19.3	17.5	19.4	21.1	22.9	23.6	22.6	22.4	(35)	
		MCDBR	25.6	24.5	23.3	24.3	22.6	20.7	23.0	25.4	28.9	27.8	27.0	25.6	(36)	
	5% WB	MCWBR	9.0	8.3	8.6	10.0	10.2	10.9	12.2	11.6	12.4	11.1	9.5	9.0	(37)	
		MCWBR	20.4	19.3	18.2	19.0	18.5	15.0	18.3	22.0	23.5	23.2	21.1	20.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.336	0.337	0.319	0.305	0.293	0.283	0.284	0.294	0.338	0.332	0.344	0.332	(40)	
		taud	2.513	2.540	2.570	2.578	2.574	2.596	2.576	2.527	2.391	2.432	2.444	2.496	(41)	
	Ebn at Noon		318	312	308	296	285	280	285	295	296	310	314	321	(42)	
		Edh at Noon	36	34	31	28	24	23	24	28	36	37	38	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		2559	2301	1997	1559	1174	970	1085	1400	1831	2208	2400	2564	(44)	
	RadStd		120	138	125	76	66	52	54	69	91	119	156	103	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page