

GRIFFITH AP, Australia

WMO: 957040

Lat: 34.249S

Lon: 146.069E

Elev: 443

StdP: 14.46

Time Zone: 10.00 (AUS)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.7	34.8	21.7	16.5	75.8	24.9	19.3	69.6	23.5	55.9	21.6	54.4	2.1	320	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.1	103.6	66.5	99.6	66.0	96.1	65.3	72.2	86.4	70.6	86.2	69.1	85.8	12.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	110.2	74.4	66.8	100.2	73.9	64.2	91.4	73.7	36.2	85.6	34.7	85.7	33.5	85.8	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	20.6	18.4	DB	28.6	108.9	1.9	3.1	27.2	111.2	26.1	113.0	25.0	114.7	23.6	116.9	(4)
(5)			WB	28.1	75.3	2.2	2.1	26.5	76.8	25.2	78.0	23.9	79.2	22.3	80.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	79.8	77.4	71.8	64.0	55.2	50.5	48.9	50.4	56.0	62.9	70.3	74.4	(6)
(7)		DBStd	12.54	7.71	7.40	7.17	6.47	5.45	4.71	4.08	4.78	6.34	7.55	7.93	7.61	(7)
(8)		HDD50	196	0	0	0	0	14	49	72	51	9	1	0	0	(8)
(9)		HDD65	2270	1	4	21	94	305	436	500	454	281	132	33	9	(9)
(10)		CDD50	5082	923	767	676	420	175	64	36	63	190	402	608	758	(10)
(11)		CDD65	1681	459	351	232	63	2	0	0	1	12	68	191	302	(11)
(12)		CDH74	21641	6311	4299	2563	658	29	0	0	12	203	997	2515	4054	(12)
(13)		CDH80	11117	3715	2306	1147	180	1	0	0	1	48	384	1217	2118	(13)
(14)	Wind	WSAvg	8.9	10.3	10.0	9.2	7.9	7.1	7.5	7.4	8.2	9.1	9.6	10.0	10.1	(14)
(15)	Precipitation	PrecAvg	16.0	1.5	1.0	1.2	1.3	1.6	1.4	1.4	1.5	1.5	1.5	1.2	1.2	(15)
(16)		PrecMax	26.0	10.1	5.4	8.5	6.7	5.4	2.8	3.5	3.5	4.6	5.6	5.0	4.1	(16)
(17)		PrecMin	7.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	0.2	0.2	0.0	0.0	(17)
(18)		PrecStd	4.7	1.9	1.3	1.5	1.3	1.2	0.9	1.0	0.8	1.0	1.3	1.1	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.1	106.8	99.7	90.3	77.7	68.9	67.5	74.9	85.8	94.0	102.2	105.5	(19)
(20)			MCWB	69.1	68.8	65.8	62.4	58.5	55.9	53.5	54.8	57.8	61.1	64.5	66.0	(20)
(21)		2%	DB	104.8	101.0	94.0	84.7	73.4	64.8	63.6	68.5	79.3	88.8	96.6	99.9	(21)
(22)			MCWB	67.6	66.5	64.9	61.5	57.1	54.5	52.6	53.1	56.9	59.9	63.7	65.1	(22)
(23)		5%	DB	100.6	96.5	90.1	81.2	69.8	62.2	60.7	64.9	75.1	84.2	91.7	95.5	(23)
(24)			MCWB	67.1	66.5	63.8	60.3	56.0	53.3	52.0	51.7	56.1	59.3	62.8	64.2	(24)
(25)		10%	DB	96.3	92.3	86.5	77.5	66.4	59.5	58.2	61.8	70.8	79.4	87.0	91.2	(25)
(26)			MCWB	66.2	65.3	63.1	59.2	54.7	52.2	50.6	50.9	54.2	57.6	60.9	63.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.3	75.6	71.6	66.8	62.5	59.0	59.3	58.3	62.5	66.6	69.8	72.6	(27)
(28)			MCD B	87.2	83.0	79.6	77.2	66.5	63.1	61.7	63.5	75.0	75.9	84.0	81.3	(28)
(29)		2%	WB	71.8	72.8	69.4	64.4	59.3	56.7	55.3	55.7	60.0	63.7	67.7	69.9	(29)
(30)			MCD B	88.7	86.7	79.8	74.8	67.5	61.4	59.1	64.6	72.0	76.2	81.0	84.0	(30)
(31)		5%	WB	70.3	70.8	67.3	62.6	57.6	55.1	53.1	53.3	57.8	61.8	66.2	67.7	(31)
(32)			MCD B	89.0	86.2	81.1	75.4	66.3	59.9	58.5	62.7	70.7	76.0	80.8	84.3	(32)
(33)		10%	WB	69.0	68.9	65.5	60.9	56.1	53.4	51.3	51.6	55.7	60.0	64.4	66.0	(33)
(34)			MCD B	89.0	85.3	82.2	74.6	65.0	58.2	56.9	60.4	68.4	75.8	80.2	84.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	26.1	24.0	23.7	23.2	21.4	17.9	18.7	21.4	25.0	25.9	25.6	26.1	(35)
(36)			MCDBR	29.8	28.7	27.1	27.2	24.4	20.8	22.1	26.4	30.7	31.4	30.7	29.9	(36)
(37)			MCWBR	9.2	9.3	9.6	11.2	11.3	11.6	12.7	13.5	13.5	12.2	9.9	9.6	(37)
(38)		5% WB	MCD BR	24.7	21.6	21.6	22.0	20.5	15.6	17.9	22.5	25.4	23.9	22.8	22.5	(38)
(39)			MCWBR	9.5	8.4	9.0	9.4	10.4	9.8	11.2	12.4	12.7	11.0	8.7	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.339	0.319	0.307	0.296	0.289	0.285	0.292	0.322	0.326	0.342	0.335	(40)	
(41)		taud	2.509	2.529	2.573	2.571	2.568	2.595	2.599	2.558	2.462	2.480	2.471	2.501	(41)	
(42)		Ebn at Noon	317	310	305	291	277	272	279	292	299	311	313	319	(42)	
(43)		Edh at Noon	36	34	30	27	23	22	23	27	33	35	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2482	2194	1853	1383	1006	786	867	1169	1622	2038	2281	2506	(44)	
(45)		RadStd	141	119	105	62	51	56	52	85	112	129	156	94	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	+0.88	N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page