

YANCO, Australia

WMO: 957050

Lat: 34.6222S

Lon: 146.4328E

Elev: 540

StdP: 14.41

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.7	37.7	21.8	16.7	75.5	25.2	19.7	72.1	24.1	56.3	20.8	53.2	4.0	230	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.9	102.2	66.6	98.2	66.0	94.8	65.1	71.8	86.1	70.4	85.6	69.1	85.1	11.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	108.8	74.3	66.4	99.3	74.2	64.2	91.8	73.6	35.9	86.5	34.6	84.9	33.5	85.2	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	21.2	18.5	DB	31.6	108.3	1.8	3.3	30.2	110.6	29.2	112.5	28.1	114.4	26.8	116.8	(4)
(5)			WB	31.0	74.6	1.8	2.2	29.7	76.2	28.6	77.5	27.6	78.8	26.2	80.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.7	79.1	77.0	72.1	64.6	56.2	51.0	49.6	51.2	56.5	63.5	70.3	74.1	(6)
(7)		DBStd	12.15	7.64	7.62	7.10	6.51	5.42	4.48	3.93	4.63	6.14	7.60	8.19	7.34	(7)
(8)		HDD50	151	0	0	0	0	8	40	56	38	8	1	0	0	(8)
(9)		HDD65	2148	1	5	19	84	276	421	478	429	266	123	36	10	(9)
(10)		CDD50	5147	904	755	684	439	201	69	43	75	203	419	609	746	(10)
(11)		CDD65	1667	440	340	237	72	4	0	0	1	11	76	195	291	(11)
(12)		CDH74	20164	5850	4090	2452	564	19	0	0	7	137	926	2449	3670	(12)
(13)		CDH80	9957	3326	2140	1042	134	1	0	0	1	28	333	1147	1805	(13)
(14)	Wind	WSAvg	8.6	10.1	9.5	8.8	7.6	7.1	7.3	7.3	7.8	8.5	9.4	10.0	10.0	(14)
(15)	Precipitation	PrecAvg	16.7	1.2	1.5	1.3	0.9	1.3	1.8	1.5	1.4	1.6	1.5	1.5	1.3	(15)
(16)		PrecMax	28.7	5.0	6.0	6.4	3.5	3.3	4.4	3.3	2.8	6.1	4.9	3.5	4.9	(16)
(17)		PrecMin	7.2	0.0	0.0	0.0	0.0	0.1	0.6	0.2	0.1	0.1	0.0	0.1	0.0	(17)
(18)		PrecStd	5.1	1.1	1.4	1.5	0.8	0.9	1.0	0.8	0.9	1.3	1.2	0.8	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.3	106.6	99.2	89.0	76.5	67.4	65.9	72.7	84.0	93.3	101.4	102.4	(19)
(20)			MCWB	68.6	68.6	66.6	62.8	58.5	55.0	53.1	54.9	58.0	60.9	64.9	64.3	(20)
(21)		2%	DB	103.3	100.9	93.3	83.6	73.0	63.8	62.2	67.5	77.6	87.9	95.7	97.9	(21)
(22)			MCWB	67.6	66.6	65.3	61.8	57.5	54.1	52.9	53.3	56.6	60.5	63.6	64.8	(22)
(23)		5%	DB	98.8	95.8	89.5	80.3	69.6	61.2	59.5	63.9	73.5	83.4	91.2	93.7	(23)
(24)			MCWB	66.8	66.5	64.6	60.3	56.2	53.0	51.7	51.9	55.3	59.1	62.3	63.9	(24)
(25)		10%	DB	94.8	91.5	85.9	76.8	66.3	58.8	57.2	60.8	69.2	78.9	86.6	89.7	(25)
(26)			MCWB	65.8	65.6	63.2	59.3	54.9	52.2	50.7	50.8	53.9	58.0	61.1	63.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	75.2	71.5	66.9	62.5	58.4	58.5	58.3	62.0	66.3	70.2	72.3	(27)
(28)			MADB	87.8	87.1	81.9	77.9	67.0	62.1	60.7	64.7	72.1	79.9	86.8	81.8	(28)
(29)		2%	WB	71.5	72.3	69.6	64.7	59.4	56.4	55.5	55.7	59.6	63.7	67.6	69.8	(29)
(30)			MADB	87.8	86.2	79.5	74.6	68.6	60.0	58.9	63.9	70.8	77.1	82.7	83.8	(30)
(31)		5%	WB	70.2	70.4	67.7	62.9	57.8	54.8	53.2	53.5	57.4	61.9	65.7	68.0	(31)
(32)			MADB	88.0	85.2	81.6	74.2	66.7	59.1	57.4	61.4	69.1	76.0	81.0	81.8	(32)
(33)		10%	WB	68.9	68.8	65.9	61.2	56.1	53.4	51.5	51.8	55.4	60.0	63.9	65.9	(33)
(34)			MADB	88.0	84.8	80.8	73.5	64.4	57.9	56.1	59.3	67.1	75.8	80.0	82.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	24.9	23.1	21.9	20.6	18.2	15.0	14.6	17.8	21.6	24.0	24.5	24.6	(35)
(36)			MADB	27.8	27.2	24.7	23.4	20.9	17.5	17.4	22.2	26.8	28.2	28.0	27.8	(36)
(37)			MCWBR	9.0	8.9	8.8	9.4	9.7	9.7	10.0	11.2	11.7	10.7	9.1	9.1	(37)
(38)		5% WB	MADB	23.1	20.9	19.9	19.1	17.8	13.7	13.9	18.9	22.0	23.7	22.7	21.1	(38)
(39)			MCWBR	9.2	8.3	8.8	8.4	9.3	8.5	9.3	10.7	11.6	11.0	8.5	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.340	0.320	0.308	0.296	0.289	0.285	0.292	0.322	0.326	0.343	0.336	(40)	
(41)		taud	2.488	2.523	2.565	2.563	2.566	2.594	2.600	2.559	2.457	2.477	2.468	2.495	(41)	
(42)		Ebn at Noon	315	309	305	290	277	271	279	292	298	310	313	318	(42)	
(43)		Edh at Noon	36	34	30	27	23	22	22	26	33	35	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2475	2179	1840	1363	986	762	836	1137	1590	2013	2271	2497	(44)	
(45)		RadStd	141	119	102	60	49	58	51	87	119	135	153	91	145	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.83	N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page