

YANCO, Australia

WMO: 957050

Lat: 34.6222S

Lon: 146.4328E

Elev: 165

StdP: 99.36

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 2.0	(c) 3.2	(d) -5.7	(e) 2.4	(f) 24.2	(g) -3.8	(h) 2.8	(i) 22.3	(j) 10.8	(k) 13.5	(l) 9.3	(m) 11.8	(n) 1.8	(o) 230	(p) 0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 13.9	(c) 39.0	(d) 19.2	(e) 36.8	(f) 18.9	(g) 34.9	(h) 18.4	(i) 22.1	(j) 30.0	(k) 21.3	(l) 29.8	(m) 20.6	(n) 29.5	(o) 5.0	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.6	15.5	23.5	19.1	14.2	23.4	17.9	13.1	23.1	65.5	30.3	62.6	29.4	60.0	29.6	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.4	(b) 9.5	(c) 8.3	(e) -0.2	(f) 42.4	(g) 1.0	(h) 1.8	(i) -1.0	(j) 43.7	(k) -1.6	(l) 44.7	(m) -2.2	(n) 45.8	(o) -2.9	(p) 47.1		
(a) 11.4	(b) 9.5	(c) 8.3	(e) -0.5	(f) 23.7	(g) 1.0	(h) 1.2	(i) -1.3	(j) 24.5	(k) -1.9	(l) 25.3	(m) -2.5	(n) 26.0	(o) -3.2	(p) 26.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	26.2	25.0	22.3	18.1	13.5	10.5	9.8	10.7	13.6	17.5	21.3	23.4		
	DBStd	6.75	4.25	4.23	3.94	3.61	3.01	2.49	2.18	2.57	3.41	4.22	4.55	4.08		
	HDD10.0	84	0	0	0	0	4	22	31	21	4	1	0	0		
	HDD18.3	1193	1	3	11	47	153	234	266	238	148	68	20	6		
	CDD10.0	2859	502	419	380	244	112	38	24	42	113	233	338	414		
	CDD18.3	926	244	189	132	40	2	0	0	1	6	42	108	162		
	CDH23.3	11202	3250	2272	1362	313	11	0	0	4	76	514	1361	2039		
	CDH26.7	5532	1848	1189	579	74	1	0	0	1	16	185	637	1003		
(14) Wind	WSAvg	3.8	4.5	4.2	3.9	3.4	3.2	3.3	3.3	3.5	3.8	4.2	4.5	4.5		
(15) Precipitation	PrecAvg	424	31	39	34	22	32	45	37	35	41	37	39	32		
	PrecMax	730	126	152	162	90	84	111	84	72	155	124	88	124		
	PrecMin	184	0	1	0	0	2	16	6	2	3	0	3	0		
	PrecStd	129	27	35	37	20	24	25	20	22	32	31	21	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	41.4	37.3	31.7	24.7	19.7	18.8	22.6	28.9	34.0	38.6	39.1		
		MCWB	20.3	20.4	19.2	17.1	14.7	12.8	11.7	12.7	14.4	16.0	18.3	18.0		
	2%	DB	39.6	38.3	34.0	28.7	22.8	17.6	16.8	19.7	25.4	31.1	35.4	36.6		
		MCWB	19.8	19.2	18.5	16.6	14.1	12.3	11.6	11.8	13.7	15.8	17.6	18.2		
	5%	DB	37.1	35.4	31.9	26.8	20.9	16.2	15.3	17.7	23.0	28.6	32.9	34.3		
		MCWB	19.4	19.2	18.1	15.7	13.4	11.6	11.0	11.1	13.0	15.1	16.8	17.7		
	10%	DB	34.9	33.1	29.9	24.9	19.1	14.9	14.0	16.0	20.7	26.1	30.3	32.1		
		MCWB	18.8	18.6	17.3	15.2	12.7	11.2	10.4	10.4	12.2	14.5	16.1	17.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	24.0	21.9	19.4	17.0	14.7	14.7	14.6	16.7	19.1	21.2	22.4		
		MCDB	31.0	30.6	27.7	25.5	19.5	16.7	15.9	18.2	22.3	26.6	30.4	27.7		
	2%	WB	22.0	22.4	20.9	18.2	15.2	13.6	13.0	13.2	15.3	17.6	19.8	21.0		
		MCDB	31.0	30.1	26.4	23.7	20.3	15.6	15.0	17.7	21.6	25.1	28.2	28.8		
	5%	WB	21.2	21.3	19.8	17.2	14.3	12.7	11.8	12.0	14.1	16.6	18.7	20.0		
		MCDB	31.1	29.6	27.5	23.4	19.3	15.0	14.1	16.3	20.6	24.4	27.2	27.6		
	10%	WB	20.5	20.4	18.8	16.2	13.4	11.9	10.8	11.0	13.0	15.6	17.7	18.9		
		MCDB	31.1	29.3	27.1	23.1	18.0	14.4	13.4	15.2	19.5	24.3	26.7	28.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.9	12.8	12.1	11.4	10.1	8.3	8.1	9.9	12.0	13.3	13.6	13.7		
		MCDBR	15.5	15.1	13.7	13.0	11.6	9.7	9.7	12.3	14.9	15.6	15.6	15.4		
		MCWBR	5.0	4.9	4.9	5.2	5.4	5.4	5.6	6.2	6.5	6.0	5.0	5.0		
		MCDBR	12.8	11.6	11.1	10.6	9.9	7.6	7.7	10.5	12.2	13.2	12.6	11.7		
	5% WB	MCWBR	5.1	4.6	4.9	4.7	5.2	4.7	5.2	5.9	6.4	6.1	4.7	5.1		
(40) Clear-Sky Solar Irradiance	taub		0.343	0.340	0.320	0.308	0.296	0.289	0.285	0.292	0.322	0.326	0.343	0.336		
	taud		2.488	2.523	2.565	2.563	2.566	2.594	2.600	2.559	2.457	2.477	2.468	2.495		
	Ebn at Noon		993	975	960	915	872	854	879	920	941	978	987	1004		
	Edh at Noon		115	107	95	85	74	68	70	83	104	111	117	115		
(44) All-Sky Solar Radiation	RadAvg		7.80	6.87	5.80	4.30	3.11	2.40	2.64	3.58	5.01	6.35	7.16	7.87		
	RadStd		0.44	0.38	0.32	0.19	0.15	0.18	0.16	0.27	0.38	0.43	0.48	0.29		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (14 neighbors)	+0.46	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page