

CONDOBOLIN, Australia

WMO: 957080

Lat: 33.0683S

Lon: 147.2133E

Elev: 635

StdP: 14.36

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.0	32.3	15.9	12.6	71.0	19.8	15.2	65.3	24.0	56.1	21.6	56.2	1.4	290	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.5	102.8	66.1	99.1	65.4	95.7	64.5	72.3	83.6	70.8	83.5	69.4	83.5	13.1	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	112.2	75.5	67.7	104.0	74.7	65.4	96.2	74.0	36.5	83.6	35.0	83.3	33.8	83.3	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	21.1	18.7	DB	25.9	108.0	2.5	4.0	24.1	110.9	22.7	113.3	21.3	115.6	19.5	118.5	(4)
(5)			WB	24.9	75.2	2.5	2.5	23.1	77.0	21.7	78.4	20.3	79.8	18.5	81.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	80.0	78.2	71.9	63.2	55.0	49.7	48.1	50.0	56.0	63.1	70.3	75.3
	DBStd	12.79	7.18	6.81	6.56	6.29	5.41	4.77	4.53	5.09	6.32	7.51	7.74	7.17
	HDD50	238	0	0	0	0	14	62	92	60	9	1	0	0
	HDD65	2331	0	2	16	106	314	458	525	465	280	129	31	5
	CDD50	5100	929	789	680	396	168	54	32	61	190	408	608	785
	CDD65	1718	465	370	231	51	3	0	0	1	11	72	189	325
	CDH74	22191	6203	4591	2505	637	29	0	0	14	211	1063	2548	4390
	CDH80	11250	3572	2458	1066	168	0	0	0	1	46	412	1215	2312
Wind	WSAvg	8.2	10.0	9.2	8.3	6.7	6.4	6.5	7.0	7.7	8.5	9.2	9.6	10.0
Precipitation	PrecAvg	18.4	2.2	1.5	1.3	1.6	1.6	1.1	1.5	1.6	1.3	2.0	1.5	1.6
	PrecMax	26.7	10.0	4.4	5.4	9.0	5.4	3.5	3.5	3.3	4.3	6.1	4.2	5.5
	PrecMin	8.8	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.2	0.2	0.0	0.0	0.0
	PrecStd	5.4	2.4	1.4	1.3	1.9	1.3	0.9	0.9	0.9	1.0	1.5	1.2	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.5	105.9	97.7	90.0	77.4	69.3	68.3	75.6	85.6	94.2	102.8	105.0
		MCWB	68.0	68.1	63.9	61.4	59.1	55.9	53.3	56.4	57.6	60.6	63.5	65.7
	2%	DB	103.6	100.6	93.5	84.4	73.7	65.3	64.1	69.7	79.5	89.3	96.4	99.6
		MCWB	66.4	66.4	63.5	60.8	57.6	54.8	52.3	53.6	56.5	60.0	62.7	64.5
	5%	DB	99.6	96.5	89.6	80.9	70.4	62.5	60.9	65.9	75.4	84.7	91.5	95.7
		MCWB	66.6	65.5	63.8	59.6	56.3	53.8	51.4	52.2	55.6	59.1	61.8	63.4
	10%	DB	95.5	92.8	86.1	77.3	66.8	59.6	58.1	62.4	71.2	79.9	87.0	91.8
		MCWB	65.5	64.7	62.9	58.7	54.9	52.4	50.5	50.9	54.4	58.1	60.5	62.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.7	75.2	73.1	67.2	63.9	59.3	59.2	60.1	63.3	66.5	69.9	72.5
		MCDB	85.8	83.7	80.8	76.4	68.5	64.4	62.4	70.3	72.8	77.4	83.0	81.9
	2%	WB	72.4	72.1	70.2	64.6	61.1	57.1	55.0	56.7	60.4	64.1	67.8	70.1
		MCDB	85.0	84.1	79.2	75.0	67.5	61.5	59.4	64.3	69.8	77.5	80.0	81.0
	5%	WB	70.7	70.4	68.2	62.8	58.7	55.4	52.9	54.2	58.4	62.2	66.0	68.2
		MCDB	85.4	84.1	78.4	74.8	66.5	60.0	58.5	62.9	69.4	76.0	78.5	82.3
	10%	WB	69.3	68.8	66.1	60.9	56.7	53.7	51.1	51.9	56.5	60.3	64.2	66.1
		MCDB	86.2	83.6	79.9	73.6	65.0	58.8	57.1	60.8	67.9	75.5	78.6	83.8
Mean Daily Temperature Range	5% DB	MDBR	25.5	24.2	24.2	25.3	23.0	19.7	20.2	23.7	26.2	27.0	26.2	26.6
		MCDBR	29.2	28.6	27.8	29.3	27.3	24.1	25.2	29.6	32.5	32.6	31.6	30.5
		MCWBR	9.2	9.2	10.1	13.0	14.2	14.7	15.3	16.3	14.7	12.9	10.9	10.2
	5% WB	MCDBR	22.1	21.4	20.6	22.4	20.4	17.9	18.9	24.3	24.2	25.2	22.9	22.4
		MCWBR	8.6	8.4	9.0	11.0	11.4	11.8	12.5	14.7	13.1	11.6	8.8	9.5
Clear-Sky Solar Irradiance	taub	0.343	0.343	0.320	0.305	0.291	0.285	0.282	0.289	0.319	0.327	0.341	0.334	
	taud	2.514	2.542	2.588	2.592	2.592	2.616	2.611	2.570	2.469	2.479	2.483	2.521	
	Ebn at Noon	316	309	305	293	282	276	283	295	301	311	314	319	
	Edh at Noon	36	34	30	27	23	22	23	27	33	35	36	36	
All-Sky Solar Radiation	RadAvg	2462	2160	1842	1434	1056	822	921	1220	1677	2058	2271	2486	
	RadStd	121	146	114	85	58	62	59	86	112	141	197	92	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+1.12	N/A	N/A	+2.86	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-160	N/A	N/A

Nomenclature: See separate page