

WEST WYALONG, Australia

WMO: 957090

Lat: 33.9383S

Lon: 147.1961E

Elev: 845

StdP: 14.25

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.2	33.5	22.3	17.3	72.6	25.2	19.8	64.9	22.6	49.5	20.3	50.6	1.8	250	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	102.1	66.7	98.3	66.3	94.8	65.3	71.9	85.3	70.5	85.0	69.2	84.5	11.8	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.6	112.2	73.9	67.0	102.5	73.6	64.7	94.5	73.2	36.2	85.3	35.0	84.5	33.8	84.3	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.1	20.6	18.2	27.7	107.6	2.4	3.3	26.0	110.0	24.6	111.9	23.3	113.8	21.6	116.2		
(5)			27.3	74.4	2.4	1.7	25.6	75.6	24.2	76.6	22.9	77.6	21.2	78.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.2	79.0	76.4	70.8	62.9	54.3	49.1	47.4	49.1	54.4	61.9	69.0	73.5
	DBStd	12.35	6.97	6.84	6.06	5.79	4.68	4.15	3.92	4.12	5.26	6.99	7.33	6.99
	HDD50	257	0	0	0	1	13	65	100	65	12	1	0	0
	HDD65	2486	0	3	18	104	334	477	545	492	320	146	38	9
	CDD50	4728	898	740	646	386	146	38	21	38	145	371	570	729
	CDD65	1483	434	323	199	40	1	0	0	0	4	51	158	273
	CDH74	19232	5832	3834	2136	513	12	0	0	4	112	889	2240	3660
	CDH80	9588	3339	1995	875	126	0	0	0	0	23	327	1035	1868
(14) Wind	WSAvg	8.3	10.0	9.5	8.7	7.1	6.7	6.7	6.7	7.5	8.3	8.9	9.6	9.7
(15) Precipitation	PrecAvg	18.6	1.9	1.1	1.4	1.8	1.9	1.1	1.6	1.7	1.5	1.7	1.6	1.6
	PrecMax	27.5	11.3	4.1	6.4	7.2	4.7	2.4	3.9	3.9	5.9	5.1	4.0	5.0
	PrecMin	7.8	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.2	0.3	0.0	0.0	0.0
	PrecStd	5.4	2.6	1.1	1.5	1.8	1.3	0.7	1.0	0.9	1.2	1.3	1.3	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.3	105.6	97.0	89.2	75.7	67.4	66.1	72.4	83.2	92.9	101.1	103.4
		MCWB	68.2	69.9	66.2	62.0	58.3	55.4	52.1	55.8	58.6	60.6	65.0	64.6
	2%	DB	103.0	100.4	92.3	83.5	72.2	63.2	62.3	66.9	76.8	87.8	94.9	98.5
		MCWB	67.3	66.9	64.9	61.6	57.2	53.6	51.7	53.4	56.2	60.0	63.2	64.8
	5%	DB	99.2	95.4	88.3	79.7	68.9	60.6	59.2	63.4	72.8	83.4	90.1	94.5
		MCWB	67.1	66.5	63.7	60.2	55.9	52.5	50.7	51.5	55.1	59.2	62.7	63.9
	10%	DB	95.1	91.0	85.0	76.2	65.6	57.9	56.7	60.2	68.7	78.7	85.9	90.4
		MCWB	66.5	65.6	63.1	59.2	54.4	51.7	49.7	50.6	53.9	58.1	61.3	62.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.7	75.4	71.6	66.4	62.5	58.1	56.5	58.5	62.0	66.3	70.2	71.9
		MCDB	86.0	84.1	79.2	78.1	66.9	61.6	60.0	64.7	73.0	77.7	84.0	79.3
	2%	WB	71.7	72.1	69.1	64.3	59.1	55.8	53.9	55.7	59.4	64.0	67.9	69.8
		MCDB	87.9	85.3	80.3	73.9	67.4	59.8	58.3	63.8	70.3	76.0	83.0	81.7
	5%	WB	70.5	70.6	67.3	62.7	57.4	54.2	52.1	53.3	57.3	62.2	65.9	67.9
		MCDB	88.0	84.3	79.7	74.1	66.1	58.3	56.7	61.5	68.7	74.6	80.2	82.2
	10%	WB	69.1	69.0	65.7	61.0	55.7	52.7	50.4	51.3	55.2	60.2	64.3	66.2
		MCDB	87.6	83.1	79.7	72.8	63.8	56.7	55.3	58.7	66.2	74.9	79.3	82.1
(35) Mean Daily Temperature Range	5% DB	MDBR	26.4	24.1	23.9	24.2	22.0	17.8	18.5	21.4	24.9	26.9	26.8	26.6
		MCDBR	30.9	29.7	28.8	29.0	26.9	22.4	24.0	28.0	32.9	33.6	32.6	31.8
		MCWBR	9.6	9.5	10.5	12.4	13.8	13.6	14.6	15.6	15.7	13.3	11.4	10.4
	5% WB	MCDBR	24.4	21.6	22.3	23.2	22.6	17.5	18.5	23.4	26.1	26.2	25.2	23.2
		MCWBR	9.3	8.2	9.5	10.6	12.5	11.5	12.1	14.2	14.0	12.4	9.5	9.6
(40) Clear-Sky Solar Irradiance	taub		0.342	0.338	0.320	0.304	0.290	0.284	0.281	0.288	0.317	0.324	0.341	0.333
	taud		2.491	2.533	2.563	2.575	2.579	2.607	2.607	2.566	2.465	2.477	2.467	2.506
	Ebn at Noon		316	310	305	293	280	274	281	294	301	312	314	319
	Edh at Noon		36	34	30	27	23	21	23	26	33	35	37	36
(44) All-Sky Solar Radiation	RadAvg		2462	2158	1831	1397	1015	781	867	1163	1623	2027	2257	2484
	RadStd		125	136	109	77	55	62	54	89	121	143	182	86

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.76	N/A	N/A	+1.93	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page