

WEST WYALONG, Australia

WMO: 957090

Lat: 33.9383S

Lon: 147.1961E

Elev: 258

StdP: 98.27

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.4	0.8	-5.4	2.5	22.6	-3.8	2.8	18.3	10.1	9.7	9.1	10.3	0.8	250	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.7	39.0	19.3	36.8	19.0	34.9	18.5	22.2	29.6	21.4	29.5	20.7	29.2	5.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.9	16.0	23.3	19.5	14.6	23.1	18.2	13.5	22.9	66.3	29.6	63.5	29.2	60.7	29.0	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.2	8.1	-2.4	42.0	1.3	1.8	-3.3	43.3	-4.1	44.4	-4.8	45.4	-5.8	46.8 (4)		
(5)			-2.6	23.5	1.3	1.0	-3.5	24.2	-4.3	24.8	-5.1	25.3	-6.0	26.0 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	26.1	24.7	21.6	17.1	12.4	9.5	8.6	9.5	12.5	16.6	20.6	23.1		
	DBStd	6.86	3.87	3.80	3.37	3.22	2.60	2.31	2.18	2.29	2.92	3.88	4.07	3.88		
	HDD10.0	143	0	0	0	1	7	36	56	36	7	1	0	0		
	HDD18.3	1381	0	2	10	58	186	265	303	273	178	81	21	5		
	CDD10.0	2627	499	411	359	214	81	21	12	21	81	206	317	405		
	CDD18.3	824	241	179	111	22	1	0	0	0	2	28	88	152		
	CDH23.3	10684	3240	2130	1187	285	7	0	0	2	62	494	1244	2033		
	CDH26.7	5327	1855	1108	486	70	0	0	0	0	13	182	575	1038		
(14) Wind	WSAvg	3.7	4.5	4.2	3.9	3.2	3.0	3.0	3.0	3.3	3.7	4.0	4.3	4.3		
(15) Precipitation	PrecAvg	473	48	27	35	46	48	27	40	42	37	44	41	41		
	PrecMax	698	286	103	163	183	119	61	98	98	149	130	102	128		
	PrecMin	198	0	0	0	0	5	1	1	4	7	1	0	0		
	PrecStd	137	67	29	39	45	32	18	26	23	30	32	33	39		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.9	40.9	36.1	31.8	24.3	19.7	18.9	22.4	28.5	33.8	38.4	39.7		
		MCWB	20.1	21.1	19.0	16.7	14.6	13.0	11.2	13.2	14.8	15.9	18.3	18.1		
	2%	DB	39.4	38.0	33.5	28.6	22.3	17.3	16.8	19.4	24.9	31.0	35.0	36.9		
		MCWB	19.6	19.4	18.3	16.5	14.0	12.0	10.9	11.9	13.5	15.6	17.3	18.2		
	5%	DB	37.3	35.2	31.3	26.5	20.5	15.9	15.1	17.4	22.7	28.5	32.3	34.7		
		MCWB	19.5	19.2	17.6	15.7	13.3	11.4	10.4	10.8	12.8	15.1	17.1	17.7		
	10%	DB	35.1	32.8	29.4	24.6	18.6	14.4	13.7	15.7	20.4	25.9	29.9	32.4		
		MCWB	19.2	18.7	17.3	15.1	12.4	10.9	9.9	10.3	12.1	14.5	16.3	17.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	24.1	22.0	19.1	16.9	14.5	13.6	14.7	16.7	19.0	21.2	22.1		
		MCDB	30.0	29.0	26.2	25.6	19.4	16.4	15.5	18.2	22.8	25.4	28.9	26.3		
	2%	WB	22.1	22.3	20.6	18.0	15.0	13.2	12.2	13.1	15.2	17.8	19.9	21.0		
		MCDB	31.1	29.6	26.8	23.3	19.6	15.4	14.6	17.7	21.3	24.4	28.3	27.6		
	5%	WB	21.4	21.4	19.6	17.1	14.1	12.3	11.2	11.8	14.1	16.8	18.8	20.0		
		MCDB	31.1	29.0	26.5	23.4	19.0	14.6	13.7	16.4	20.4	23.7	26.8	27.9		
	10%	WB	20.6	20.5	18.7	16.1	13.2	11.5	10.2	10.7	12.9	15.7	17.9	19.0		
		MCDB	30.9	28.4	26.5	22.7	17.7	13.7	12.9	14.8	19.0	23.8	26.3	27.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	13.4	13.3	13.4	12.2	9.9	10.3	11.9	13.9	14.9	14.9	14.8		
		MCDBR	17.2	16.5	16.0	16.1	14.9	12.4	13.3	15.5	18.3	18.7	18.1	17.7		
		MCWBR	5.4	5.3	5.8	6.9	7.7	7.6	8.1	8.7	8.7	7.4	6.3	5.8		
		MCDBR	13.5	12.0	12.4	12.9	12.6	9.7	10.3	13.0	14.5	14.6	14.0	12.9		
	5% WB	MCWBR	5.2	4.5	5.3	5.9	7.0	6.4	6.7	7.9	7.8	6.9	5.3	5.3		
(40) Clear-Sky Solar Irradiance	taub		0.342	0.338	0.320	0.304	0.290	0.284	0.281	0.288	0.317	0.324	0.341	0.333		
	taud		2.491	2.533	2.563	2.575	2.579	2.607	2.607	2.566	2.465	2.477	2.467	2.506		
	Ebn at Noon		995	978	961	923	883	865	887	927	948	982	990	1007		
	Edh at Noon		115	106	96	84	74	67	71	83	104	111	117	114		
(44) All-Sky Solar Radiation	RadAvg		7.76	6.80	5.77	4.40	3.20	2.46	2.73	3.67	5.12	6.39	7.12	7.83		
	RadStd		0.40	0.43	0.34	0.24	0.17	0.20	0.17	0.28	0.38	0.45	0.57	0.27		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.42	N/A	N/A	+1.07	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page