

WALGETT, Australia

WMO: 957150

Lat: 30.0372S

Lon: 148.1222E

Elev: 134

StdP: 99.73

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.2	1.6	-9.8	1.7	21.7	-7.6	2.0	19.1	8.8	16.3	8.0	16.3	1.4	220	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.7	40.4	19.7	38.5	19.7	36.8	19.3	23.5	30.8	22.8	30.5	22.1	30.1	5.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	16.9	24.9	20.9	15.8	25.0	20.0	14.9	24.6	70.8	30.3	68.1	30.2	65.4	30.0	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	8.3	7.4	-3.0	42.9	1.4	2.5	-4.0	44.7	-4.8	46.2	-5.5	47.5	-6.5	49.3	
			DB												
			WB	-3.7	24.9	1.4	0.8	-4.6	25.5	-5.5	26.0	-6.2	26.4	-7.2	27.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	28.4	27.2	24.4	19.8	14.8	11.9	11.0	12.5	16.4	20.3	23.7	26.2
	DBStd	6.90	3.56	3.41	3.23	3.28	3.06	2.70	2.74	3.07	3.62	4.02	4.05	3.58
	HDD10.0	39	0	0	0	0	2	11	18	8	1	0	0	0
	HDD18.3	852	0	0	1	22	114	192	227	184	81	26	4	1
	CDD10.0	3574	569	481	447	294	152	68	51	85	193	320	412	503
	CDD18.3	1345	311	248	189	66	6	0	1	3	23	87	166	245
	CDH23.3	17404	4251	3125	2113	714	86	3	4	54	435	1218	2136	3265
	CDH26.7	9219	2534	1758	1018	220	6	0	0	9	151	545	1116	1862
Wind	WSAvg	3.7	4.4	4.2	3.9	3.3	3.0	3.2	3.0	3.4	3.7	4.0	4.3	4.4
Precipitation	PrecAvg	507	81	49	40	40	48	22	33	33	27	38	43	46
	PrecMax	743	345	201	139	233	182	72	102	117	97	118	169	201
	PrecMin	210	2	2	0	0	0	0	0	0	0	3	0	0
	PrecStd	133	76	50	38	57	49	20	25	27	26	28	38	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.6	42.0	38.2	33.0	27.5	23.5	23.8	27.8	33.7	36.6	41.2	41.6
		MCWB	21.1	20.8	19.7	18.1	16.2	14.6	13.2	15.1	15.4	16.6	18.6	19.3
	2%	DB	40.3	39.1	35.7	30.8	25.5	21.5	21.4	24.7	30.6	34.1	37.9	39.0
		MCWB	20.3	20.3	19.3	17.5	15.3	14.0	12.7	13.1	14.7	16.4	17.7	19.1
	5%	DB	38.3	37.0	33.7	29.2	24.0	20.0	19.7	22.5	28.0	32.0	35.2	36.9
		MCWB	20.5	20.4	19.2	16.9	14.6	13.0	12.1	12.4	14.2	16.3	17.7	18.5
	10%	DB	36.4	34.9	32.0	27.6	22.4	18.3	17.9	20.5	25.7	29.9	32.6	35.1
		MCWB	20.2	19.9	18.9	16.6	14.0	12.3	11.4	11.6	13.6	15.8	17.6	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	24.5	23.6	21.2	18.7	16.8	16.8	17.1	18.6	20.7	22.6	23.5
		MCDB	33.2	31.2	28.6	26.8	21.4	19.9	19.0	23.2	23.8	27.1	27.8	30.0
	2%	WB	23.6	23.4	22.5	19.7	17.2	15.5	14.8	15.2	17.1	19.4	21.2	22.4
		MCDB	31.5	31.1	28.6	26.3	21.9	18.4	18.2	20.2	23.0	27.1	28.2	29.9
	5%	WB	22.8	22.6	21.6	18.6	16.1	14.5	13.4	13.8	16.1	18.4	20.3	21.5
		MCDB	31.2	30.8	28.1	25.2	21.6	17.8	17.3	19.7	23.3	26.4	27.8	29.4
	10%	WB	22.1	21.8	20.7	17.5	15.0	13.4	12.3	12.6	14.9	17.4	19.5	20.7
		MCDB	31.1	30.2	27.7	25.0	21.0	17.3	16.7	19.1	23.3	25.9	27.2	29.0
Mean Daily Temperature Range	5% DB	MDBR	13.7	13.2	13.5	14.6	14.5	12.9	14.0	15.6	16.5	16.0	14.7	14.8
		MCDBR	15.6	15.8	15.7	16.2	16.3	15.0	16.3	18.3	20.1	18.5	17.5	17.3
		MCWBR	5.4	5.6	6.3	7.2	8.2	8.3	9.1	9.2	8.4	7.5	6.8	6.5
	5% WB	MCDBR	12.8	12.3	11.8	12.6	12.1	11.2	11.7	14.2	14.4	13.9	12.7	13.1
		MCWBR	5.1	4.8	5.4	6.1	6.7	6.9	7.2	7.8	7.2	6.7	5.7	5.4
Clear-Sky Solar Irradiance	taub		0.360	0.361	0.334	0.317	0.301	0.294	0.287	0.300	0.333	0.346	0.365	0.355
	taud		2.502	2.509	2.580	2.587	2.582	2.613	2.612	2.549	2.450	2.442	2.435	2.492
	Ebn at Noon		980	961	956	923	892	877	900	929	941	964	969	987
	Edh at Noon		115	110	97	87	78	72	75	88	108	117	122	116
All-Sky Solar Radiation	RadAvg		7.63	6.95	5.96	4.86	3.77	3.04	3.46	4.45	5.67	6.70	7.19	7.70
	RadStd		0.42	0.47	0.38	0.27	0.19	0.23	0.20	0.23	0.33	0.47	0.69	0.48

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.65	N/A	N/A	N/A	N/A	N/A	N/A	+227	+203
(47) Regional (5 neighbors)		+0.58	N/A	N/A	+1.26	N/A	N/A	N/A	+270	+208

Nomenclature: See separate page