

PARKES, Australia

WMO: 957170

Lat: 33.1281S

Lon: 148.2428E

Elev: 1063

StdP: 14.14

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.9	32.0	21.8	17.0	65.8	25.3	20.1	57.3	21.4	55.9	19.9	54.2	3.5	60	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.8	99.7	67.2	96.0	66.5	92.8	65.8	72.6	85.9	70.9	84.9	69.6	83.8	12.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.6	113.0	76.1	67.4	104.9	74.9	65.4	97.6	74.7	37.0	85.7	35.5	84.4	34.3	83.7	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.0	20.5	18.1	DB	26.5	105.8	2.0	3.9	25.1	108.6	24.0	110.8	22.9	113.0	21.5	115.8
			WB	26.1	77.2	2.1	4.2	24.6	80.2	23.3	82.7	22.2	85.1	20.6	88.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	78.2	76.2	70.7	62.8	54.3	49.5	47.2	48.9	54.3	61.3	68.5	73.5	(6)
	DBStd	12.41	6.78	6.70	6.26	6.27	5.60	5.06	4.51	5.18	5.85	7.18	7.82	7.04	(7)
	HDD50	310	0	0	0	2	22	69	111	84	19	3	0	0	(8)
	HDD65	2532	1	4	21	111	335	465	551	499	324	160	49	12	(9)
	CDD50	4705	875	732	642	386	154	54	25	50	149	354	556	728	(10)
	CDD65	1453	412	316	197	45	2	0	0	0	5	47	155	274	(11)
	CDH74	16934	4983	3488	1899	465	12	0	0	4	88	684	1953	3358	(12)
	CDH80	7887	2666	1722	714	98	0	0	0	0	9	208	864	1606	(13)
(14) Wind	WSAvg	7.6	9.3	8.5	7.9	6.8	6.2	6.3	6.4	6.6	7.4	8.3	8.8	9.1	(14)
(15) Precipitation	PrecAvg	25.0	2.8	2.1	1.8	1.8	2.3	1.5	2.0	2.2	1.8	2.4	2.2	2.0	(15)
	PrecMax	39.7	9.9	8.1	5.4	11.8	8.1	4.1	5.2	4.5	4.6	6.4	7.3	5.4	(16)
	PrecMin	11.7	0.0	0.0	0.0	0.0	0.1	0.0	0.2	0.0	0.3	0.0	0.0	0.0	(17)
	PrecStd	6.7	2.5	1.9	1.3	2.0	1.7	1.0	1.2	1.2	1.1	1.5	1.7	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.6	103.5	95.1	87.6	76.0	68.8	66.1	73.5	80.8	90.3	100.2	101.2	(19)
		MCWB	68.4	69.7	65.8	63.6	59.5	56.7	54.7	57.7	58.5	60.9	66.3	65.9	(20)
	2%	DB	100.3	97.8	90.8	82.4	72.4	64.8	62.5	67.8	76.2	85.7	93.7	96.5	(21)
		MCWB	67.7	68.0	65.1	62.0	58.0	55.0	52.3	54.1	57.3	60.4	63.4	65.5	(22)
	5%	DB	96.5	93.5	87.0	79.1	69.4	62.2	59.9	64.4	72.4	81.6	89.0	92.7	(23)
		MCWB	67.4	67.1	64.3	60.4	56.5	53.8	51.5	52.9	56.3	59.6	62.7	65.0	(24)
	10%	DB	92.7	89.8	83.7	75.9	66.3	59.5	57.3	61.1	68.5	77.3	84.4	88.9	(25)
		MCWB	66.7	66.4	63.5	59.2	55.2	53.0	50.4	51.3	54.9	58.8	62.1	64.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.2	75.5	71.4	66.9	62.9	60.0	58.8	59.9	63.2	67.0	71.8	73.3	(27)
		MCDB	87.7	88.7	81.5	78.5	70.3	64.4	62.0	68.6	73.0	77.9	84.2	85.2	(28)
	2%	WB	72.0	73.0	69.0	64.1	60.4	57.4	55.1	56.7	60.7	64.4	68.3	70.3	(29)
		MCDB	87.8	85.3	81.2	75.3	67.8	61.8	59.0	63.9	70.6	75.7	82.7	83.5	(30)
	5%	WB	70.7	71.1	67.3	62.5	58.4	55.5	53.0	54.5	58.6	62.7	66.6	68.6	(31)
		MCDB	86.9	83.6	80.2	74.4	65.9	60.1	57.8	62.3	68.1	74.6	79.9	82.6	(32)
	10%	WB	69.4	69.6	65.8	60.9	56.6	53.6	51.0	52.2	56.6	61.0	64.8	67.0	(33)
		MCDB	85.5	82.3	78.9	72.7	64.5	59.0	56.0	60.1	65.4	73.1	77.6	81.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	24.8	23.5	23.9	24.2	22.0	18.2	19.2	22.6	25.8	27.1	26.0	26.5	(35)
		MCDBR	28.8	28.1	27.3	27.5	25.8	22.0	23.8	27.6	32.0	32.4	31.3	30.2	(36)
	5% WB	MCWBR	9.8	9.6	10.7	12.1	13.1	13.3	14.7	15.8	16.1	13.8	11.7	10.9	(37)
		MCWBR	23.5	20.7	21.9	22.8	19.9	16.8	18.0	22.8	24.9	25.3	23.7	23.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.345	0.347	0.321	0.304	0.288	0.283	0.278	0.286	0.315	0.327	0.342	0.337	(40)
		taud	2.508	2.523	2.578	2.592	2.593	2.616	2.617	2.574	2.475	2.472	2.475	2.515	(41)
	Ebn at Noon		315	308	305	294	283	277	284	296	302	311	314	318	(42)
		Edh at Noon	36	34	30	26	23	22	23	26	33	36	37	36	(43)
(44) All-Sky Solar Radiation	RadAvg		2434	2117	1796	1413	1036	796	895	1189	1643	2024	2239	2455	(44)
	RadStd		124	157	125	97	63	65	58	88	120	151	198	110	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	-1.39	N/A	+2.52	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	-43	-166	+281	+130

Nomenclature: See separate page