

TEMORA, Australia

WMO: 957220

Lat: 34.4292S

Lon: 147.5111E

Elev: 922

StdP: 14.21

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.7	30.5	22.5	17.5	65.5	25.5	20.2	54.8	21.5	51.8	20.0	51.7	2.3	190	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.4	101.5	66.7	97.5	66.1	93.8	65.0	71.5	87.4	70.0	85.4	68.8	84.1	12.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.2	107.0	74.1	66.2	99.8	74.0	64.2	92.9	73.6	35.8	87.6	34.6	85.5	33.5	83.1	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.5	19.3	17.4	25.6	107.3	1.9	3.3	24.2	109.7	23.1	111.6	22.0	113.4	20.6	115.8		
(5)			24.8	74.5	2.2	1.9	23.3	75.8	22.0	76.9	20.8	78.0	19.2	79.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	77.9	75.6	70.3	61.3	52.7	47.9	46.2	47.0	52.1	60.2	67.5	72.0		
	DBStd	12.60	6.94	6.55	6.45	6.12	4.87	4.44	3.89	4.12	4.94	7.10	7.37	6.97		
	HDD50	397	0	0	0	3	27	92	131	112	29	3	0	0		
	HDD65	2853	2	4	27	140	382	513	584	557	387	185	56	16		
	CDD50	4346	866	717	629	341	110	30	12	20	93	319	526	683		
	CDD65	1327	403	301	191	28	1	0	0	1	36	132	234			
	CDH74	17179	5310	3417	2054	425	7	0	0	1	64	760	1914	3227		
	CDH80	8422	3023	1732	838	99	0	0	0	0	9	256	863	1602		
(14) Wind	WSAvg	7.9	9.7	9.5	8.6	6.9	6.1	6.3	6.4	6.8	7.7	8.2	9.2	9.4		
(15) Precipitation	PrecAvg	21.7	2.0	1.3	1.4	1.9	2.1	1.5	2.1	2.1	2.0	2.1	1.8	1.7		
	PrecMax	37.4	11.3	5.8	6.3	8.1	5.0	5.0	5.9	4.6	5.4	6.3	8.1	5.8		
	PrecMin	8.7	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.3	0.3	0.0	0.1	0.0		
	PrecStd	6.7	2.3	1.3	1.5	2.1	1.5	1.1	1.3	1.1	1.2	1.5	1.7	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.0	105.6	96.7	88.2	74.6	65.6	63.5	69.3	80.6	91.6	100.6	103.9		
		MCWB	68.5	69.4	65.2	62.0	58.7	54.0	54.3	56.1	57.3	60.1	65.1	64.9		
	2%	DB	102.4	99.2	91.7	82.5	71.1	62.1	60.3	64.6	74.6	86.6	93.8	97.7		
		MCWB	67.5	66.5	64.5	61.3	57.0	53.0	52.7	53.6	55.5	59.6	62.5	64.7		
	5%	DB	98.5	94.1	88.0	78.8	68.0	59.6	58.0	61.3	70.7	82.2	89.2	93.3		
		MCWB	67.2	66.1	63.6	59.9	55.8	52.1	51.3	51.7	54.8	59.5	62.4	63.8		
	10%	DB	94.6	89.9	84.8	75.2	64.8	57.5	55.6	58.5	66.8	77.9	84.6	89.0		
		MCWB	66.1	65.1	63.0	58.8	54.5	51.5	49.6	50.3	53.8	58.1	61.1	62.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	74.7	70.5	66.4	62.2	57.1	59.0	57.6	61.2	65.8	69.9	71.8		
		MCDB	90.3	84.6	80.6	78.1	67.5	59.7	60.3	64.5	70.4	77.7	84.2	82.6		
	2%	WB	71.5	71.7	68.5	64.1	58.9	55.2	54.1	55.3	59.0	63.8	67.4	69.1		
		MCDB	90.0	86.4	79.3	73.6	68.7	58.9	58.2	63.1	69.5	75.8	81.7	82.2		
	5%	WB	70.1	70.0	67.1	62.3	57.1	53.7	52.0	52.7	57.0	62.0	65.6	67.6		
		MCDB	88.0	83.8	79.1	72.7	65.5	58.3	56.6	59.8	66.7	74.9	81.3	81.0		
	10%	WB	69.0	68.3	65.5	60.5	55.4	52.3	50.4	50.9	54.9	60.2	63.8	65.7		
		MCDB	86.9	83.5	78.8	72.5	63.3	56.9	54.9	57.5	64.6	73.5	78.5	82.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	27.4	24.9	24.5	25.6	23.8	19.2	18.8	22.3	27.0	29.0	27.6	28.0		
		MCDBR	32.6	31.0	29.4	31.0	28.6	23.0	23.5	28.1	35.7	36.7	34.3	33.5		
		MCWBR	9.9	9.9	10.4	14.1	16.3	15.0	16.0	17.7	18.9	15.7	11.8	10.8		
	5% WB	MCDBR	25.3	22.7	20.6	23.9	24.0	17.8	20.2	24.3	27.6	27.4	25.8	23.6		
		MCWBR	9.2	8.5	8.8	11.6	14.2	12.0	14.4	16.2	16.7	13.7	10.1	9.9		
(40) Clear-Sky Solar Irradiance	taub		0.347	0.340	0.321	0.306	0.293	0.285	0.281	0.288	0.316	0.325	0.342	0.336		
	taud		2.468	2.520	2.550	2.559	2.562	2.597	2.604	2.562	2.465	2.468	2.461	2.491		
	Ebn at Noon		314	309	304	291	278	272	280	293	300	311	313	318		
	Edh at Noon		37	34	31	27	23	21	22	26	33	36	37	37		
(44) All-Sky Solar Radiation	RadAvg		2448	2136	1815	1372	988	751	829	1122	1580	1996	2236	2471		
	RadStd		127	136	111	76	53	64	48	89	129	152	174	86		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (18 neighbors)	+0.79	N/A	N/A	+2.09	N/A	N/A	N/A	N/A	+214		

Nomenclature: See separate page