

MURRURUNDI GAP, Australia

WMO: 957470

Lat: 31.7417S

Lon: 150.7936E

Elev: 2395

StdP: 13.47

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.2	38.0	20.0	16.4	60.0	23.6	19.5	57.4	36.9	49.2	33.7	47.7	13.0	130	0.638

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	90.9	64.5	87.7	63.9	84.8	63.3	69.2	80.1	68.0	79.0	66.8	77.4	13.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	106.8	72.2	65.0	101.2	70.7	63.8	96.7	69.8	34.8	80.2	33.7	78.7	32.7	77.9	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
32.9	29.1	26.0	DB	32.0	96.0	1.8	4.0	30.7	98.9	29.6	101.2	28.6	103.4	27.2	106.3
			WB	29.9	72.5	1.4	1.7	28.9	73.7	28.1	74.7	27.3	75.6	26.3	76.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.9	71.7	69.8	66.3	60.5	54.2	48.7	47.4	50.0	55.7	61.0	65.3	68.5	(6)
	DBStd	9.99	6.29	6.06	5.19	5.20	4.88	4.10	4.27	4.99	6.07	6.78	6.86	6.40	(7)
	HDD50	272	0	0	0	2	16	70	105	63	13	3	0	0	(8)
	HDD65	2626	12	18	47	152	334	489	546	466	286	162	77	37	(9)
	CDD50	3872	674	555	505	316	147	31	24	62	184	343	459	572	(10)
	CDD65	749	220	153	87	17	0	0	0	6	37	85	144		(11)
	CDH74	6249	2028	1289	532	61	0	0	0	31	240	775	1293		(12)
	CDH80	2019	773	446	107	3	0	0	0	2	35	236	417		(13)
(14) Wind	WSAvg	13.7	14.1	14.7	13.7	13.1	11.7	13.6	13.7	13.7	13.7	13.8	14.0	14.3	(14)
(15) Precipitation	PrecAvg	29.3	2.9	2.8	2.0	1.6	1.9	2.5	2.1	2.0	2.2	2.4	3.2	3.9	(15)
	PrecMax	45.0	8.9	10.4	6.3	5.7	4.1	6.8	8.3	4.5	5.3	6.0	10.9	6.5	(16)
	PrecMin	14.9	0.3	0.0	0.4	0.1	0.0	0.7	0.1	0.0	0.2	0.0	0.6	1.1	(17)
	PrecStd	6.7	2.2	2.3	1.4	1.3	1.2	1.6	1.7	1.3	1.3	1.5	2.1	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.1	94.5	86.8	79.7	70.1	63.1	62.1	68.0	77.8	83.7	92.4	92.7	(19)
		MCWB	67.4	65.8	63.9	60.1	55.6	52.3	52.1	53.4	54.9	57.5	63.8	64.5	(20)
	2%	DB	91.0	89.2	83.0	75.4	67.0	58.7	59.2	64.1	73.4	79.6	86.2	88.5	(21)
		MCWB	65.1	64.7	63.5	59.3	54.7	50.8	49.8	50.5	53.7	57.4	61.4	62.8	(22)
	5%	DB	87.6	85.6	79.8	72.4	64.6	56.6	56.9	61.5	69.9	76.4	81.8	85.1	(23)
		MCWB	64.9	64.1	62.8	58.7	53.6	50.3	49.1	49.2	52.9	56.8	60.6	62.1	(24)
	10%	DB	84.4	81.7	76.6	69.7	62.2	54.8	54.7	59.0	66.6	73.3	78.3	81.5	(25)
		MCWB	64.7	64.2	62.1	57.8	52.7	49.8	48.0	47.9	51.9	56.5	59.6	61.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	71.2	68.4	64.6	60.1	55.3	56.7	56.6	59.3	63.9	67.3	69.3	(27)
		MCDB	83.3	84.2	77.3	70.7	63.0	57.0	59.2	65.0	68.9	71.3	81.4	79.4	(28)
	2%	WB	69.5	69.0	66.7	62.2	57.7	53.4	53.4	53.2	57.5	61.7	65.4	67.2	(29)
		MCDB	80.2	80.6	75.4	70.1	62.8	56.1	55.9	59.3	65.8	71.1	77.9	77.9	(30)
	5%	WB	68.3	67.5	65.5	60.5	55.6	52.1	51.1	51.1	55.8	60.1	63.8	65.9	(31)
		MCDB	79.4	78.5	74.0	68.8	62.2	54.9	54.0	58.3	64.9	70.0	75.0	76.2	(32)
	10%	WB	67.2	66.1	64.3	59.1	54.0	50.9	48.8	49.4	54.0	58.5	62.5	64.8	(33)
		MCDB	78.1	76.8	72.5	66.6	60.4	53.7	53.2	56.7	63.1	68.6	72.6	75.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.2	18.4	16.3	15.1	13.1	10.3	11.5	13.9	16.0	17.9	18.6	19.2	(35)
		MCDBR	23.6	24.1	20.6	18.2	14.7	12.4	13.6	16.3	19.5	21.2	23.1	24.1	(36)
	5% WB	MCWBR	6.9	7.5	7.1	7.5	7.2	7.0	8.0	8.7	8.6	8.6	8.1	7.8	(37)
		MCWBR	19.2	19.5	17.0	16.1	12.7	9.0	9.9	13.6	15.6	18.2	18.8	19.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.342	0.343	0.318	0.297	0.280	0.275	0.270	0.278	0.306	0.322	0.345	0.339	(40)
		taud	2.532	2.549	2.609	2.640	2.644	2.661	2.658	2.621	2.519	2.507	2.485	2.529	(41)
	Ebn at Noon		316	310	307	298	289	283	290	301	306	313	313	318	(42)
		Edh at Noon	35	33	30	26	23	21	22	26	32	35	37	36	(43)
(44) All-Sky Solar Radiation	RadAvg		2234	1989	1670	1363	1066	839	968	1270	1671	1942	2086	2247	(44)
	RadStd		148	165	140	99	76	69	67	84	112	175	213	172	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (20 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	-158	+310	+160

Nomenclature: See separate page