

BOMBO HEADLAND, AustraliaWMO: **957490**Lat: **34.6533S**Lon: **150.8608E**Elev: **16**StdP: **101.14**Time Zone: **10.00 (AUS)**Period: **04-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	9.5	-1.5	3.3	13.5	-0.4	3.6	13.2	15.2	13.0	12.9	12.5	4.4	280	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.1	28.5	19.5	26.4	20.7	25.3	20.8	23.9	25.3	22.9	24.6	22.2	24.1	5.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.5	18.3	24.5	22.5	17.2	23.8	21.5	16.2	23.4	71.7	25.3	68.1	24.5	65.3	24.1	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.5	10.1	DB	7.0	35.6	0.8	2.5	6.5	37.4	6.0	38.9	5.6	40.3	5.0	42.2	(4)
(5)			WB	3.7	24.7	0.5	2.1	3.3	26.2	3.1	27.4	2.8	28.6	2.4	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	21.8	21.5	20.8	18.8	16.4	14.4	13.7	14.1	15.8	17.3	19.0	20.2
	DBStd	3.46	2.01	1.91	1.81	1.91	1.92	1.53	1.74	1.89	2.40	2.60	2.23	2.01
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	638	1	1	2	16	66	119	144	132	84	50	18	6
	CDD10.0	2842	365	323	334	263	198	131	114	128	174	227	268	317
	CDD18.3	439	107	91	78	29	6	0	1	1	8	19	36	64
	CDH23.3	1065	286	231	137	44	9	0	2	2	41	82	97	132
	CDH26.7	181	42	23	12	4	0	0	0	11	23	32	33	
Wind	WSAvg	4.6	4.8	4.8	4.7	4.2	4.3	4.6	4.4	4.8	4.5	4.7	4.7	4.7
Precipitation	PrecAvg	1270	119	130	166	130	122	133	52	78	77	93	108	90
	PrecMax	2012	321	435	617	466	562	671	188	342	218	444	592	278
	PrecMin	602	19	8	13	8	2	0	0	2	2	4	7	8
	PrecStd	388	77	114	125	122	109	119	41	88	65	85	104	72
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	29.5	27.3	27.0	24.6	20.4	22.5	23.2	28.1	29.8	31.1	31.2
		MCWB	21.4	22.5	19.7	17.2	15.5	14.0	13.2	13.4	15.4	16.4	19.4	19.1
	2%	DB	26.9	26.7	25.6	24.4	22.2	19.0	19.5	20.5	23.5	25.4	25.6	26.1
		MCWB	22.8	22.7	20.9	18.8	16.2	14.1	12.9	13.5	14.3	16.7	18.1	19.3
	5%	DB	25.6	25.6	24.7	23.2	20.9	18.1	18.1	19.0	21.2	22.8	23.5	24.3
		MCWB	22.4	22.0	20.6	18.6	15.5	13.4	12.2	12.7	14.3	17.0	19.2	20.3
	10%	DB	24.7	24.7	23.9	22.2	19.8	17.2	17.0	17.8	19.6	21.4	22.4	23.4
		MCWB	21.8	21.4	20.1	18.2	15.1	13.0	11.7	12.3	14.5	16.9	18.6	19.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.9	25.1	23.4	21.4	18.6	17.1	16.4	16.0	17.6	20.1	21.6	23.0
		MCDB	26.7	26.5	24.5	23.6	21.0	18.0	18.9	19.2	21.3	22.4	25.2	24.5
	2%	WB	24.0	24.0	22.4	20.5	17.6	15.4	14.8	15.0	16.7	19.1	20.7	21.7
		MCDB	25.2	25.6	24.0	22.6	20.3	17.3	17.4	18.0	20.2	22.0	23.2	23.8
	5%	WB	23.0	23.1	21.6	19.7	16.7	14.7	13.6	14.2	16.1	18.4	20.1	21.1
		MCDB	24.7	24.8	23.7	22.0	19.8	16.6	16.2	17.3	19.6	21.3	22.6	23.3
	10%	WB	22.3	22.2	20.9	18.8	15.9	14.0	12.6	13.2	15.3	17.7	19.2	20.4
		MCDB	24.2	24.0	23.4	21.4	19.3	16.1	15.8	16.5	18.7	20.5	21.7	22.7
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.0	5.1	5.5	5.9	5.2	6.2	6.4	6.9	6.5	5.8	5.4
		MCDBR	6.7	6.6	6.5	7.3	7.4	6.5	8.1	8.4	10.3	10.1	8.7	7.5
		MCWBR	3.9	4.0	4.2	4.6	4.7	4.1	4.9	5.2	5.4	5.6	4.7	4.1
	5% WB	MCDBR	6.2	5.8	5.6	6.1	6.4	4.9	6.6	7.1	8.2	7.5	6.8	6.1
		MCWBR	4.2	3.7	4.1	4.3	4.6	3.7	4.8	5.3	5.4	5.0	4.3	3.9
Clear-Sky Solar Irradiance	taub	0.397	0.386	0.363	0.334	0.317	0.307	0.298	0.307	0.339	0.355	0.385	0.397	
	taud	2.443	2.501	2.541	2.597	2.595	2.618	2.632	2.598	2.509	2.495	2.443	2.422	
	Ebn at Noon	940	929	914	887	849	833	865	905	924	949	945	944	
	Edh at Noon	121	110	98	83	73	67	69	81	99	109	120	124	
All-Sky Solar Radiation	RadAvg	6.50	5.52	4.71	3.79	2.96	2.31	2.72	3.60	4.86	5.72	6.11	6.65	
	RadStd	0.49	0.48	0.39	0.32	0.18	0.21	0.22	0.19	0.29	0.45	0.52	0.50	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days</
--	-------	---------	--	---------	--	--	---------------