

MERRIWA, Australia

WMO: 957540

Lat: 32.1853S

Lon: 150.1736E

Elev: 376

StdP: 96.89

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.9	0.4	-5.5	2.5	14.2	-3.4	3.0	12.0	10.6	14.7	9.8	13.6	1.2	280	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	36.6	20.2	34.6	19.6	32.8	19.2	22.8	30.5	22.0	28.8	21.2	27.9	5.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.0	16.4	24.3	20.2	15.6	23.7	19.5	14.9	23.2	69.4	30.6	66.2	28.7	63.5	27.8	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.7	7.9	-3.7	40.0	0.8	2.8	-4.3	42.0	-4.8	43.7	-5.2	45.2	-5.8	47.3		
(5)			-4.0	24.9	0.9	1.3	-4.7	25.8	-5.2	26.6	-5.7	27.3	-6.4	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	23.9	22.5	20.5	16.5	12.4	10.0	9.0	10.1	13.3	16.6	20.0	21.9
	DBStd	5.88	3.34	3.29	2.74	2.81	2.35	2.15	2.14	2.29	2.77	3.58	3.43	3.39
	HDD10.0	106	0	0	0	1	6	26	45	26	2	1	0	0
	HDD18.3	1322	2	3	9	69	185	251	288	256	153	77	21	8
	CDD10.0	2424	431	351	326	194	79	26	15	29	101	206	299	369
	CDD18.3	598	174	121	77	13	0	0	0	0	2	24	69	118
	CDH23.3	6845	1914	1226	685	149	5	0	0	3	102	466	923	1371
	CDH26.7	3088	996	577	238	33	0	0	0	0	21	167	399	657
Wind	WSAvg	3.6	4.0	4.2	3.6	3.1	3.0	3.0	3.4	3.6	3.7	3.8	4.0	4.1
Precipitation	PrecAvg	625	66	69	43	38	33	49	41	38	43	53	68	85
	PrecMax	921	134	229	148	137	106	266	160	105	116	154	166	173
	PrecMin	342	8	6	0	0	0	10	0	1	0	5	10	14
	PrecStd	140	41	48	39	37	27	50	34	28	31	34	41	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.5	39.1	34.1	30.3	24.0	19.2	20.7	23.5	28.9	33.3	37.4	37.8
		MCWB	21.7	20.3	18.9	17.2	14.6	12.8	13.1	12.9	14.5	16.8	19.3	19.6
	2%	DB	36.8	35.4	31.8	27.1	22.0	17.3	18.3	21.1	26.4	30.8	33.7	35.1
		MCWB	20.7	20.3	19.4	17.1	14.4	12.1	10.9	11.7	13.8	16.1	17.9	19.5
	5%	DB	34.6	32.9	29.3	24.7	20.2	16.1	16.3	19.0	23.6	28.4	31.1	33.1
		MCWB	20.3	20.0	19.1	16.6	13.5	11.5	10.7	11.1	13.2	15.9	17.8	18.6
	10%	DB	32.4	30.1	27.2	22.9	18.6	14.9	14.8	16.9	21.3	25.8	28.6	30.6
		MCWB	20.2	19.8	18.8	16.1	13.0	11.2	10.3	10.3	12.6	15.3	17.1	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.0	23.7	23.1	20.2	17.6	14.7	15.8	15.1	16.7	19.9	21.2	22.7
		MCDB	33.5	31.6	26.6	24.3	19.8	17.1	18.3	19.6	23.2	27.4	31.0	31.3
	2%	WB	22.9	22.7	21.5	18.6	16.0	13.6	13.3	13.3	15.6	18.4	20.2	21.4
		MCDB	31.5	29.7	26.5	22.8	19.4	15.5	15.2	18.1	21.6	25.3	28.3	29.0
	5%	WB	22.1	21.7	20.6	17.8	14.7	12.7	11.8	12.1	14.6	17.4	19.4	20.6
		MCDB	29.5	28.1	25.4	22.2	18.4	14.6	14.3	17.1	20.5	24.2	26.7	27.7
	10%	WB	21.4	20.9	19.7	16.9	13.7	12.1	10.7	11.0	13.6	16.5	18.7	19.9
		MCDB	28.4	27.2	24.5	21.6	17.5	14.0	13.7	15.7	19.4	23.3	25.3	26.8
Mean Daily Temperature Range	5% DB	MDBR	13.6	12.9	12.5	13.0	13.2	10.9	12.5	14.0	15.3	15.4	14.4	13.9
		MCDBR	18.3	17.5	16.2	15.5	15.7	12.8	15.2	18.1	19.8	20.0	19.0	18.5
		MCWBR	5.5	5.6	6.3	7.0	8.6	8.0	9.2	9.8	9.5	8.1	6.5	6.0
	5% WB	MCDBR	14.1	13.4	12.8	12.8	12.7	9.8	11.6	14.9	15.3	15.6	14.7	14.2
		MCWBR	5.2	5.4	5.9	6.4	7.5	6.6	8.1	8.8	8.5	7.6	5.9	5.5
Clear-Sky Solar Irradiance	taub	0.360	0.359	0.333	0.310	0.292	0.285	0.280	0.288	0.317	0.334	0.360	0.353	
	taud	2.502	2.527	2.584	2.621	2.618	2.645	2.643	2.603	2.510	2.494	2.463	2.508	
	Ebn at Noon	978	960	952	925	893	877	899	935	953	974	972	988	
	Edh at Noon	114	108	95	82	73	67	70	82	101	110	118	114	
All-Sky Solar Radiation	RadAvg	7.10	6.27	5.25	4.27	3.32	2.60	3.01	3.95	5.24	6.14	6.62	7.21	
	RadStd	0.44	0.52	0.45	0.32	0.22	0.21	0.20	0.26	0.34	0.56	0.66	0.54	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.45	N/A	N/A	N/A	N/A	-8	-86	+173

Nomenclature: See separate page