

COORANBONG, Australia

WMO: 957670

Lat: 33.0886S

Lon: 151.4636E

Elev: 21

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.7	37.0	27.4	21.4	62.2	30.3	24.4	58.3	13.5	62.6	12.0	62.5	0.1	0	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.3	94.5	69.3	89.5	69.4	85.8	69.9	75.0	85.5	73.7	83.4	72.5	81.5	7.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	118.3	79.3	70.8	113.7	78.1	69.7	109.3	77.2	38.6	85.8	37.3	83.5	36.2	81.6	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.9	9.6	30.5	104.6	1.9	4.6	29.1	107.9	28.0	110.6	27.0	113.2	25.6	116.5
			30.0	78.0	1.9	1.5	28.7	79.1	27.6	80.0	26.5	80.8	25.1	81.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	73.3	72.1	69.8	64.1	57.9	54.5	52.7	53.6	58.7	62.7	67.2	70.3
	DBStd	8.46	5.21	4.56	3.97	4.02	3.78	3.69	3.59	3.80	4.75	5.32	5.40	5.10
	HDD50	26	0	0	0	0	1	6	12	7	0	0	0	0
	HDD65	1697	2	1	4	61	223	316	381	353	200	111	35	10
	CDD50	4774	721	619	614	424	245	139	96	120	260	393	515	628
	CDD65	969	258	199	154	35	2	0	0	0	10	38	100	173
	CDH74	8047	2130	1426	932	291	41	1	4	27	284	575	946	1390
	CDH80	2732	814	443	213	65	1	0	0	2	91	219	377	507
(14) Wind	WSAvg	2.9	3.6	3.2	2.6	2.0	2.1	2.3	2.5	2.9	3.2	3.3	3.5	3.6
(15) Precipitation	PrecAvg	41.7	3.7	5.6	4.3	4.1	3.5	4.3	2.3	2.6	2.4	2.4	3.4	3.3
	PrecMax	70.4	11.8	21.3	10.9	12.5	11.2	19.3	6.5	10.0	6.6	7.8	9.1	8.5
	PrecMin	28.8	0.2	0.6	0.4	0.3	0.4	0.4	0.2	0.2	0.0	0.4	0.8	1.0
	PrecStd	10.3	2.5	4.3	2.2	3.3	2.6	3.5	1.6	2.4	1.7	1.6	2.0	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.2	99.0	91.5	87.9	78.3	70.3	74.0	77.7	87.9	93.1	98.6	97.9
		MCWB	70.9	72.1	70.9	66.4	61.9	58.4	59.0	58.3	61.3	62.4	68.3	67.2
	2%	DB	93.5	89.6	85.0	80.4	74.5	67.2	69.3	72.8	82.2	86.4	89.4	90.7
		MCWB	71.1	73.8	71.3	66.6	60.9	56.9	55.2	55.5	59.4	64.3	66.7	69.1
	5%	DB	87.3	84.4	81.6	76.8	71.4	65.3	66.0	68.8	75.9	80.1	83.5	85.4
		MCWB	73.4	71.9	70.3	65.8	60.3	56.3	54.1	54.4	58.7	64.3	67.8	69.7
	10%	DB	83.8	81.3	79.1	74.1	68.6	63.3	63.4	65.5	71.5	75.2	78.7	81.2
		MCWB	72.2	70.9	69.0	64.3	58.4	55.8	53.4	53.3	57.7	63.7	67.6	69.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.2	76.8	74.6	71.1	65.6	61.8	62.3	60.7	64.7	69.8	73.6	75.2
		MCDB	88.1	89.7	82.9	79.8	72.2	65.2	70.0	71.0	76.3	80.9	85.9	87.9
	2%	WB	75.3	74.7	72.6	68.8	63.5	59.9	59.0	58.5	62.7	67.8	71.4	73.0
		MCDB	86.0	84.2	80.8	75.6	70.8	64.0	64.5	66.4	72.7	78.1	82.0	84.0
	5%	WB	73.9	73.2	71.5	67.4	61.7	58.4	56.8	56.7	61.2	66.1	69.8	71.7
		MCDB	84.0	81.8	79.6	74.1	68.6	62.7	62.4	64.4	71.5	74.8	79.6	81.3
	10%	WB	72.7	72.0	70.2	65.9	60.1	57.2	54.9	55.1	59.7	64.6	68.2	70.2
		MCDB	81.8	79.5	77.5	72.3	66.6	61.4	60.6	62.8	68.9	72.9	76.8	78.6
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	17.4	17.8	20.2	22.7	18.8	22.9	24.7	24.8	22.4	19.9	19.1
		MCDBR	27.4	24.8	23.0	25.4	27.1	21.6	28.0	31.6	34.7	34.4	30.9	28.7
		MCWBR	10.7	10.6	10.7	13.1	15.0	12.8	15.8	16.5	15.3	14.7	12.4	11.1
	5% WB	MCDBR	22.2	20.3	20.3	21.1	23.8	17.1	21.2	24.7	26.7	26.0	24.1	22.7
		MCWBR	9.9	9.2	10.2	11.7	14.4	11.5	13.8	14.8	14.2	13.7	11.5	10.4
(40) Clear-Sky Solar Irradiance	taub		0.400	0.390	0.359	0.335	0.318	0.310	0.302	0.310	0.345	0.367	0.395	0.389
	taud		2.437	2.487	2.563	2.601	2.598	2.617	2.623	2.589	2.487	2.450	2.415	2.455
	Ebn at Noon		298	294	293	283	272	266	276	288	292	298	297	302
	Edh at Noon		39	36	31	27	23	22	23	26	33	36	39	38
(44) All-Sky Solar Radiation	RadAvg		2062	1807	1529	1231	973	775	905	1197	1574	1806	1935	2091
	RadStd		140	154	134	103	74	66	73	73	84	153	179	171

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+0.81	N/A	N/A	+1.53	N/A	N/A	-4	-153	+340	+184

Nomenclature: See separate page