

COORANBONG, Australia

WMO: 957670

Lat: 33.0886S

Lon: 151.4636E

Elev: 7

StdP: 101.25

Time Zone: 10.00 (AUS)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 1.5	(c) 2.8	(d) -2.6	(e) 3.1	(f) 16.8	(g) -1.0	(h) 3.5	(i) 14.6	(j) 6.0	(k) 17.0	(l) 5.3	(m) 16.9	(n) 0.1	(o) 0	(p) 0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 10.2	(c) 34.7	(d) 20.7	(e) 32.0	(f) 20.8	(g) 29.9	(h) 21.0	(i) 23.9	(j) 29.7	(k) 23.1	(l) 28.6	(m) 22.5	(n) 27.5	(o) 3.5	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	16.9	26.3	21.6	16.2	25.6	20.9	15.6	25.1	71.9	29.9	68.8	28.6	66.4	27.6	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.5	4.9	4.3	-0.8	40.4	1.0	2.5	-1.6	42.2	-2.2	43.7	-2.8	45.1	-3.6	47.0
			-1.1	25.6	1.0	0.8	-1.9	26.2	-2.5	26.7	-3.1	27.1	-3.8	27.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	22.9	22.3	21.0	17.8	14.4	12.5	11.5	12.0	14.8	17.0	19.5	21.3
	DBStd	4.70	2.89	2.53	2.21	2.23	2.10	2.05	2.00	2.11	2.64	2.95	3.00	2.83
	HDD10.0	14	0	0	0	0	1	3	7	4	0	0	0	0
	HDD18.3	943	1	1	2	34	124	176	212	196	111	62	19	6
	CDD10.0	2652	401	344	341	236	136	77	53	67	144	218	286	349
	CDD18.3	538	143	111	86	19	1	0	0	0	6	21	56	96
	CDH23.3	4471	1183	792	518	162	23	1	2	15	158	319	526	772
	CDH26.7	1518	452	246	118	36	1	0	0	1	51	122	209	282
(14) Wind	WSAvg	1.3	1.6	1.4	1.2	0.9	0.9	1.0	1.1	1.3	1.5	1.5	1.6	1.6
(15) Precipitation	PrecAvg	1059	93	141	108	104	89	108	59	66	60	60	87	84
	PrecMax	1789	300	542	276	317	284	491	165	253	168	198	230	215
	PrecMin	732	6	14	11	8	10	9	6	5	1	10	21	25
	PrecStd	262	63	110	56	83	66	90	40	61	44	41	52	49
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.0	37.2	33.1	31.1	25.7	21.3	23.3	25.4	31.1	34.0	37.0	36.6
		MCWB	21.6	22.3	21.6	19.1	16.6	14.7	15.0	14.6	16.3	16.9	20.1	19.6
	2%	DB	34.2	32.0	29.4	26.9	23.6	19.6	20.7	22.7	27.9	30.2	31.9	32.6
		MCWB	21.7	23.2	21.9	19.2	16.1	13.9	12.9	13.1	15.2	17.9	19.3	20.6
	5%	DB	30.7	29.1	27.6	24.9	21.9	18.5	18.9	20.4	24.4	26.7	28.6	29.7
		MCWB	23.0	22.2	21.3	18.8	15.7	13.5	12.3	12.4	14.8	17.9	19.9	20.9
	10%	DB	28.8	27.4	26.1	23.4	20.3	17.4	17.5	18.6	22.0	24.0	25.9	27.4
		MCWB	22.3	21.6	20.5	17.9	14.7	13.2	11.9	11.8	14.3	17.6	19.8	20.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	24.9	23.7	21.7	18.7	16.5	16.8	15.9	18.2	21.0	23.1	24.0
		MCDB	31.2	32.1	28.3	26.5	22.3	18.4	21.1	21.7	24.6	27.2	29.9	31.0
	2%	WB	24.0	23.7	22.6	20.4	17.5	15.5	15.0	14.7	17.1	19.9	21.9	22.8
		MCDB	30.0	29.0	27.1	24.2	21.6	17.8	18.0	19.1	22.6	25.6	27.8	28.9
	5%	WB	23.3	22.9	21.9	19.6	16.5	14.7	13.8	13.7	16.2	19.0	21.0	22.0
		MCDB	28.9	27.7	26.5	23.4	20.4	17.0	16.9	18.0	21.9	23.8	26.5	27.4
	10%	WB	22.6	22.2	21.2	18.8	15.6	14.0	12.7	12.8	15.4	18.1	20.1	21.2
		MCDB	27.7	26.4	25.3	22.4	19.2	16.3	15.9	17.1	20.5	22.7	24.9	25.9
(35) Mean Daily Temperature Range	MDBR		10.2	9.6	9.9	11.2	12.6	10.5	12.7	13.7	13.8	12.4	11.1	10.6
	5% DB	MCDBR	15.2	13.8	12.8	14.1	15.1	12.0	15.5	17.5	19.3	19.1	17.2	16.0
		MCWBR	6.0	5.9	6.0	7.3	8.4	7.1	8.8	9.1	8.5	8.2	6.9	6.2
	5% WB	MCDBR	12.3	11.3	11.3	11.7	13.2	9.5	11.8	13.7	14.8	14.5	13.4	12.6
		MCWBR	5.5	5.1	5.7	6.5	8.0	6.4	7.7	8.2	7.9	7.6	6.4	5.8
(40) Clear-Sky Solar Irradiance	taub		0.400	0.390	0.359	0.335	0.318	0.310	0.302	0.310	0.345	0.367	0.395	0.389
	taud		2.437	2.487	2.563	2.601	2.598	2.617	2.623	2.589	2.487	2.450	2.415	2.455
	Ebn at Noon		939	928	923	893	858	840	869	907	922	939	937	953
	Edh at Noon		122	112	97	84	74	69	71	83	103	115	124	120
(44) All-Sky Solar Radiation	RadAvg		6.50	5.70	4.82	3.88	3.07	2.44	2.85	3.77	4.96	5.69	6.10	6.59
	RadStd		0.44	0.49	0.42	0.33	0.23	0.21	0.23	0.23	0.27	0.48	0.56	0.54

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+0.45	N/A	N/A	+0.85	N/A	N/A	-2	-85	+189	+102

Nomenclature: See separate page