

TAREE, Australia

WMO: 957840

Lat: 31.890S

Lon: 152.512E

Elev: 9

StdP: 101.22

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	5.0	-2.4	3.1	15.6	-0.9	3.5	14.2	9.3	15.6	8.4	15.6	1.3	270	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.6	33.9	22.1	31.8	21.9	29.9	21.7	24.5	30.1	23.7	28.5	23.1	27.3	5.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.1	17.9	26.2	22.2	16.9	25.2	21.9	16.6	24.9	74.3	30.3	71.3	28.6	68.6	27.3	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.1	7.2	0.3	38.7	1.4	2.5	-0.8	40.5	-1.6	41.9	-2.4	43.3	-3.4	45.1		
(5)			-0.2	26.5	1.3	1.1	-1.1	27.2	-1.9	27.9	-2.6	28.5	-3.6	29.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	23.6	23.1	21.6	18.8	15.6	13.5	12.5	13.3	16.1	18.1	20.4	22.0	(6)
(7)		DBStd	4.43	2.46	2.30	1.96	1.81	2.00	1.92	1.79	2.05	2.57	2.65	2.84	2.58	(7)
(8)		HDD10.0	3	0	0	0	0	0	1	2	1	0	0	0	0	(8)
(9)		HDD18.3	714	0	0	1	15	88	146	181	156	78	37	10	2	(9)
(10)		CDD10.0	2985	421	366	358	263	173	105	79	104	182	251	311	373	(10)
(11)		CDD18.3	655	162	133	101	29	3	0	0	1	10	29	71	117	(11)
(12)		CDH23.3	4682	1211	876	532	155	24	1	3	20	174	314	542	829	(12)
(13)		CDH26.7	1490	439	277	122	23	2	0	0	2	56	102	191	277	(13)
(14)	Wind	WSAvg	3.1	3.6	3.3	2.9	2.7	2.8	2.9	2.8	3.0	3.1	3.3	3.5	3.6	(14)
(15)	Precipitation	PrecAvg	1192	125	125	181	114	114	98	53	50	81	99	95	(15)	
(16)		PrecMax	2410	349	362	710	448	355	342	217	221	169	321	303	312	(16)
(17)		PrecMin	556	19	19	5	1	6	3	1	0	0	6	10	9	(17)
(18)		PrecStd	369	76	83	165	108	99	72	49	54	42	73	65	65	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.9	36.1	32.3	29.2	25.9	22.2	23.2	25.9	32.6	33.2	34.8	36.0	(19)
(20)			MCWB	23.9	24.2	22.9	19.7	16.7	15.1	14.4	15.4	16.7	18.1	21.5	21.2	(20)
(21)		2%	DB	33.2	32.0	29.2	26.8	23.8	20.4	21.1	22.9	27.8	29.4	31.1	32.1	(21)
(22)			MCWB	23.7	23.3	22.0	19.4	16.6	14.4	13.1	13.7	16.7	18.4	21.2	22.5	(22)
(23)		5%	DB	30.9	29.8	27.9	25.0	22.1	19.1	19.2	21.0	25.0	26.6	28.8	29.5	(23)
(24)			MCWB	22.8	22.8	21.6	18.9	15.9	13.9	12.6	13.3	15.8	18.1	20.6	21.6	(24)
(25)		10%	DB	29.0	28.0	26.1	23.8	20.8	18.0	17.8	19.2	22.7	24.2	26.2	27.3	(25)
(26)			MCWB	22.1	21.9	20.8	18.1	15.5	13.7	12.2	12.8	15.2	17.5	19.9	20.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.8	26.0	24.3	21.6	19.3	17.6	16.9	17.5	19.6	21.7	24.6	24.5	(27)
(28)			MCDWB	33.2	33.0	29.5	25.3	22.7	19.5	20.2	22.4	25.7	26.8	31.0	30.6	(28)
(29)		2%	WB	24.5	24.5	23.2	20.6	18.2	16.4	15.4	15.8	18.2	20.5	22.7	23.5	(29)
(30)			MCDWB	30.3	29.3	27.4	24.1	21.4	18.4	18.0	19.4	23.2	25.4	28.1	28.8	(30)
(31)		5%	WB	23.7	23.6	22.3	19.8	17.2	15.6	14.2	14.8	17.2	19.4	21.6	22.6	(31)
(32)			MCDWB	28.4	27.6	26.0	23.2	20.4	17.6	17.1	18.8	22.2	23.8	26.1	27.4	(32)
(33)		10%	WB	23.0	22.7	21.6	19.1	16.3	14.8	13.3	13.8	16.3	18.5	20.7	21.8	(33)
(34)			MCDWB	26.9	26.4	24.9	22.4	19.3	16.9	16.2	17.8	21.2	22.7	24.6	25.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	9.1	9.3	9.9	10.8	9.8	11.4	12.4	12.8	11.6	10.2	10.0	(35)
(36)			MCDBR	13.7	12.6	12.1	12.8	13.0	11.8	14.5	16.0	17.2	16.6	15.1	14.2	(36)
(37)			MCWBR	5.7	5.1	5.6	6.3	6.8	6.7	7.9	8.3	7.9	7.6	6.6	6.0	(37)
(38)		5% WB	MCDWB	10.9	10.8	10.3	10.9	10.6	8.8	11.0	13.1	14.5	13.0	12.1	11.5	(38)
(39)			MCWBR	5.1	4.9	5.1	5.9	6.2	6.0	6.9	7.7	7.6	6.7	6.0	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.382	0.358	0.339	0.315	0.308	0.300	0.311	0.351	0.364	0.388	0.391	(40)	
(41)		taud	2.452	2.516	2.574	2.598	2.616	2.630	2.634	2.588	2.467	2.469	2.447	2.459	(41)	
(42)		Ebn at Noon	944	938	927	894	868	851	877	911	918	944	945	952	(42)	
(43)		Edh at Noon	120	109	97	85	74	69	72	84	105	113	120	120	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.51	5.76	4.87	4.00	3.21	2.62	3.01	3.94	5.10	5.74	6.10	6.48	(44)	
(45)		RadStd	0.44	0.46	0.43	0.27	0.23	0.19	0.24	0.26	0.31	0.47	0.61	0.52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-69	+160	+87

Nomenclature: See separate page