

STENHOUSE BAY, Australia

WMO: 958060

Lat: 35.279S

Lon: 136.939E

Elev: 44

StdP: 100.80

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	7.8	2.0	4.4	16.0	3.1	4.7	13.3	14.1	11.6	13.2	11.8	3.6	0	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.1	32.4	18.2	28.8	17.9	26.3	18.2	20.8	25.9	20.1	24.9	19.5	24.2	7.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.3	22.4	18.5	13.4	22.2	17.7	12.8	21.8	60.5	25.9	58.0	25.0	55.8	24.1	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.5	10.5	DB	4.7	39.9	0.7	3.0	4.2	42.1	3.8	43.8	3.3	45.4	2.8	47.6	(4)
(5)			WB	3.9	22.6	0.8	1.5	3.3	23.7	2.8	24.6	2.3	25.5	1.7	26.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	20.4	20.4	19.4	17.4	15.2	13.0	12.2	12.5	13.8	15.4	17.2	18.7	(6)	
	DBStd	3.75	2.94	2.68	2.76	2.33	1.80	1.56	1.42	1.59	2.17	2.71	3.00	2.93	(7)	
	HDD10.0	2	0	0	0	0	0	1	1	1	0	0	0	0	(8)	
	HDD18.3	1019	6	4	14	43	100	160	191	180	137	100	56	28	(9)	
	CDD10.0	2295	322	291	291	223	161	91	69	79	115	169	217	269	(10)	
	CDD18.3	270	69	62	47	16	2	0	0	0	2	11	23	38	(11)	
	CDH23.3	1482	383	275	229	83	8	0	0	0	12	94	162	236	(12)	
(13)	CDH26.7	576	155	103	88	28	1	0	0	0	1	29	71	100	(13)	
(14)	Wind	WSAvg	5.9	6.4	6.3	6.1	5.3	5.4	5.8	5.8	6.0	6.1	6.2	6.1	(14)	
(15) Precipitation	PrecAvg	506	16	16	18	32	56	80	78	71	57	35	23	21	(15)	
	PrecMax	733	36	73	76	69	119	150	132	107	125	90	87	68	(16)	
	PrecMin	325	3	0	1	0	15	30	43	21	18	1	3	2	(17)	
	PrecStd	103	10	19	18	19	25	28	23	27	26	21	17	16	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.6	36.0	34.6	30.8	24.4	18.9	18.2	21.2	24.8	30.2	34.1	35.6	(19)	
		MCWB	18.7	19.7	18.9	17.0	15.3	14.1	13.0	13.2	14.3	16.0	17.2	18.4	(20)	
	2%	DB	30.3	29.2	28.5	25.5	21.2	17.4	16.6	18.4	22.0	25.9	27.7	28.9	(21)	
		MCWB	19.1	19.2	18.1	16.4	15.2	13.4	12.6	12.9	13.9	14.8	16.9	17.4	(22)	
	5%	DB	26.8	26.0	25.2	22.1	19.3	16.4	15.6	16.6	19.6	22.2	23.8	25.2	(23)	
		MCWB	19.4	19.5	18.8	16.8	14.9	13.0	12.2	12.4	13.3	14.4	16.7	17.8	(24)	
	10%	DB	24.6	24.1	23.1	20.5	18.0	15.6	14.8	15.4	17.5	19.3	21.3	22.9	(25)	
		MCWB	18.9	19.0	18.4	16.2	14.4	12.7	11.7	12.0	13.2	14.4	16.4	17.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	22.3	21.8	19.0	17.5	15.4	14.5	14.7	16.1	17.5	19.6	20.4	(27)	
		MCDB	28.2	27.7	26.1	23.3	19.8	17.0	16.0	17.3	21.1	24.2	26.6	26.0	(28)	
	2%	WB	20.7	20.8	20.4	18.1	16.4	14.5	13.6	13.8	15.1	16.2	18.5	19.3	(29)	
		MCDB	26.4	25.8	24.1	21.6	18.8	16.0	15.4	16.4	19.1	21.6	24.6	24.5	(30)	
	5%	WB	20.0	20.0	19.5	17.4	15.7	13.8	12.9	13.1	14.3	15.4	17.5	18.5	(31)	
		MCDB	25.2	24.5	23.6	20.7	18.0	15.5	14.7	15.6	17.8	19.9	22.2	23.5	(32)	
	10%	WB	19.2	19.4	18.6	16.8	15.0	13.2	12.3	12.5	13.6	14.7	16.6	17.7	(33)	
		MCDB	24.0	23.7	22.7	19.9	17.3	15.0	14.2	14.9	16.8	18.6	20.7	22.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	6.6	6.2	5.9	5.4	5.0	5.2	5.8	6.6	7.0	6.9	7.0	(35)	
		MCDBR	12.2	10.5	11.0	9.7	8.1	6.3	6.5	8.3	11.2	13.4	12.3	12.3	(36)	
		MCWBR	4.0	3.9	4.3	4.5	4.4	3.9	4.0	4.5	5.1	5.1	4.4	4.3	(37)	
	5% WB	MCDBR	9.5	8.4	8.7	7.5	6.5	5.2	5.6	6.9	8.7	9.8	9.9	9.5	(38)	
		MCWBR	4.1	3.9	4.2	4.1	4.1	3.7	4.1	4.4	4.8	4.7	4.3	4.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.340	0.326	0.319	0.310	0.303	0.300	0.310	0.333	0.342	0.341	0.335	(40)	
	taud		2.574	2.598	2.626	2.633	2.638	2.639	2.644	2.604	2.530	2.504	2.538	2.582	(41)	
	Ebn at Noon		993	975	953	902	856	835	859	899	929	961	989	1005	(42)	
	Edh at Noon		105	99	90	79	69	65	68	80	97	108	109	106	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.46	6.45	5.18	3.74	2.60	2.15	2.34	3.23	4.47	5.73	6.82	7.31	(44)	
	RadStd		0.35	0.29	0.20	0.22	0.12	0.12	0.10	0.20	0.33	0.37	0.37	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.23	N/A	N/A	+1.10	N/A	N/A	N/A	-102	+121	N/A
(47)	Regional (24 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70

Nomenclature: See separate page