

PALLAMANA, Australia

WMO: 958180

Lat: 35.0650S

Lon: 139.2272E

Elev: 149

StdP: 14.62

Time Zone: 9.50 (AUA)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.9	35.3	20.2	15.2	82.5	25.0	19.2	75.6	28.1	56.5	26.0	57.6	3.3	340	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	102.4	65.4	97.3	64.0	92.5	63.4	70.0	87.0	68.2	85.0	66.5	83.2	14.1	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	97.9	74.1	63.6	88.6	71.3	61.5	82.0	70.0	34.0	86.3	32.6	84.2	31.2	83.3	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.4	22.7	20.5	DB	28.4	110.2	1.4	3.1	27.3	112.5	26.5	114.3	25.7	116.0	24.7	118.3	(4)
(5)			WB	30.3	77.6	1.3	5.3	29.4	81.4	28.6	84.5	27.8	87.5	26.8	91.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.6	71.6	70.4	67.3	62.0	56.2	51.1	50.4	51.1	54.3	59.7	64.9	68.4	(6)	
	DBStd	9.52	7.19	6.80	6.71	5.31	4.10	3.72	3.65	3.98	4.92	6.52	7.30	7.16	(7)	
	HDD50	109	0	0	0	0	2	30	39	30	7	1	0	0	(8)	
	HDD65	2420	12	18	49	122	273	416	452	430	323	196	91	38	(9)	
	CDD50	3974	670	572	537	360	195	65	52	66	137	301	448	571	(10)	
	CDD65	807	217	169	121	32	1	0	0	0	3	31	90	143	(11)	
	CDH74	10928	2724	1892	1382	497	34	0	1	15	122	759	1460	2042	(12)	
	CDH80	5676	1572	1000	661	184	2	0	0	2	25	325	773	1132	(13)	
(14) Wind	WSAvg	10.1	12.0	11.2	10.2	8.8	8.7	8.3	9.8	9.6	9.9	10.6	11.1	11.5	(14)	
(15) Precipitation	PrecAvg	13.9	0.7	0.8	0.7	1.1	1.4	1.5	1.5	1.6	1.5	1.5	1.1	0.9	(15)	
	PrecMax	26.6	2.6	5.0	3.7	3.8	3.4	6.5	3.0	3.2	3.1	5.4	3.4	4.4	(16)	
	PrecMin	5.4	0.0	0.0	0.0	0.0	0.2	0.2	0.2	0.4	0.3	0.1	0.0	0.1	(17)	
	PrecStd	3.3	0.6	1.0	0.8	0.9	0.8	1.1	0.7	0.7	0.7	1.2	0.7	0.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.3	103.7	101.4	92.9	78.7	66.9	68.2	75.8	83.5	95.2	100.8	105.9	(19)	
		MCWB	67.8	65.6	64.2	62.2	57.8	53.3	54.5	55.3	57.1	60.5	63.8	67.3	(20)	
	2%	DB	103.7	97.8	93.1	85.1	72.8	63.7	63.7	68.6	77.2	88.6	95.2	99.2	(21)	
		MCWB	66.5	64.9	65.0	59.7	56.9	53.1	53.3	53.1	55.0	58.7	62.3	63.9	(22)	
	5%	DB	96.6	92.0	87.7	79.4	68.4	61.5	61.0	64.1	72.2	82.8	89.6	92.8	(23)	
		MCWB	65.1	65.0	62.8	58.0	55.5	52.7	52.4	52.2	54.5	57.9	61.6	62.7	(24)	
	10%	DB	88.5	85.7	81.5	74.2	65.4	59.4	58.7	60.8	67.2	76.6	82.8	85.4	(25)	
		MCWB	64.3	63.9	62.6	57.4	55.0	52.2	51.3	51.2	53.1	56.8	59.8	61.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.6	72.8	69.9	65.5	60.9	57.1	59.0	57.6	60.0	64.9	68.8	72.9	(27)	
		MCDB	85.4	88.0	84.3	74.8	71.8	61.8	63.2	68.7	73.9	84.1	88.0	87.2	(28)	
	2%	WB	70.0	69.2	67.8	63.3	59.0	55.4	55.2	55.3	57.5	61.7	65.8	68.1	(29)	
		MCDB	89.5	82.6	82.2	74.2	67.7	60.2	60.0	64.8	70.7	79.2	82.4	84.9	(30)	
	5%	WB	68.0	67.4	65.9	61.4	57.5	54.1	53.5	53.5	55.9	59.6	64.1	65.4	(31)	
		MCDB	88.3	82.3	79.8	72.8	64.9	59.2	59.5	61.3	68.0	75.4	81.8	83.2	(32)	
	10%	WB	66.0	65.5	64.2	59.5	56.3	53.0	52.1	52.1	54.3	57.8	62.0	63.4	(33)	
		MCDB	84.0	81.6	78.5	70.0	63.1	58.1	57.7	59.5	64.9	72.3	77.7	79.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	26.8	24.8	24.1	23.5	18.5	17.0	17.3	19.7	24.3	27.3	26.8	26.9	(35)	
		MCDBR	42.3	36.9	34.9	34.1	25.3	21.0	21.5	27.0	35.2	40.5	40.6	40.7	(36)	
		MCWBR	13.6	11.5	11.5	13.6	12.0	12.1	13.2	14.4	15.9	15.9	13.2	13.2	(37)	
	5% WB	MCDBR	31.5	28.3	26.8	24.2	20.3	16.5	18.4	22.6	28.7	32.1	32.3	29.4	(38)	
		MCWBR	13.0	10.6	10.0	11.1	10.8	10.5	12.4	13.5	14.6	14.0	12.0	12.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.339	0.320	0.311	0.302	0.294	0.294	0.306	0.329	0.341	0.342	0.336	(40)	
	taud		2.502	2.525	2.569	2.579	2.586	2.590	2.578	2.527	2.459	2.434	2.465	2.504	(41)	
	Ebn at Noon		316	310	304	289	274	268	274	285	295	305	313	318	(42)	
	Edh at Noon		36	34	30	26	23	21	23	27	33	36	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2477	2182	1773	1279	874	727	784	1075	1470	1905	2249	2436	(44)	
	RadStd		124	111	80	72	38	45	32	67	117	120	104	92	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-166	+284	+126

Nomenclature: See separate page