

PALLAMANA, Australia

WMO: 958180

Lat: 35.0650S

Lon: 139.2272E

Elev: 46

StdP: 100.78

Time Zone: 9.50 (AUA)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.5	1.8	-6.6	2.2	28.0	-3.9	2.7	24.2	12.6	13.6	11.6	14.2	1.5	340	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	39.1	18.6	36.3	17.8	33.6	17.4	21.1	30.5	20.1	29.4	19.2	28.4	6.3	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.0	23.4	17.6	12.7	21.8	16.4	11.7	21.1	61.3	30.2	57.9	29.0	54.7	28.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	10.1	9.2	DB	-2.0	43.5	0.8	1.7	-2.6	44.7	-3.0	45.7	-3.5	46.7	-4.1	47.9	(4)
(5)			WB	-0.9	25.3	0.7	3.0	-1.5	27.5	-1.9	29.2	-2.3	30.8	-2.9	33.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	22.0	21.3	19.6	16.7	13.5	10.6	10.2	10.6	12.4	15.4	18.3	20.2	(6)	
	DBStd	5.29	3.99	3.78	3.73	2.95	2.28	2.07	2.03	2.21	2.73	3.62	4.05	3.98	(7)	
	HDD10.0	61	0	0	0	0	1	17	22	17	4	1	0	0	(8)	
	HDD18.3	1344	7	10	27	68	152	231	251	239	179	109	51	21	(9)	
	CDD10.0	2208	372	318	298	200	108	36	29	37	76	167	249	317	(10)	
	CDD18.3	448	121	94	67	18	1	0	0	0	2	17	50	79	(11)	
	CDH23.3	6071	1513	1051	768	276	19	0	1	8	68	422	811	1134	(12)	
(13)	CDH26.7	3153	873	556	367	102	1	0	0	1	14	181	429	629	(13)	
(14)	Wind	WSAvg	4.5	5.4	5.0	4.6	3.9	3.7	4.4	4.3	4.4	4.7	5.0	5.1	(14)	
(15) Precipitation	PrecAvg	353	17	20	19	28	35	39	37	40	38	38	28	23	(15)	
	PrecMax	675	65	128	95	96	86	165	75	82	79	136	87	112	(16)	
	PrecMin	136	0	0	0	0	5	5	4	9	8	2	0	2	(17)	
	PrecStd	83	15	26	20	22	20	28	19	18	19	30	19	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	39.9	38.6	33.8	25.9	19.4	20.1	24.3	28.6	35.1	38.2	41.0	(19)	
		MCWB	19.9	18.7	17.9	16.8	14.3	11.8	12.5	12.9	13.9	15.8	17.6	19.6	(20)	
	2%	DB	39.8	36.6	34.0	29.5	22.7	17.6	17.6	20.4	25.1	31.5	35.1	37.3	(21)	
		MCWB	19.1	18.3	18.3	15.4	13.9	11.7	11.8	11.7	12.8	14.8	16.8	17.7	(22)	
	5%	DB	35.9	33.3	31.0	26.3	20.2	16.4	16.1	17.8	22.3	28.2	32.0	33.8	(23)	
		MCWB	18.4	18.4	17.1	14.4	13.1	11.5	11.3	11.2	12.5	14.4	16.4	17.1	(24)	
	10%	DB	31.4	29.8	27.5	23.5	18.6	15.2	14.9	16.0	19.5	24.8	28.2	29.6	(25)	
		MCWB	17.9	17.7	17.0	14.1	12.8	11.2	10.7	10.7	11.7	13.8	15.5	16.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	22.7	21.0	18.6	16.1	13.9	15.0	14.2	15.6	18.3	20.4	22.7	(27)	
		MCDB	29.7	31.1	29.1	23.8	22.1	16.5	17.4	20.4	23.3	28.9	31.1	30.7	(28)	
	2%	WB	21.1	20.7	19.9	17.4	15.0	13.0	12.9	12.9	14.2	16.5	18.8	20.1	(29)	
		MCDB	32.0	28.1	27.9	23.5	19.8	15.7	15.6	18.2	21.5	26.2	28.0	29.4	(30)	
	5%	WB	20.0	19.7	18.8	16.3	14.2	12.3	12.0	12.0	13.3	15.4	17.8	18.5	(31)	
		MCDB	31.3	27.9	26.6	22.7	18.3	15.1	15.3	16.3	20.0	24.1	27.7	28.4	(32)	
	10%	WB	18.9	18.6	17.9	15.3	13.5	11.6	11.2	11.2	12.4	14.3	16.6	17.5	(33)	
		MCDB	28.9	27.5	25.8	21.1	17.3	14.5	14.3	15.3	18.3	22.4	25.4	26.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	13.8	13.4	13.1	10.3	9.5	9.6	11.0	13.5	15.2	14.9	14.9	(35)	
		MCDBR	23.5	20.5	19.4	18.9	14.0	11.7	11.9	15.0	19.6	22.5	22.6	22.6	(36)	
	5% WB	MCWBR	7.6	6.4	6.4	7.6	6.7	6.7	7.3	8.0	8.8	8.8	7.3	7.4	(37)	
		MCDWR	17.5	15.7	14.9	13.5	11.3	9.1	10.2	12.6	15.9	17.8	18.0	16.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.339	0.320	0.311	0.302	0.294	0.294	0.306	0.329	0.341	0.342	0.336	(40)	
		taud	2.502	2.525	2.569	2.579	2.586	2.590	2.578	2.527	2.459	2.434	2.465	2.504	(41)	
	Ebn at Noon		995	976	958	910	864	845	863	900	931	961	987	1004	(42)	
		Edh at Noon	113	107	95	83	72	67	72	86	104	115	117	114	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.81	6.88	5.59	4.03	2.76	2.29	2.47	3.39	4.63	6.01	7.09	7.68	(44)	
	RadStd		0.39	0.35	0.25	0.23	0.12	0.14	0.10	0.21	0.37	0.38	0.33	0.29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (26 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-92	+158	+70	(47)	

Nomenclature: See separate page