

KANAGULK, Australia

WMO: 958270

Lat: 37.1169S

Lon: 141.8031E

Elev: 621

StdP: 14.37

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.3	35.3	25.8	20.2	85.2	29.9	24.5	69.2	23.1	51.5	20.7	51.3	1.5	260	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.0	98.5	63.9	93.8	63.2	89.6	62.6	68.6	81.6	66.8	82.2	65.2	82.0	11.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	95.7	70.6	62.6	86.7	69.5	60.2	79.6	68.0	33.2	81.1	31.7	81.9	30.4	81.7	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	18.9	17.3	DB	29.6	106.5	1.7	3.9	28.4	109.3	27.4	111.6	26.4	113.8	25.2	116.6	(4)
(5)			WB	29.5	71.6	1.7	2.2	28.3	73.2	27.3	74.5	26.3	75.8	25.1	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	69.7	68.8	65.0	58.5	52.5	48.1	47.4	48.5	51.2	55.8	61.1	65.1	(6)
(7)		DBStd	9.88	7.63	7.09	7.02	5.94	4.58	3.57	3.40	3.96	4.68	6.51	7.60	7.49	(7)
(8)		HDD50	325	0	0	0	3	23	77	96	77	35	12	2	0	(8)
(9)		HDD65	3290	31	36	89	211	386	506	547	513	413	299	169	90	(9)
(10)		CDD50	3093	610	527	464	259	102	21	13	30	72	191	334	470	(10)
(11)		CDD65	583	175	143	88	17	0	0	0	0	0	13	52	95	(11)
(12)		CDH74	8732	2642	1834	1163	243	1	0	0	0	10	301	895	1643	(12)
(13)		CDH80	4231	1435	892	509	64	0	0	0	0	1	103	403	824	(13)
(14)	Wind	WSAvg	8.3	10.2	10.0	8.8	7.3	7.1	6.7	7.6	7.8	8.5	9.0	9.2	(14)	
(15)	Precipitation	PrecAvg	20.5	1.2	1.0	0.9	1.3	1.7	2.5	2.5	2.6	2.2	1.7	1.3	1.5	(15)
(16)		PrecMax	30.2	5.3	2.7	2.9	3.5	3.5	5.5	4.4	5.2	5.2	3.4	2.6	6.5	(16)
(17)		PrecMin	11.9	0.0	0.2	0.1	0.1	0.2	0.4	1.1	0.6	0.9	0.2	0.3	0.2	(17)
(18)		PrecStd	4.4	1.1	0.7	0.7	0.8	0.9	1.3	0.8	1.2	1.1	1.0	0.6	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.8	100.0	97.6	87.3	71.9	61.6	60.4	67.5	75.1	89.0	95.6	103.2	(19)
(20)			MCWB	65.8	67.0	63.5	62.0	56.9	53.7	53.4	54.9	57.5	60.0	63.4	63.5	(20)
(21)		2%	DB	100.5	95.0	90.6	80.4	67.4	58.7	57.2	62.6	68.8	82.2	90.0	95.7	(21)
(22)			MCWB	64.1	64.5	63.0	59.0	55.4	52.8	51.9	52.6	56.1	58.5	62.0	62.1	(22)
(23)		5%	DB	93.9	90.6	85.9	75.7	63.6	56.8	55.2	58.7	64.2	76.0	84.7	89.3	(23)
(24)			MCWB	63.6	64.2	62.1	57.5	55.2	52.0	51.1	51.8	54.5	57.6	61.8	61.2	(24)
(25)		10%	DB	88.0	85.4	80.3	70.9	60.7	55.0	53.6	56.0	60.8	70.4	78.3	83.3	(25)
(26)			MCWB	62.3	62.6	61.0	56.4	54.3	51.1	50.3	50.6	53.1	56.7	59.5	60.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	71.1	68.1	63.8	60.2	56.5	55.7	56.3	60.1	64.6	68.0	69.3	(27)
(28)			MCDWB	83.5	88.0	78.9	76.6	64.0	58.7	57.6	63.1	69.5	76.8	84.4	78.9	(28)
(29)		2%	WB	68.9	68.1	65.8	61.7	58.1	54.4	53.5	54.0	57.6	61.2	65.3	65.7	(29)
(30)			MCDWB	83.0	80.7	79.9	72.1	62.8	56.8	55.2	59.8	65.5	73.2	80.2	80.2	(30)
(31)		5%	WB	66.6	66.4	64.2	59.9	56.6	53.0	52.0	52.5	55.6	59.2	63.3	63.8	(31)
(32)			MCDWB	85.6	81.9	79.0	69.3	61.2	55.3	54.2	57.2	62.5	71.5	77.0	81.2	(32)
(33)		10%	WB	64.5	64.4	62.5	58.3	55.1	51.8	50.8	51.2	53.7	57.3	61.2	62.0	(33)
(34)			MCDWB	84.9	82.3	77.5	67.6	59.6	54.2	53.0	55.2	60.2	69.4	75.5	80.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	29.0	26.4	23.9	21.2	15.7	14.4	13.0	15.3	17.9	23.1	25.2	27.6	(35)
(36)			MCDBR	39.2	35.2	33.2	30.2	20.2	17.1	14.6	20.0	24.5	34.4	36.7	39.2	(36)
(37)			MCWBR	10.7	10.5	10.9	12.4	10.9	11.8	10.2	11.9	13.5	14.8	12.4	11.4	(37)
(38)		5% WB	MCDWB	28.9	26.9	26.6	21.9	15.6	13.9	12.8	17.5	21.9	27.4	29.1	28.7	(38)
(39)			MCWBR	11.1	9.8	10.8	10.5	9.9	10.5	9.8	11.2	13.2	13.9	11.8	10.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.332	0.316	0.307	0.299	0.294	0.295	0.305	0.324	0.336	0.334	0.332	(40)	
(41)		taud	2.497	2.526	2.569	2.577	2.579	2.581	2.577	2.531	2.466	2.440	2.480	2.506	(41)	
(42)		Ebn at Noon	316	310	303	287	271	263	270	283	295	305	315	319	(42)	
(43)		Edh at Noon	36	33	30	26	22	21	22	26	32	36	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2372	2083	1636	1146	766	619	670	946	1310	1739	2066	2307	(44)	
(45)		RadStd	137	100	76	70	38	48	39	55	98	141	142	129	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		+0.70	N/A	N/A	+1.60	N/A	N/A	N/A	-173	+238	+70

Nomenclature: See separate page