

WALPEUP, Australia

WMO: 958310

Lat: 35.1200S

Lon: 142.0039E

Elev: 344

StdP: 14.51

Time Zone: 10.00 (AUS)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.2	38.1	19.7	15.0	80.9	23.2	17.7	78.5	29.0	59.0	24.8	56.3	5.6	200	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.2	104.2	66.0	99.7	64.7	95.6	63.8	70.6	87.2	68.8	86.6	67.2	85.9	12.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	99.6	73.6	64.2	91.0	72.5	61.3	82.1	72.6	34.6	86.0	33.1	86.2	31.8	85.2	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	21.7	19.0	DB	32.6	110.9	1.6	2.8	31.5	112.9	30.6	114.6	29.7	116.1	28.6	118.2	(4)
(5)			WB	31.9	73.3	1.5	2.2	30.8	74.9	29.9	76.2	29.0	77.4	27.9	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	76.4	75.0	70.2	63.4	56.2	51.2	50.2	51.8	56.3	62.0	68.2	72.3
	DBStd	11.50	8.72	8.16	8.06	6.75	5.15	3.67	3.77	4.75	6.05	7.79	8.61	8.80
	HDD50	118	0	0	0	0	5	29	45	32	6	1	0	0
	HDD65	2232	6	8	33	110	276	415	460	410	274	156	62	22
	CDD50	4750	818	700	627	401	198	63	50	87	195	373	545	693
	CDD65	1390	359	288	195	61	4	0	0	1	12	63	157	250
	CDH74	18681	5090	3743	2289	610	28	0	0	12	196	947	2188	3578
	CDH80	9710	2957	2020	1060	195	1	0	0	0	51	393	1089	1944
Wind	WSAvg	9.6	10.5	10.2	9.3	8.8	8.9	8.5	9.2	9.2	9.8	10.2	10.4	10.5
Precipitation	PrecAvg	11.4	0.9	0.8	0.4	0.8	0.9	1.1	1.1	1.0	1.2	1.0	1.0	1.1
	PrecMax	19.5	4.4	4.2	2.1	2.8	3.1	2.8	2.5	2.2	4.8	2.7	2.8	4.4
	PrecMin	5.9	0.0	0.0	0.0	0.0	0.0	0.2	0.2	0.0	0.2	0.0	0.1	0.1
	PrecStd	3.7	1.0	0.9	0.5	0.8	0.7	0.6	0.6	0.6	1.0	0.9	0.7	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	110.1	107.2	100.8	92.1	77.7	67.1	67.1	75.6	86.2	95.6	102.1	107.4
		MCWB	67.4	68.5	65.0	62.9	57.7	54.5	53.1	54.7	57.7	60.2	64.0	65.6
	2%	DB	105.3	101.0	95.3	85.2	72.8	63.1	62.8	69.5	80.0	89.3	95.8	101.5
		MCWB	66.8	66.0	64.1	60.3	56.4	53.0	51.9	52.8	56.3	59.5	62.6	64.1
	5%	DB	100.1	96.1	90.8	81.0	68.7	60.6	60.1	65.0	74.3	84.1	91.2	96.1
		MCWB	65.2	65.3	63.7	58.9	55.4	52.1	51.2	51.3	54.6	57.3	61.5	62.8
	10%	DB	94.6	91.8	85.9	76.5	65.4	58.4	57.7	61.7	69.1	78.9	86.5	90.9
		MCWB	64.3	64.4	62.6	57.6	54.5	51.5	50.4	50.4	52.9	56.6	60.1	61.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.9	73.7	69.3	65.5	61.2	57.7	56.5	56.7	59.8	64.8	69.3	70.9
		MCDB	87.7	92.7	85.7	75.9	67.5	60.7	60.9	67.1	78.1	81.2	85.5	85.8
	2%	WB	70.5	70.9	67.5	62.9	58.8	55.4	54.0	54.6	57.6	62.0	66.6	68.0
		MCDB	87.7	87.9	83.6	76.3	67.6	59.9	59.3	65.1	74.0	79.7	81.8	83.1
	5%	WB	68.7	68.6	66.0	61.2	57.1	53.8	52.5	52.9	55.7	59.9	64.6	66.2
		MCDB	89.3	85.8	82.6	75.1	65.4	58.6	57.9	62.2	70.1	77.4	82.5	85.7
	10%	WB	66.8	66.6	64.2	59.4	55.7	52.4	51.1	51.5	54.0	58.0	62.3	64.2
		MCDB	89.7	85.6	82.6	73.5	63.6	57.2	56.4	59.9	66.7	75.2	81.2	86.0
Mean Daily Temperature Range	5% DB	MDBR	28.2	27.0	24.3	22.1	17.8	15.6	15.7	18.8	23.0	26.4	27.2	27.7
		MCDBR	32.9	30.7	27.6	26.4	20.8	17.8	18.1	23.4	29.7	32.1	32.1	32.0
		MCWBR	10.3	9.6	9.2	10.4	9.6	9.8	10.1	11.1	12.2	12.0	10.5	10.4
	5% WB	MCDBR	26.3	23.9	23.7	21.3	17.3	15.2	15.9	20.1	25.3	26.9	25.9	24.3
		MCWBR	10.8	9.2	9.7	9.6	9.3	9.4	9.9	10.8	11.7	11.2	10.5	10.5
Clear-Sky Solar Irradiance	taub	0.336	0.333	0.316	0.307	0.298	0.289	0.289	0.299	0.321	0.330	0.340	0.329	
	taud	2.508	2.534	2.572	2.570	2.575	2.595	2.593	2.550	2.482	2.471	2.475	2.520	
	Ebn at Noon	317	311	305	290	275	270	276	288	298	309	314	321	
	Edh at Noon	36	34	30	27	23	21	23	27	32	35	37	36	
All-Sky Solar Radiation	RadAvg	2497	2233	1826	1332	924	748	806	1113	1521	1976	2252	2481	
	RadStd	117	111	86	65	44	48	39	69	106	126	118	98	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+227	+146

Nomenclature: See separate page