

EDENHOPE, Australia

WMO: 958320

Lat: 37.0222S

Lon: 141.2658E

Elev: 509

StdP: 14.43

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	36.5	28.5	22.9	75.4	31.4	26.2	62.7	26.6	51.7	22.7	53.0	2.7	80	0.528

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.0	99.0	65.2	94.3	64.5	90.0	63.6	68.8	85.5	67.2	84.6	65.7	83.4	11.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	94.0	71.3	62.2	85.2	69.8	60.1	79.0	69.3	33.2	85.3	31.9	85.0	30.7	83.4	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.3	19.1	16.8	31.0	106.7	1.7	3.7	29.7	109.4	28.7	111.6	27.7	113.7	26.4	116.4		
(5)			30.6	71.9	1.8	2.1	29.4	73.4	28.3	74.6	27.3	75.8	26.1	77.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.3	69.7	69.2	65.3	59.0	53.4	48.9	48.3	49.5	52.4	56.9	61.8	65.5	(6)
(7)		DBStd	9.90	8.15	7.57	7.82	6.22	4.80	3.62	3.53	4.15	5.08	7.00	7.88	8.18	(7)
(8)		HDD50	253	0	0	0	2	18	63	75	59	25	10	1	0	(8)
(9)		HDD65	3108	34	36	93	202	361	484	516	480	378	272	158	94	(9)
(10)		CDD50	3271	611	537	475	272	123	29	24	44	98	223	355	480	(10)
(11)		CDD65	648	180	153	102	21	1	0	0	0	1	20	62	108	(11)
(12)		CDH74	9078	2651	1911	1285	236	5	0	0	1	15	313	926	1735	(12)
(13)		CDH80	4430	1448	940	578	63	0	0	0	0	0	105	410	886	(13)
(14)	Wind	WSAvg	8.0	8.9	8.6	7.9	6.9	7.3	6.4	8.1	8.0	8.1	8.4	8.5	8.7	(14)
(15)	Precipitation	PrecAvg	23.9	1.1	0.7	1.1	1.7	2.4	2.8	3.2	3.0	2.7	2.3	1.6	1.2	(15)
(16)		PrecMax	35.8	6.0	2.3	3.5	5.7	6.1	5.8	8.6	6.1	5.0	6.4	4.6	5.4	(16)
(17)		PrecMin	13.6	0.1	0.0	0.0	0.0	0.3	0.5	1.1	1.1	0.8	0.2	0.2	0.0	(17)
(18)		PrecStd	4.8	1.0	0.6	0.8	1.3	1.3	1.3	1.4	1.3	1.2	1.3	1.1	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.7	99.9	99.0	87.0	73.1	62.7	62.0	69.7	76.1	89.1	95.0	102.7	(19)
(20)			MCWB	67.6	66.9	64.6	62.0	57.6	53.5	53.3	55.4	59.0	61.7	64.9	64.8	(20)
(21)		2%	DB	100.3	95.1	91.7	80.4	68.2	59.6	58.5	64.6	70.7	82.2	89.9	96.4	(21)
(22)			MCWB	65.2	65.2	64.5	59.3	55.9	52.7	51.7	53.3	56.1	59.8	63.1	63.3	(22)
(23)		5%	DB	94.2	91.1	86.7	75.4	64.5	57.3	56.2	60.2	66.1	76.3	84.9	89.8	(23)
(24)			MCWB	64.8	65.0	62.4	58.0	55.4	52.2	50.9	51.8	54.3	58.0	62.0	62.1	(24)
(25)		10%	DB	88.1	85.7	81.0	70.8	61.4	55.5	54.5	57.0	62.4	71.1	78.5	83.8	(25)
(26)			MCWB	63.0	63.3	61.5	56.9	54.7	51.1	50.1	50.6	53.0	56.5	60.3	60.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	70.4	68.3	63.9	60.4	55.8	55.4	56.6	60.1	65.5	68.5	69.3	(27)
(28)			MCD B	86.8	89.3	83.1	80.1	66.9	59.0	58.1	65.2	72.0	80.1	85.3	85.4	(28)
(29)		2%	WB	69.2	67.9	66.3	61.8	58.4	54.1	53.5	54.5	57.5	61.7	66.1	66.1	(29)
(30)			MCD B	85.8	85.1	82.9	72.6	64.0	57.5	56.4	61.4	66.9	74.0	82.9	82.3	(30)
(31)		5%	WB	67.3	66.5	64.7	60.1	57.0	53.0	52.1	52.9	55.7	59.5	63.9	64.2	(31)
(32)			MCD B	85.8	84.0	80.7	70.1	62.1	56.2	54.9	58.6	63.9	72.7	78.2	83.5	(32)
(33)		10%	WB	65.3	65.0	63.1	58.4	55.5	51.9	50.8	51.4	53.8	57.6	61.7	62.4	(33)
(34)			MCD B	85.1	81.8	78.0	67.7	60.3	54.7	53.6	56.1	61.1	69.5	75.7	81.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	28.0	25.8	23.8	20.0	14.8	14.0	12.8	14.7	17.5	21.9	24.6	26.9	(35)
(36)			MCDBR	36.6	32.9	31.3	27.3	18.6	16.0	14.1	19.6	23.4	31.0	33.9	36.7	(36)
(37)			MCWBR	11.0	10.2	10.4	11.3	10.0	10.6	9.3	11.1	12.0	13.3	12.2	11.3	(37)
(38)		5% WB	MCDBR	28.7	27.0	25.4	20.8	15.0	13.7	12.3	16.5	20.0	25.9	28.4	28.8	(38)
(39)			MCWBR	11.2	10.0	10.5	10.0	9.2	9.7	8.9	10.4	11.2	12.8	11.6	10.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.331	0.316	0.308	0.301	0.298	0.295	0.306	0.326	0.334	0.334	0.333	(40)	
(41)		taud	2.502	2.528	2.568	2.573	2.571	2.570	2.575	2.527	2.461	2.443	2.479	2.498	(41)	
(42)		Ebn at Noon	317	311	304	287	270	261	269	283	295	306	315	319	(42)	
(43)		Edh at Noon	36	33	30	26	23	21	22	27	32	36	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2383	2090	1642	1151	770	626	675	952	1316	1749	2081	2322	(44)	
(45)		RadStd	134	102	73	71	39	47	37	52	102	136	139	130	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		+0.70	N/A	N/A	+1.62	N/A	N/A	N/A	-173	+238	+70

Nomenclature: See separate page