

KYABRAM, Australia

WMO: 958330

Lat: 36.3350S

Lon: 145.0639E

Elev: 344

StdP: 14.51

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.6	34.6	28.7	22.9	65.1	30.9	25.4	55.7	20.3	52.0	17.6	54.6	0.5	200	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.9	99.7	66.3	95.1	65.7	91.3	65.0	71.2	84.7	69.4	83.7	67.7	84.1	8.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.9	103.8	75.5	65.0	93.8	73.7	62.7	86.2	72.6	35.2	84.2	33.6	83.1	32.3	84.4	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.2	15.7	13.9	DB	28.2	107.3	1.6	3.1	27.0	109.5	26.0	111.3	25.1	113.0	23.9	115.3
			WB	27.9	74.3	1.7	1.9	26.7	75.7	25.7	76.8	24.7	77.8	23.5	79.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.9	73.7	72.4	68.1	60.6	53.4	48.6	47.5	48.8	52.9	58.6	65.3	69.5
	DBStd	10.96	7.40	6.67	6.62	5.72	4.43	3.83	3.61	3.99	5.06	6.33	7.32	7.19
	HDD50	277	0	0	0	2	16	70	94	71	21	3	0	0
	HDD65	2812	10	12	40	153	360	491	543	503	366	220	83	31
	CDD50	3883	734	627	561	321	121	29	16	34	108	268	458	606
	CDD65	945	279	220	137	23	0	0	0	2	21	91	172	
	CDH74	12039	3689	2516	1483	230	2	0	0	1	46	404	1330	2338
	CDH80	5705	2005	1216	600	40	0	0	0	0	11	131	576	1126
(14) Wind	WSAvg	6.0	7.4	6.8	6.2	4.8	4.6	5.2	5.7	5.9	6.4	6.9	7.2	
(15) Precipitation	PrecAvg	17.1	1.2	1.5	0.9	1.1	1.3	2.0	1.7	1.5	1.5	1.4	1.5	1.3
	PrecMax	28.3	4.1	5.7	3.7	3.2	3.4	5.1	3.7	3.4	4.1	4.1	3.5	4.2
	PrecMin	7.9	0.0	0.0	0.0	0.0	0.0	1.0	0.3	0.0	0.0	0.0	0.0	0.1
	PrecStd	5.0	1.3	1.5	0.8	0.8	1.0	1.0	0.9	0.9	1.1	1.3	1.1	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.6	103.5	97.3	84.3	72.6	63.2	62.0	67.9	79.2	90.1	97.0	102.6
		MCWB	67.3	68.9	65.8	62.1	58.1	54.7	54.3	55.5	57.5	61.5	64.0	65.4
	2%	DB	101.2	96.0	91.1	79.8	68.3	60.3	58.9	63.3	72.7	83.6	91.7	96.6
		MCWB	67.1	66.9	65.1	61.3	57.2	53.5	52.3	53.4	57.4	60.2	63.5	64.8
	5%	DB	95.7	91.8	86.7	76.3	65.1	58.1	56.7	60.3	67.9	78.3	86.9	91.3
		MCWB	66.5	66.4	64.1	59.7	56.0	52.3	51.4	52.0	56.2	58.8	62.1	63.8
	10%	DB	90.9	87.6	82.3	72.9	62.3	56.3	54.8	57.5	64.1	73.5	81.9	86.4
		MCWB	65.4	65.0	62.6	58.8	54.7	51.4	50.3	50.8	54.2	57.0	61.4	62.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	74.3	70.4	66.0	62.1	57.5	56.2	57.0	62.6	65.5	70.0	71.3
		MCDB	86.9	90.7	82.0	76.3	66.1	59.7	58.4	63.7	74.0	81.4	83.7	80.8
	2%	WB	71.0	71.4	68.2	63.5	58.9	55.2	53.8	54.8	59.6	62.7	66.8	68.8
		MCDB	87.5	83.6	82.7	73.4	64.5	58.3	57.1	60.9	68.0	75.0	81.5	81.6
	5%	WB	69.1	69.4	66.4	61.9	57.1	53.6	52.2	53.0	57.3	60.8	64.7	66.6
		MCDB	86.8	82.2	80.4	71.6	63.1	56.6	55.5	58.7	66.1	73.8	78.9	83.2
	10%	WB	67.3	67.3	64.7	60.2	55.6	52.2	50.8	51.4	55.1	58.8	62.9	64.8
		MCDB	86.6	83.0	79.0	70.7	61.2	55.3	54.0	56.6	63.1	71.2	77.2	82.9
(35) Mean Daily Temperature Range	5% DB	MDBR	27.9	25.8	24.1	22.4	19.0	16.4	15.6	18.1	21.9	25.1	26.3	27.1
		MCDBR	35.2	31.9	29.5	27.0	22.3	18.8	17.8	22.6	27.9	33.1	33.7	33.8
		MCWBR	9.6	9.3	9.5	11.4	12.2	12.4	11.9	13.6	14.4	13.3	11.1	9.9
	5% WB	MCDBR	27.7	25.5	23.8	21.8	18.4	14.6	15.2	19.4	24.1	26.5	25.8	26.1
		MCWBR	9.8	10.1	9.5	10.3	11.0	10.4	10.9	12.5	13.6	12.7	10.7	10.0
(40) Clear-Sky Solar Irradiance	taub		0.344	0.343	0.322	0.311	0.300	0.291	0.290	0.300	0.327	0.329	0.344	0.335
	taud		2.483	2.501	2.554	2.555	2.562	2.587	2.587	2.534	2.449	2.464	2.462	2.502
	Ebn at Noon		314	307	302	286	272	266	273	286	295	308	312	318
	Edh at Noon		36	35	30	27	23	21	22	27	33	35	37	36
(44) All-Sky Solar Radiation	RadAvg		2460	2178	1780	1275	871	670	725	1024	1446	1908	2212	2458
	RadStd		127	113	81	58	53	72	39	75	117	145	110	110

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.90	N/A	N/A	N/A	+1.80	N/A	N/A	-38	-212	+315	+133

Nomenclature: See separate page