

KYABRAM, Australia

WMO: 958330

Lat: 36.3350S

Lon: 145.0639E

Elev: 105

StdP: 100.07

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.3	1.5	-1.8	3.3	18.4	-0.6	3.6	13.2	9.1	11.1	7.9	12.5	0.2	200	0.459

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	37.6	19.0	35.1	18.7	33.0	18.3	21.8	29.3	20.8	28.7	19.9	28.9	3.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	14.8	24.2	18.3	13.4	23.2	17.0	12.3	22.6	63.9	29.0	60.4	28.4	57.1	29.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.0	6.2	DB	-2.1	41.8	0.9	1.7	-2.8	43.0	-3.3	44.0	-3.8	45.0	-4.5	46.3	(4)
(5)			WB	-2.3	23.5	0.9	1.0	-3.0	24.3	-3.5	24.9	-4.0	25.5	-4.7	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	23.2	22.4	20.1	15.9	11.9	9.2	8.6	9.3	11.6	14.8	18.5	20.9	(6)
(7)		DBStd	6.09	4.11	3.71	3.68	3.18	2.46	2.13	2.01	2.22	2.81	3.52	4.07	4.00	(7)
(8)		HDD10.0	154	0	0	0	1	9	39	52	39	12	2	0	0	(8)
(9)		HDD18.3	1562	6	7	22	85	200	273	302	279	203	122	46	17	(9)
(10)		CDD10.0	2157	408	348	312	178	67	16	9	19	60	149	254	337	(10)
(11)		CDD18.3	525	155	122	76	13	0	0	0	0	1	12	51	96	(11)
(12)		CDH23.3	6688	2049	1398	824	128	1	0	0	1	26	224	739	1299	(12)
(13)		CDH26.7	3169	1114	676	333	22	0	0	0	0	6	73	320	626	(13)
(14)	Wind	WSAvg	2.7	3.3	3.0	2.8	2.2	2.1	2.1	2.3	2.5	2.6	2.9	3.1	3.2	(14)
(15)	Precipitation	PrecAvg	435	30	39	24	28	34	52	43	38	39	36	38	34	(15)
(16)		PrecMax	719	103	146	94	82	86	130	94	86	105	104	89	107	(16)
(17)		PrecMin	200	0	0	0	0	1	25	7	0	1	0	1	3	(17)
(18)		PrecStd	127	32	38	21	20	26	25	22	23	27	32	27	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.0	39.7	36.3	29.1	22.6	17.3	16.6	20.0	26.2	32.3	36.1	39.2	(19)
(20)			MCWB	19.6	20.5	18.8	16.7	14.5	12.6	12.4	13.1	14.2	16.4	17.8	18.6	(20)
(21)		2%	DB	38.5	35.6	32.8	26.6	20.2	15.7	15.0	17.4	22.6	28.7	33.1	35.9	(21)
(22)			MCWB	19.5	19.4	18.4	16.3	14.0	11.9	11.3	11.9	14.1	15.7	17.5	18.2	(22)
(23)		5%	DB	35.4	33.2	30.4	24.6	18.4	14.5	13.7	15.7	20.0	25.7	30.5	32.9	(23)
(24)			MCWB	19.2	19.1	17.9	15.4	13.3	11.3	10.8	11.1	13.4	14.9	16.7	17.7	(24)
(25)		10%	DB	32.7	30.9	28.0	22.7	16.9	13.5	12.7	14.2	17.8	23.1	27.7	30.2	(25)
(26)			MCWB	18.6	18.3	17.0	14.9	12.6	10.8	10.2	10.5	12.3	13.9	16.3	17.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.5	21.3	18.9	16.7	14.1	13.5	13.9	17.0	18.6	21.1	21.8	(27)
(28)			MCDWB	30.5	32.6	27.8	24.6	19.0	15.4	14.7	17.6	23.3	27.4	28.7	27.1	(28)
(29)		2%	WB	21.7	21.9	20.1	17.5	14.9	12.9	12.1	12.7	15.3	17.1	19.3	20.4	(29)
(30)			MCDWB	30.9	28.6	28.2	23.0	18.1	14.6	13.9	16.1	20.0	23.9	27.5	27.5	(30)
(31)		5%	WB	20.6	20.8	19.1	16.6	13.9	12.0	11.2	11.7	14.0	16.0	18.2	19.2	(31)
(32)			MCDWB	30.5	27.9	26.9	22.0	17.3	13.7	13.0	14.8	19.0	23.2	26.1	28.4	(32)
(33)		10%	WB	19.6	19.6	18.1	15.7	13.1	11.2	10.4	10.8	12.8	14.9	17.2	18.2	(33)
(34)			MCDWB	30.3	28.3	26.1	21.5	16.2	12.9	12.2	13.7	17.3	21.8	25.1	28.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.5	14.4	13.4	12.4	10.6	9.1	8.7	10.0	12.1	13.9	14.6	15.1	(35)
(36)			MCDBR	19.5	17.7	16.4	15.0	12.4	10.4	9.9	12.5	15.5	18.4	18.7	18.8	(36)
(37)			MCWBR	5.3	5.2	5.3	6.3	6.8	6.9	6.6	7.6	8.0	7.4	6.2	5.5	(37)
(38)		5% WB	MCDWB	15.4	14.2	13.2	12.1	10.2	8.1	8.4	10.8	13.4	14.7	14.3	14.5	(38)
(39)			MCWBR	5.5	5.6	5.3	5.7	6.1	5.8	6.1	6.9	7.5	7.0	5.9	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.343	0.322	0.311	0.300	0.291	0.290	0.300	0.327	0.329	0.344	0.335	(40)	
(41)		taud	2.483	2.501	2.554	2.555	2.562	2.587	2.587	2.534	2.449	2.464	2.462	2.502	(41)	
(42)		Ebn at Noon	990	969	952	903	856	838	861	902	930	971	984	1003	(42)	
(43)		Edh at Noon	115	109	95	84	72	66	70	84	104	111	117	114	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.75	6.87	5.61	4.02	2.75	2.11	2.29	3.23	4.56	6.01	6.97	7.75	(44)	
(45)		RadStd	0.40	0.36	0.26	0.18	0.17	0.23	0.12	0.24	0.37	0.46	0.35	0.35	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (29 neighbors)	+0.50	N/A	N/A	+1.00	N/A	N/A	-21	-118	+175	+74	(47)

Nomenclature: See separate page