

HORSHAM, AustraliaWMO: **958390**Lat: **36.6697S**Lon: **142.1731E**Elev: **441**StdP: **14.46**Time Zone: **10.00 (AUS)**Period: **01-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.2	33.2	23.0	17.6	76.7	26.7	21.0	67.2	29.1	53.5	26.8	53.8	6.0	80	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.1	100.3	64.9	95.9	63.9	91.8	63.1	69.4	84.8	67.5	84.2	65.8	83.7	15.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	96.2	72.0	62.7	86.7	71.1	60.1	78.8	70.0	33.7	85.2	32.2	83.1	30.8	83.5	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	27.7	24.6	22.1	27.1	109.1	1.6	3.2	26.0	111.4	25.1	113.3	24.2	115.0	23.0	117.3	
(5)				26.7	72.6	1.5	2.3	25.5	74.2	24.6	75.6	23.8	76.9	22.6	78.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.0	70.7	69.8	65.4	58.8	52.4	48.1	47.1	48.0	51.2	56.2	62.5	66.9	(6)
(7)		DBStd	10.40	7.85	7.28	7.13	5.84	4.57	3.59	3.49	3.95	4.82	6.68	7.74	7.84	(7)
(8)		HDD50	344	0	0	0	3	24	78	101	88	38	11	1	0	(8)
(9)		HDD65	3234	26	28	84	203	389	508	554	528	415	288	142	69	(9)
(10)		CDD50	3274	641	556	476	267	100	20	12	25	74	204	376	523	(10)
(11)		CDD65	686	202	164	95	17	0	0	0	0	1	15	66	126	(11)
(12)		CDH74	11332	3219	2382	1421	331	12	0	0	1	40	445	1241	2240	(12)
(13)		CDH80	5677	1787	1215	641	94	0	0	0	0	4	167	580	1189	(13)
(14)	Wind	WSAvg	11.5	12.5	12.1	11.5	10.3	10.5	10.3	11.2	11.2	12.0	12.4	12.8	(14)	
(15)	Precipitation	PrecAvg	17.4	1.0	0.8	0.8	1.1	1.8	1.8	2.0	2.0	1.8	1.4	0.9	(15)	
(16)		PrecMax	30.0	3.5	4.4	2.4	4.1	4.9	5.7	4.4	3.9	4.2	7.2	3.6	3.1	(16)
(17)		PrecMin	7.2	0.0	0.0	0.0	0.0	0.3	0.2	0.6	0.3	0.4	0.2	0.2	0.0	(17)
(18)		PrecStd	4.5	0.9	0.8	0.6	1.0	1.1	1.1	1.0	0.9	1.1	1.3	0.9	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.0	103.2	99.0	88.8	75.3	63.8	62.6	70.2	79.1	91.5	97.9	105.0	(19)
(20)		0.4%	MCWB	66.9	68.3	64.0	61.4	56.5	53.2	52.5	54.7	57.0	60.1	63.4	63.9	(20)
(21)		2%	DB	101.8	96.9	92.2	82.1	69.7	60.4	59.1	64.1	72.2	84.8	92.2	98.3	(21)
(22)		2%	MCWB	65.3	65.3	63.8	59.6	55.5	52.4	51.7	52.8	56.3	58.4	61.7	63.6	(22)
(23)		5%	DB	95.5	92.6	87.3	77.6	65.5	58.3	56.8	60.0	67.0	78.7	87.4	92.3	(23)
(24)		5%	MCWB	64.1	64.5	62.2	58.4	54.8	51.9	50.7	51.5	54.2	57.4	60.9	61.8	(24)
(25)		10%	DB	90.0	87.8	82.1	72.9	62.3	56.3	54.8	57.2	62.6	72.7	81.4	86.5	(25)
(26)		10%	MCWB	63.0	63.0	61.3	56.9	54.1	51.0	49.8	50.3	53.0	55.9	59.3	60.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.7	72.6	68.3	63.8	60.3	56.3	54.9	56.7	60.7	64.4	68.3	70.2	(27)
(28)		0.4%	MCDWB	86.5	91.7	83.0	76.7	66.0	60.0	58.9	64.8	71.0	76.9	84.4	81.7	(28)
(29)		2%	WB	69.3	69.5	66.4	61.9	58.2	54.3	53.1	54.2	57.8	61.3	65.7	66.6	(29)
(30)		2%	MCDWB	85.7	84.7	81.6	74.3	65.1	58.3	57.0	61.5	67.8	75.1	82.3	82.5	(30)
(31)		5%	WB	67.3	67.3	64.4	60.0	56.6	52.9	51.8	52.5	55.6	59.0	63.5	64.6	(31)
(32)		5%	MCDWB	86.8	83.3	81.1	72.4	63.2	56.8	55.4	58.5	65.0	74.4	78.2	84.8	(32)
(33)		10%	WB	65.2	65.2	62.6	58.3	55.0	51.7	50.5	51.0	53.6	57.0	61.2	62.6	(33)
(34)		10%	MCDWB	86.2	82.8	79.8	70.1	61.0	55.2	54.1	56.3	61.8	71.0	77.1	83.1	(34)
(35)	Mean Daily Temperature Range		MDBR	31.1	29.8	27.9	25.8	20.5	17.7	16.8	19.8	23.3	27.9	29.5	30.4	(35)
(36)		5% DB	MCDBR	39.2	36.4	35.1	32.9	25.7	20.4	18.8	24.4	31.2	39.1	38.9	39.7	(36)
(37)		5% DB	MCWBR	13.1	12.2	13.4	14.9	14.8	13.6	12.5	15.2	16.9	17.1	13.8	13.3	(37)
(38)		5% WB	MCDBR	29.7	28.4	29.3	26.4	20.1	17.5	16.2	21.5	26.1	32.0	31.2	30.0	(38)
(39)		5% WB	MCWBR	12.4	11.0	12.6	13.0	12.4	12.3	11.7	14.1	15.6	15.9	12.8	12.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.338	0.333	0.316	0.309	0.300	0.292	0.292	0.304	0.322	0.331	0.337	0.330	(40)	
(41)		taud	2.497	2.520	2.566	2.566	2.577	2.593	2.592	2.535	2.473	2.457	2.473	2.512	(41)	
(42)		Ebn at Noon	316	310	304	287	271	265	272	284	296	307	314	320	(42)	
(43)		Edh at Noon	36	34	30	26	23	21	22	26	32	36	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2440	2168	1719	1218	820	655	705	993	1374	1831	2161	2395	(44)	
(45)		RadStd	126	103	78	65	39	49	42	62	99	131	137	115	(45)	