

WESTMERE, Australia

WMO: 958400

Lat: 37.7067S

Lon: 142.9378E

Elev: 227

StdP: 98.63

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.1	1.1	-1.6	3.4	11.2	-0.2	3.8	7.8	13.2	11.2	12.0	10.9	1.2	20	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.2	35.9	18.3	33.1	17.7	30.6	17.2	20.3	28.3	19.4	27.6	18.5	27.0	6.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.6	21.7	17.1	12.6	20.8	16.0	11.7	20.0	59.5	28.6	56.1	27.5	53.2	27.1	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.7	8.7	-2.2	40.9	1.1	2.3	-2.9	42.6	-3.6	43.9	-4.2	45.2	-5.0	46.9		
(5)			-2.3	22.1	1.1	1.4	-3.1	23.1	-3.7	23.9	-4.4	24.7	-5.2	25.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.3	19.3	19.0	17.0	14.0	11.1	8.6	8.2	8.5	9.8	12.0	14.9	17.1	(6)
	DBStd	5.10	4.24	3.73	3.90	3.00	2.50	1.85	1.81	2.05	2.50	3.50	4.05	4.03	(7)
	HDD10.0	237	0	0	1	3	16	50	59	56	33	15	3	0	(8)
	HDD18.3	2069	37	34	74	136	226	293	313	305	256	200	121	74	(9)
	CDD10.0	1423	288	252	217	122	49	8	4	9	27	77	149	221	(10)
	CDD18.3	214	67	53	33	4	0	0	0	0	0	3	18	36	(11)
	CDH23.3	3562	1102	733	483	77	1	0	0	0	3	118	358	687	(12)
	CDH26.7	1672	596	342	206	15	0	0	0	0	0	34	144	335	(13)
(14) Wind	WSAvg	4.2	4.4	4.4	4.2	3.8	4.2	3.8	4.7	4.5	4.1	4.0	4.0	4.2	(14)
(15) Precipitation	PrecAvg	536	36	37	26	39	41	51	53	62	55	50	49	37	(15)
	PrecMax	770	132	99	51	94	91	93	86	139	136	96	90	109	(16)
	PrecMin	355	0	3	6	3	6	19	23	21	23	6	18	1	(17)
	PrecStd	103	30	24	14	23	21	19	15	29	25	28	20	25	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.9	37.0	36.5	28.7	21.5	15.3	15.0	18.2	22.6	30.4	34.0	38.3	(19)
		MCWB	19.2	18.1	18.0	15.9	13.7	11.6	11.9	13.1	14.8	16.2	17.7	17.9	(20)
	2%	DB	36.6	33.7	31.7	25.4	19.0	14.1	13.5	15.6	19.4	26.8	30.6	34.1	(21)
		MCWB	18.4	18.3	17.8	14.8	13.2	11.2	10.7	11.5	13.7	15.5	17.1	17.1	(22)
	5%	DB	33.2	31.0	28.5	23.2	17.2	13.2	12.5	14.0	17.1	23.3	27.8	30.4	(23)
		MCWB	17.7	17.8	16.8	14.1	12.8	10.9	10.1	10.7	12.7	14.8	16.6	16.5	(24)
	10%	DB	29.4	28.0	25.6	20.9	15.6	12.3	11.5	12.5	15.1	20.1	24.3	27.0	(25)
		MCWB	17.2	17.4	16.2	13.5	12.2	10.5	9.5	10.0	11.7	13.8	15.8	16.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	21.7	19.6	17.5	15.3	12.7	12.6	13.6	15.6	18.2	20.2	21.1	(27)
		MCDB	30.7	30.6	27.4	24.8	17.8	13.8	14.1	17.5	20.7	24.6	28.7	27.0	(28)
	2%	WB	20.3	20.1	18.6	16.1	14.2	11.9	11.4	12.0	14.2	16.6	18.9	19.2	(29)
		MCDB	29.6	26.8	27.1	20.7	17.5	13.3	12.9	14.6	18.4	23.4	26.1	27.4	(30)
	5%	WB	19.2	19.1	17.8	15.2	13.3	11.3	10.5	11.1	13.0	15.2	17.7	18.0	(31)
		MCDB	28.8	27.3	25.9	20.0	16.3	12.7	11.9	13.1	16.4	21.8	24.6	26.4	(32)
	10%	WB	18.1	18.0	17.0	14.4	12.5	10.7	9.8	10.3	12.0	14.1	16.4	16.8	(33)
		MCDB	27.8	26.1	23.3	19.1	15.2	12.0	11.1	12.1	14.9	19.9	23.1	25.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.2	14.5	13.2	11.7	8.2	7.3	6.7	7.8	9.9	13.2	14.0	15.4	(35)
		MCDBR	23.2	20.4	18.7	17.0	10.8	8.9	7.6	10.0	13.4	20.0	21.1	22.8	(36)
	5% WB	MCWBR	7.2	7.0	6.8	7.8	6.2	6.5	5.4	6.6	8.4	10.0	8.7	8.0	(37)
		MCWBR	16.9	16.4	14.9	12.7	8.8	7.7	6.8	9.1	12.3	16.7	16.6	17.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.342	0.335	0.319	0.309	0.299	0.290	0.289	0.301	0.329	0.331	0.336	0.330	(40)
		taud	2.471	2.509	2.551	2.558	2.564	2.580	2.581	2.528	2.431	2.437	2.457	2.501	(41)
	Ebn at Noon		991	974	951	899	848	828	853	894	923	967	990	1007	(42)
		Edh at Noon	116	107	95	82	71	64	68	83	105	114	117	114	(43)
(44) All-Sky Solar Radiation	RadAvg		7.29	6.34	4.98	3.45	2.30	1.83	2.01	2.85	4.00	5.33	6.30	7.10	(44)
	RadStd		0.44	0.32	0.27	0.23	0.11	0.14	0.13	0.17	0.27	0.45	0.42	0.42	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (38 neighbors)	+0.48	N/A	N/A	+0.88	+0.41	N/A	N/A	-125	+167	+54

Nomenclature: See separate page