

YARRAM, Australia

WMO: 958900

Lat: 38.5647S

Lon: 146.7478E

Elev: 19

StdP: 101.10

Time Zone: 10.00 (AUS)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.2	1.5	-0.3	3.7	1.3	0.9	4.0	3.5	14.1	12.0	12.9	11.4	1.2	0	0.571

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	32.3	19.6	29.4	19.2	26.9	18.9	21.6	27.2	20.7	26.0	19.9	24.7	6.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.8	22.8	19.2	14.0	22.2	18.4	13.3	21.7	63.1	26.5	59.9	26.5	57.1	24.7	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.0	10.0	DB	-2.2	39.4	1.0	2.9	-2.9	41.5	-3.5	43.1	-4.0	44.7	-4.7	46.8	(4)
(5)			WB	-2.3	24.6	1.0	1.3	-3.0	25.6	-3.6	26.3	-4.2	27.0	-4.9	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	18.6	18.6	17.3	14.6	11.9	9.8	9.4	9.8	11.3	13.1	15.1	16.7	(6)	
	DBStd	4.34	3.72	3.01	3.08	2.63	2.25	2.04	2.17	2.07	2.49	3.07	3.28	3.42	(7)	
	HDD10.0	118	0	0	0	1	7	29	37	29	12	3	1	0	(8)	
	HDD18.3	1806	40	29	59	116	200	257	276	265	212	167	111	74	(9)	
	CDD10.0	1512	268	241	226	138	66	22	19	23	51	99	152	208	(10)	
	CDD18.3	159	49	37	27	4	1	0	0	0	1	4	12	24	(11)	
	CDH23.3	1614	517	268	224	53	2	0	0	0	8	99	158	284	(12)	
	CDH26.7	613	240	88	71	12	0	0	0	0	0	27	56	119	(13)	
(14) Wind	WSAvg	4.5	4.7	4.6	4.4	3.8	4.3	3.8	4.7	4.7	4.8	4.8	4.9	4.8	(14)	
(15) Precipitation	PrecAvg	861	59	60	54	76	58	91	78	84	86	75	78	66	(15)	
	PrecMax	1111	161	142	142	197	159	227	181	184	256	149	201	156	(16)	
	PrecMin	595	11	6	17	26	18	20	21	28	25	15	19	21	(17)	
	PrecStd	153	33	32	28	45	34	49	35	36	44	34	45	40	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.4	33.2	32.3	28.5	23.1	17.8	18.5	19.8	24.5	29.7	31.9	35.7	(19)	
		MCWB	20.4	20.4	19.4	16.7	14.8	12.5	11.8	12.8	14.6	17.2	18.3	19.9	(20)	
	2%	DB	32.7	29.1	28.6	24.5	20.3	16.3	16.3	17.3	21.2	26.2	28.2	29.9	(21)	
		MCWB	20.1	20.0	18.8	16.5	14.2	12.5	11.4	12.3	14.3	16.3	18.1	19.2	(22)	
	5%	DB	28.8	26.4	25.7	22.0	18.3	15.2	14.8	15.6	18.7	22.9	24.3	26.0	(23)	
		MCWB	20.2	19.7	18.5	16.2	13.6	12.1	10.6	11.1	13.1	15.4	17.4	19.0	(24)	
	10%	DB	25.3	24.2	23.2	19.9	16.5	14.2	13.7	14.2	16.6	20.0	21.6	23.2	(25)	
		MCWB	18.8	18.7	17.8	15.8	12.9	11.5	10.3	10.5	12.4	14.8	16.6	17.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	22.5	21.9	19.4	16.4	14.9	13.3	14.0	16.2	19.1	20.7	22.3	(27)	
		MCDB	31.3	27.9	25.6	24.3	19.9	15.6	16.4	17.8	21.6	24.6	25.9	29.0	(28)	
	2%	WB	21.5	21.2	20.4	17.7	14.9	13.4	11.9	12.8	14.8	17.3	19.3	20.6	(29)	
		MCDB	27.8	26.3	25.0	21.6	17.9	15.0	15.0	16.1	19.1	23.8	25.2	26.0	(30)	
	5%	WB	20.6	20.4	19.5	16.9	14.0	12.5	11.2	11.7	13.7	16.0	18.0	19.3	(31)	
		MCDB	26.6	24.6	23.9	20.5	17.0	14.6	13.9	14.7	17.9	21.7	22.8	24.0	(32)	
	10%	WB	19.6	19.5	18.6	16.2	13.2	11.7	10.6	10.9	12.7	14.9	16.9	18.3	(33)	
		MCDB	25.0	23.1	22.8	19.3	16.0	13.9	13.1	13.5	16.1	19.4	21.0	22.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	10.5	10.5	10.4	9.4	9.1	8.6	8.8	10.0	11.4	11.1	11.0	(35)	
		MCDBR	17.4	14.5	15.1	14.6	13.0	10.7	10.7	11.5	14.6	17.4	16.7	17.1	(36)	
	5% WB	MCWBR	7.2	6.7	7.2	7.7	8.2	7.5	6.8	7.2	8.4	9.1	8.3	7.8	(37)	
		MCWBR	14.3	11.5	12.4	12.2	11.4	9.8	9.0	10.3	12.8	15.4	13.9	13.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.374	0.366	0.341	0.335	0.317	0.304	0.310	0.317	0.345	0.346	0.351	0.360	(40)	
		taud	2.447	2.490	2.556	2.546	2.574	2.598	2.571	2.549	2.466	2.483	2.495	2.478	(41)	
	Ebn at Noon		958	941	926	865	822	805	821	873	904	950	974	976	(42)	
		Edh at Noon	119	109	94	83	70	63	69	81	101	108	112	116	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.83	5.86	4.67	3.29	2.23	1.79	2.04	2.85	4.00	5.27	6.17	6.86	(44)	
	RadStd		0.43	0.33	0.28	0.18	0.11	0.12	0.10	0.10	0.26	0.34	0.36	0.41	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.50	N/A	N/A	+0.79	N/A	N/A	-16	-132	+173

Nomenclature: See separate page