

ALBURY, Australia

WMO: 958960

Lat: 36.0689S

Lon: 146.9508E

Elev: 165

StdP: 99.36

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.1	0.9	-2.9	3.0	17.5	-1.3	3.5	10.9	9.2	10.4	8.3	10.7	0.7	330	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.7	37.3	19.3	35.0	19.0	33.1	18.4	21.9	29.3	21.0	29.2	20.3	28.7	4.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.1	23.4	18.8	13.9	23.3	17.6	12.9	22.9	64.9	28.6	61.7	29.1	58.9	28.4	33.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.7	7.5	6.6	-1.8	40.7	0.8	2.0	-2.4	42.1	-2.9	43.2	-3.3	44.3	-3.9	45.7		
			-2.2	24.4	0.9	2.7	-2.8	26.3	-3.3	27.9	-3.8	29.4	-4.4	31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	24.5	23.7	20.4	15.5	11.5	8.8	8.1	9.1	11.7	14.9	18.8	21.6
	DBStd	6.46	3.77	3.49	3.45	2.96	2.56	2.14	1.96	2.12	2.55	3.16	3.69	3.71
	HDD10.0	181	0	0	0	1	13	48	63	43	10	1	0	0
	HDD18.3	1579	2	3	19	92	213	286	316	286	199	114	38	11
	CDD10.0	2255	451	385	323	167	59	12	6	16	61	154	263	360
	CDD18.3	612	194	154	83	8	0	0	0	0	8	51	113	
	CDH23.3	7466	2424	1737	903	115	2	0	0	9	167	669	1439	
	CDH26.7	3483	1297	846	347	19	0	0	0	1	42	263	669	
Wind	WSAvg	2.4	3.0	2.6	2.4	1.8	1.7	1.7	2.0	2.2	2.6	2.6	3.0	3.1
Precipitation	PrecAvg	722	54	38	40	46	60	75	85	87	70	70	50	51
	PrecMax	962	180	109	122	154	172	170	193	164	132	190	97	123
	PrecMin	415	7	1	1	6	4	8	20	18	24	8	11	10
	PrecStd	146	52	32	33	43	45	37	44	41	30	45	27	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.1	39.1	35.6	29.1	22.7	17.6	16.3	19.9	24.5	30.9	35.2	38.5
		MCWB	20.4	19.9	18.7	16.9	14.7	12.5	11.8	13.8	14.9	16.1	18.4	18.3
	2%	DB	38.1	36.0	32.5	26.2	20.1	15.9	14.8	17.4	22.0	27.4	32.2	35.4
		MCWB	19.7	19.6	18.5	16.3	14.0	11.7	10.9	12.0	14.9	15.9	17.5	18.4
	5%	DB	35.5	33.8	30.2	24.3	18.4	14.6	13.5	15.8	19.9	25.0	29.7	32.8
		MCWB	19.2	19.1	17.7	15.5	13.2	11.0	10.2	11.1	13.7	15.4	17.0	17.7
	10%	DB	33.2	31.8	28.3	22.5	16.9	13.4	12.3	14.2	18.0	22.6	27.2	30.4
		MCWB	18.8	18.6	17.0	14.7	12.7	10.6	9.5	10.3	12.6	14.6	16.5	17.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	25.1	21.9	19.1	16.7	14.1	13.2	14.4	16.7	19.2	21.3	21.7
		MCDB	31.7	30.1	27.4	24.8	18.6	15.6	14.7	17.9	21.5	25.6	29.1	28.7
	2%	WB	21.7	22.1	20.4	17.6	15.2	12.7	11.6	12.9	15.6	17.7	19.7	20.4
		MCDB	31.0	28.1	26.9	23.1	18.5	14.5	13.6	16.5	20.2	23.5	27.2	28.0
	5%	WB	21.0	21.1	19.3	16.5	14.1	11.8	10.7	11.6	14.5	16.6	18.7	19.4
		MCDB	30.7	28.2	26.7	22.0	17.3	13.8	12.7	14.9	18.8	22.3	25.6	28.0
	10%	WB	20.2	20.1	18.4	15.6	13.1	10.9	9.9	10.6	13.2	15.5	17.7	18.5
		MCDB	29.7	28.5	25.7	21.1	16.2	13.0	11.9	13.7	17.2	21.3	24.4	27.6
Mean Daily Temperature Range	5% DB	MDBR	14.7	13.9	13.7	13.2	11.1	9.6	9.0	10.4	11.7	13.1	13.7	14.6
		MCDBR	18.1	16.9	16.4	15.9	13.2	11.8	11.0	13.3	14.8	17.5	17.9	18.1
		MCWBR	5.0	5.4	5.9	7.1	7.3	7.6	7.2	8.2	8.1	7.8	6.2	5.6
	5% WB	MCDBR	14.3	12.9	13.0	13.3	10.9	9.6	9.2	11.6	12.8	13.6	13.7	14.2
	MCWBR	5.0	5.5	5.9	6.5	6.5	6.6	6.4	7.4	7.5	7.1	5.8	5.7	
Clear-Sky Solar Irradiance	taub	0.364	0.351	0.321	0.315	0.302	0.291	0.288	0.298	0.329	0.329	0.346	0.349	
	taud	2.432	2.494	2.576	2.545	2.556	2.593	2.602	2.555	2.454	2.481	2.471	2.471	
	Ebn at Noon	970	960	954	899	855	840	865	907	929	972	982	990	
	Edh at Noon	121	110	94	85	73	66	69	82	104	110	116	118	
All-Sky Solar Radiation	RadAvg	7.62	6.64	5.55	4.02	2.75	2.09	2.26	3.15	4.52	5.98	6.90	7.65	
	RadStd	0.44	0.44	0.33	0.21	0.19	0.24	0.14	0.27	0.46	0.52	0.40	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.50	N/A	N/A	+1.32	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	N/A

Nomenclature: See separate page