

THREDBO, Australia

WMO: 959090

Lat: 36.4917S

Lon: 148.2858E

Elev: 4488

StdP: 12.46

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	20.4	-5.3	4.9	34.8	-0.2	6.4	34.1	57.1	29.8	53.4	29.1	13.1	310	0.916

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.6	69.8	54.7	66.7	53.3	64.2	52.1	57.7	64.3	56.1	62.7	54.6	61.1	16.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.6	77.7	59.1	53.5	72.0	57.8	51.8	67.5	56.7	26.8	64.6	25.7	62.8	24.6	61.2	66.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 49.0	43.6	38.7	DB	15.7	74.2	1.5	3.0	14.6	76.4	13.7	78.2	12.9	79.9	11.8	82.1	(4)
(5)			WB	14.5	60.3	1.3	1.9	13.6	61.6	12.8	62.7	12.1	63.8	11.2	65.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.3	53.5	51.9	47.9	41.9	35.3	30.6	28.0	28.7	33.4	38.8	44.9	49.0
	DBStd	10.65	7.32	6.57	6.35	5.62	5.30	4.63	3.69	4.44	5.48	7.13	7.58	7.09
	HDD50	3977	49	51	113	247	456	582	683	661	497	350	186	102
	HDD65	9032	358	369	530	692	921	1032	1148	1126	947	811	602	496
	CDD50	424	159	103	49	4	0	0	0	0	0	4	33	72
	CDD65	4	3	1	0	0	0	0	0	0	0	0	0	0
	CDH74	12	9	3	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.7	14.7	13.7	14.4	14.9	17.9	16.4	20.9	18.9	19.7	17.7	15.4	15.8
Precipitation	PrecAvg	72.6	4.3	3.4	4.3	4.3	6.3	6.7	5.6	7.3	8.3	8.0	6.1	4.6
	PrecMax	104.6	10.6	10.7	11.9	12.0	13.5	19.5	12.8	15.0	14.8	15.6	13.6	8.5
	PrecMin	47.9	0.9	0.3	0.4	0.3	0.4	1.6	1.2	1.9	2.6	0.9	1.4	0.3
	PrecStd	18.7	2.4	2.2	2.7	2.8	3.2	3.5	3.2	3.4	3.6	3.9	2.8	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.0	73.1	67.7	58.5	51.5	46.4	40.2	43.2	49.4	59.4	67.1	70.8
		MCWB	57.4	57.6	52.7	47.2	40.8	34.1	34.7	34.8	40.9	46.2	51.9	53.5
	2%	DB	71.1	67.6	63.8	55.5	48.1	42.2	37.4	40.0	46.2	55.4	62.9	66.5
		MCWB	55.6	54.2	51.2	45.6	39.8	34.3	32.3	33.9	38.9	44.8	50.4	52.5
	5%	DB	67.7	64.7	60.5	52.9	45.7	39.8	35.2	37.7	43.8	52.6	59.8	63.1
		MCWB	54.1	52.8	49.8	44.4	38.5	34.1	31.3	33.0	38.4	43.4	48.3	50.8
	10%	DB	65.0	62.1	57.9	50.4	43.1	37.6	33.6	35.7	41.9	50.0	56.8	60.3
		MCWB	52.9	51.8	48.9	43.3	36.7	33.0	30.4	31.8	37.5	42.6	46.9	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.4	60.4	56.9	51.6	46.6	40.8	38.4	38.7	43.3	49.6	54.9	56.7
		MCDB	68.5	67.3	60.1	54.4	47.8	41.1	39.0	40.1	45.9	53.6	62.4	62.8
	2%	WB	58.1	57.5	54.2	48.8	42.6	38.1	35.2	36.4	41.7	47.4	52.5	54.5
		MCDB	66.2	63.1	59.5	53.0	45.1	39.2	35.7	38.0	43.9	51.8	59.1	61.8
	5%	WB	56.6	55.7	52.5	46.7	40.6	36.2	33.3	34.5	40.1	45.5	50.6	52.9
		MCDB	64.2	61.2	57.7	50.2	43.0	37.5	34.0	36.3	42.7	50.3	56.9	60.2
	10%	WB	55.0	54.0	50.7	45.1	38.9	34.4	31.7	32.7	38.2	43.7	48.8	51.2
		MCDB	62.5	59.5	55.5	48.4	41.4	36.2	32.5	34.4	41.1	48.5	54.8	58.3
Mean Daily Temperature Range	5% DB	MDBR	14.6	14.0	13.2	11.3	9.1	7.4	6.6	7.6	8.9	11.8	13.5	14.5
		MCDBR	16.9	16.0	15.8	14.2	13.3	11.3	9.1	10.0	11.1	15.1	16.0	16.9
		MCWBR	9.5	9.2	10.4	10.2	9.5	8.9	8.0	8.5	9.0	10.8	10.2	9.9
	5% WB	MCDBR	15.0	13.5	13.4	11.1	10.3	8.3	7.0	8.4	9.4	13.1	14.0	15.0
		MCWBR	9.7	9.0	9.8	9.0	8.6	8.0	7.3	8.1	8.5	10.3	9.8	9.7
Clear-Sky Solar Irradiance	taub	0.361	0.313	0.282	0.273	0.259	0.248	0.245	0.253	0.278	0.289	0.299	0.305	
	taud	2.382	2.576	2.682	2.663	2.666	2.715	2.727	2.688	2.593	2.586	2.592	2.579	
	Ebn at Noon	309	318	317	302	289	285	293	305	313	322	327	328	
	Edh at Noon	40	32	27	24	20	18	19	23	29	31	33	34	
All-Sky Solar Radiation	RadAvg	2293	1954	1656	1210	855	653	720	997	1420	1839	2089	2324	
	RadStd	164	171	135	91	42	54	41	63	123	151	150	125	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.76	N/A	N/A	+1.76	N/A	N/A	N/A	N/A	+218	+103

Nomenclature: See separate page