

MOUNT MOORNAPA, Australia

WMO: 959130

Lat: 37.7481S

Lon: 147.1428E

Elev: 1575

StdP: 13.88

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.3	38.8	26.3	21.4	55.9	28.9	24.3	50.9	20.8	51.1	18.0	49.8	8.0	0	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.5	91.3	64.5	86.2	63.8	82.0	63.1	69.7	80.3	67.6	78.3	65.8	76.1	7.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	104.5	72.9	64.5	96.4	70.4	62.6	90.1	69.0	34.7	80.2	33.0	78.5	31.5	75.9	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.8	14.4	12.8	DB	35.1	100.9	0.9	5.0	34.4	104.5	33.8	107.5	33.3	110.3	32.6	113.9
			WB	32.7	72.8	1.0	2.6	32.0	74.6	31.4	76.1	30.8	77.6	30.1	79.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.3	66.2	65.3	62.5	57.0	52.5	48.2	47.3	48.7	52.1	55.3	59.2	62.2	(6)
	DBStd	8.97	8.01	7.34	7.19	5.88	4.88	3.91	3.68	4.53	5.60	6.90	7.59	7.50	(7)
	HDD50	354	0	0	0	7	26	79	102	79	36	19	5	1	(8)
	HDD65	3554	79	79	137	252	388	503	550	504	390	314	211	147	(9)
	CDD50	2663	502	428	388	216	104	26	17	40	98	184	281	379	(10)
	CDD65	385	116	87	60	10	0	0	0	0	2	14	36	60	(11)
	CDH74	3566	1193	736	459	48	0	0	0	0	15	136	350	629	(12)
	CDH80	1387	539	281	155	10	0	0	0	0	2	32	116	252	(13)
(14) Wind	WSAvg	5.9	5.2	5.1	5.1	5.4	6.1	5.9	6.9	6.8	6.5	6.3	5.6	5.5	(14)
(15) Precipitation	PrecAvg	31.5	2.2	2.8	2.4	2.7	1.9	3.4	2.1	2.3	2.3	3.1	3.4	2.8	(15)
	PrecMax	42.2	8.5	6.3	7.4	7.0	4.2	12.6	7.2	4.7	4.8	6.5	7.0	7.2	(16)
	PrecMin	20.2	0.2	0.6	0.6	0.8	0.6	0.7	0.3	0.7	0.9	0.6	0.7	0.8	(17)
	PrecStd	5.9	1.9	1.8	1.5	1.9	0.9	3.3	1.7	0.9	0.9	1.5	1.5	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.5	94.8	90.8	79.3	69.6	62.8	61.6	67.3	75.8	84.8	89.2	95.2	(19)
		MCWB	66.5	65.5	63.7	60.7	56.1	53.6	49.4	52.4	55.9	58.9	61.6	64.5	(20)
	2%	DB	91.5	87.9	84.4	73.6	65.4	59.2	58.1	62.4	69.9	77.7	83.0	86.9	(21)
		MCWB	65.1	65.1	63.2	58.6	54.6	51.0	48.6	50.3	54.3	57.3	62.0	63.4	(22)
	5%	DB	85.5	82.7	78.9	69.3	62.4	56.5	55.4	59.0	65.9	72.2	77.4	80.9	(23)
		MCWB	65.1	64.6	62.2	57.9	53.4	49.5	47.5	48.9	52.5	56.4	60.2	62.6	(24)
	10%	DB	80.2	77.8	74.1	66.0	59.8	54.0	53.0	56.2	62.1	67.5	72.4	75.5	(25)
		MCWB	64.5	64.2	61.0	56.5	52.1	48.1	46.2	47.5	51.6	55.0	58.9	61.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.1	71.7	69.3	64.2	59.2	54.9	52.4	55.1	59.3	63.4	68.3	70.2	(27)
		MCDB	85.4	81.7	78.4	72.9	64.8	60.2	57.3	62.4	68.5	75.0	78.7	80.2	(28)
	2%	WB	69.8	69.3	66.3	61.2	56.8	52.5	50.1	52.0	56.6	60.3	64.5	66.6	(29)
		MCDB	81.9	79.0	75.9	68.7	62.0	57.2	54.8	59.1	66.0	71.1	74.4	78.1	(30)
	5%	WB	67.7	67.3	64.3	59.3	54.8	50.7	48.6	49.9	54.3	58.1	62.2	64.7	(31)
		MCDB	79.5	76.9	73.6	66.4	60.3	54.8	53.4	57.1	63.2	68.4	72.2	76.0	(32)
	10%	WB	65.5	65.3	62.3	57.6	53.1	49.1	47.2	48.3	52.3	56.0	60.1	62.7	(33)
		MCDB	76.4	74.6	71.7	64.2	58.5	52.9	51.7	54.7	60.2	65.7	70.1	73.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.5	18.6	16.7	13.6	10.9	9.5	10.3	12.4	15.3	17.7	18.8	19.9	(35)
		MCDBR	28.6	26.6	24.1	18.6	13.8	12.3	13.4	16.3	21.3	25.0	26.3	28.2	(36)
		MCWBR	9.9	10.0	9.3	8.7	8.1	7.8	8.2	8.9	10.3	10.8	10.8	11.2	(37)
	5% WB	MCDBR	23.5	21.7	19.7	16.2	12.4	10.7	11.5	14.8	18.6	21.2	21.9	23.0	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.361	0.342	0.319	0.309	0.287	0.277	0.281	0.286	0.308	0.318	0.326	0.367	(40)
		taud	2.450	2.535	2.589	2.590	2.638	2.659	2.633	2.618	2.549	2.545	2.553	2.418	(41)
		Ebn at Noon	308	307	302	285	275	269	274	290	301	311	318	308	(42)
	Edh at Noon		38	33	29	25	21	19	21	24	30	32	34	39	(43)
(44) All-Sky Solar Radiation	RadAvg		2163	1864	1542	1104	769	605	685	952	1327	1715	1964	2193	(44)
	RadStd		150	133	110	76	40	45	37	50	103	125	139	135	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.83	N/A	N/A	+1.46	N/A	N/A	N/A	-205	+290	+110

Nomenclature: See separate page