

ORBOST, Australia

WMO: 959180

Lat: 37.6922S

Lon: 148.4667E

Elev: 208

StdP: 14.59

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.3	40.0	31.8	26.4	50.2	33.5	28.3	49.8	21.7	55.9	19.0	54.3	2.1	350	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.7	93.3	68.4	88.5	67.7	84.1	67.0	71.9	84.7	70.2	82.3	68.7	79.7	9.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.3	104.7	74.8	66.8	99.3	73.7	65.3	94.1	72.6	35.8	85.5	34.3	82.9	33.0	79.9	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.8	16.1	13.7	DB	34.8	104.3	1.2	4.1	33.9	107.2	33.2	109.6	32.6	111.9	31.7	114.8	(4)
(5)			WB	33.8	75.4	0.8	1.2	33.2	76.3	32.7	77.0	32.3	77.7	31.7	78.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.8	68.2	67.1	64.9	60.2	55.5	51.3	50.5	51.5	54.5	57.4	61.1	64.4
	DBStd	8.19	7.50	6.14	5.92	5.03	4.15	3.48	3.40	3.96	4.99	6.09	6.75	6.63
	HDD50	96	0	0	0	0	2	24	34	26	8	2	0	0
	HDD65	2721	45	39	74	161	295	411	449	420	320	253	160	94
	CDD50	3325	563	479	463	307	174	63	50	72	142	232	333	447
	CDD65	471	143	98	72	18	1	0	0	0	4	17	43	75
	CDH74	4733	1533	865	589	142	7	0	0	1	52	229	476	839
	CDH80	1924	736	349	211	31	1	0	0	0	8	61	171	356
Wind	WSAvg	5.4	5.5	5.1	4.9	4.5	5.1	4.8	5.5	5.7	6.0	5.7	5.6	5.7
Precipitation	PrecAvg	34.1	2.4	2.2	2.6	3.0	3.1	3.4	2.8	2.4	3.0	2.9	3.2	3.5
	PrecMax	61.4	6.6	8.2	10.2	13.0	12.2	16.7	9.8	6.1	8.5	6.8	12.1	8.2
	PrecMin	20.4	0.3	0.2	0.1	0.4	0.4	0.4	0.2	0.4	0.6	0.9	0.5	0.1
	PrecStd	8.5	1.4	1.8	2.0	2.4	2.6	3.2	2.1	1.3	1.7	1.5	2.1	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	102.6	96.2	92.8	84.3	74.5	67.4	67.0	70.9	79.4	86.9	92.3	97.2
		MCWB	70.8	68.7	67.3	65.3	59.1	55.6	54.1	55.5	59.5	62.9	66.5	67.8
	2%	DB	94.5	89.4	86.4	77.9	69.8	63.3	63.5	66.1	74.0	80.2	84.8	89.5
		MCWB	69.9	68.7	66.2	62.7	57.9	54.2	52.3	53.4	58.1	62.3	66.3	67.1
	5%	DB	87.8	83.8	80.6	73.2	66.6	60.3	60.5	63.1	69.0	75.2	79.6	83.7
		MCWB	68.5	68.0	65.9	61.3	56.6	52.4	51.0	52.1	56.1	60.5	64.4	66.6
	10%	DB	82.5	78.7	76.0	69.2	63.3	58.0	57.9	60.1	64.7	70.1	74.2	78.0
		MCWB	67.9	67.3	64.8	60.1	55.2	51.5	49.7	50.8	54.7	59.1	62.9	64.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.8	73.9	71.0	66.8	61.7	58.0	55.9	57.4	62.1	66.6	70.9	72.2
		MCDB	91.4	84.3	82.2	78.4	68.4	63.1	62.6	66.7	74.9	78.4	82.2	85.1
	2%	WB	72.3	71.6	69.0	64.5	59.5	55.6	53.7	55.0	59.1	63.9	67.6	69.5
		MCDB	86.7	83.2	79.3	73.7	66.5	60.7	60.2	63.4	70.3	74.9	80.3	83.7
	5%	WB	70.4	69.7	67.4	62.7	57.7	54.0	52.1	53.2	57.1	61.7	65.6	67.6
		MCDB	83.2	80.1	76.5	69.9	64.3	58.2	58.3	60.4	67.0	72.7	76.8	80.0
	10%	WB	68.5	67.9	66.0	61.0	56.1	52.6	50.8	51.6	55.3	59.5	63.6	65.7
		MCDB	80.3	76.1	74.1	67.8	62.1	56.5	56.4	58.0	63.3	68.7	73.4	76.6
Mean Daily Temperature Range	5% DB	MDBR	18.7	17.5	16.9	16.4	14.4	13.1	14.5	15.3	16.7	17.5	17.3	18.2
		MCDBR	30.3	27.6	25.7	22.5	19.2	16.7	18.8	20.5	25.4	27.5	27.3	29.8
		MCWBR	11.2	10.7	10.1	10.3	10.7	10.0	10.8	11.2	12.6	12.5	12.4	12.5
	5% WB	MCDBR	25.6	21.7	20.4	19.7	17.1	14.8	16.5	18.6	23.1	24.3	23.7	24.2
		MCWBR	11.7	10.3	9.3	10.1	10.2	9.9	10.4	11.3	12.7	12.7	12.1	11.8
Clear-Sky Solar Irradiance	taub	0.416	0.379	0.344	0.330	0.309	0.296	0.290	0.304	0.331	0.343	0.352	0.374	
	taud	2.326	2.470	2.559	2.573	2.606	2.636	2.656	2.602	2.520	2.512	2.519	2.459	
	Ebn at Noon	291	295	293	278	266	262	272	284	293	303	309	306	
	Edh at Noon	43	36	30	26	22	20	20	24	30	34	35	38	
All-Sky Solar Radiation	RadAvg	2092	1800	1503	1097	787	617	718	987	1359	1729	1951	2158	
	RadStd	140	120	114	83	42	46	46	58	95	104	140	149	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (26 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-157	+227	+85	

Nomenclature: See separate page