

ORBOST, Australia

WMO: 959180

Lat: 37.6922S

Lon: 148.4667E

Elev: 63

StdP: 100.57

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.5	4.5	-0.1	3.8	10.1	0.9	4.0	9.9	9.7	13.3	8.5	12.4	1.0	350	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.4	34.1	20.2	31.4	19.8	29.0	19.4	22.2	29.3	21.2	27.9	20.4	26.5	4.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.0	23.8	19.3	14.2	23.1	18.5	13.4	22.5	65.4	29.7	61.9	28.3	58.9	26.6	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.2	6.1	DB	1.6	40.2	0.7	2.3	1.1	41.8	0.7	43.1	0.3	44.4	-0.2	46.0	
			WB	1.0	24.1	0.5	0.7	0.7	24.6	0.4	25.0	0.2	25.4	-0.2	25.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	20.1	19.5	18.3	15.7	13.1	10.7	10.3	10.8	12.5	14.1	16.2	18.0
	DBStd	4.55	4.17	3.41	3.29	2.80	2.30	1.94	1.89	2.20	2.77	3.38	3.75	3.69
	HDD10.0	53	0	0	0	0	1	13	19	14	4	1	0	0
	HDD18.3	1512	25	22	41	89	164	228	249	233	178	141	89	52
	CDD10.0	1847	313	266	257	171	97	35	28	40	79	129	185	248
	CDD18.3	262	79	54	40	10	1	0	0	0	2	9	24	42
	CDH23.3	2629	852	481	327	79	4	0	0	1	29	127	264	466
	CDH26.7	1069	409	194	117	17	1	0	0	4	34	95	198	
Wind	WSAvg	2.4	2.5	2.3	2.2	2.0	2.3	2.1	2.4	2.6	2.7	2.5	2.5	2.6
Precipitation	PrecAvg	867	62	55	65	76	79	86	70	61	76	74	81	88
	PrecMax	1559	167	208	260	330	311	425	248	154	215	172	308	209
	PrecMin	519	8	4	2	10	11	11	6	10	16	23	12	2
	PrecStd	215	36	46	52	62	65	81	53	34	42	37	54	53
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	35.7	33.8	29.1	23.6	19.7	19.5	21.6	26.3	30.5	33.5	36.2
		MCWB	21.5	20.4	19.6	18.5	15.0	13.1	12.3	13.0	15.3	17.2	19.2	19.9
	2%	DB	34.7	31.9	30.2	25.5	21.0	17.4	17.5	19.0	23.4	26.8	29.3	32.0
		MCWB	21.0	20.4	19.0	17.1	14.4	12.3	11.3	11.9	14.5	16.8	19.0	19.5
	5%	DB	31.0	28.8	27.0	22.9	19.2	15.7	15.8	17.3	20.6	24.0	26.5	28.7
		MCWB	20.3	20.0	18.8	16.3	13.7	11.3	10.6	11.2	13.4	15.8	18.0	19.2
	10%	DB	28.1	25.9	24.5	20.6	17.4	14.4	14.4	15.6	18.1	21.2	23.5	25.5
		MCWB	19.9	19.6	18.2	15.6	12.9	10.8	9.8	10.4	12.6	15.0	17.2	18.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.8	23.3	21.7	19.3	16.5	14.4	13.3	14.1	16.7	19.2	21.6	22.4
		MCDB	33.0	29.0	27.9	25.8	20.2	17.3	17.0	19.3	23.9	25.8	27.9	29.5
	2%	WB	22.4	22.0	20.6	18.1	15.3	13.1	12.0	12.8	15.1	17.7	19.8	20.8
		MCDB	30.4	28.4	26.3	23.2	19.2	15.9	15.7	17.5	21.3	23.9	26.8	28.7
	5%	WB	21.3	21.0	19.7	17.0	14.3	12.2	11.2	11.8	13.9	16.5	18.7	19.8
		MCDB	28.4	26.7	24.7	21.1	18.0	14.5	14.6	15.8	19.4	22.6	24.9	26.6
	10%	WB	20.3	20.0	18.9	16.1	13.4	11.4	10.4	10.9	12.9	15.3	17.6	18.7
		MCDB	26.8	24.5	23.4	19.9	16.7	13.6	13.5	14.5	17.4	20.4	23.0	24.8
Mean Daily Temperature Range	5% DB	MDBR	10.4	9.7	9.4	9.1	8.0	7.3	8.0	8.5	9.3	9.7	9.6	10.1
		MCDBR	16.8	15.3	14.3	12.5	10.7	9.3	10.4	11.4	14.1	15.3	15.2	16.6
		MCWBR	6.2	5.9	5.6	5.7	5.9	5.6	6.0	6.2	7.0	6.9	6.9	6.9
	5% WB	MCDBR	14.2	12.0	11.4	11.0	9.5	8.2	9.2	10.3	12.8	13.5	13.1	13.4
	MCWBR	6.5	5.7	5.2	5.6	5.7	5.5	5.8	6.3	7.1	7.0	6.7	6.6	
Clear-Sky Solar Irradiance	taub	0.416	0.379	0.344	0.330	0.309	0.296	0.290	0.304	0.331	0.343	0.352	0.374	
	taud	2.326	2.470	2.559	2.573	2.606	2.636	2.656	2.602	2.520	2.512	2.519	2.459	
	Ebn at Noon	918	929	925	877	839	825	856	894	923	956	974	964	
	Edh at Noon	134	112	94	81	68	62	64	77	96	106	110	119	
All-Sky Solar Radiation	RadAvg	6.60	5.67	4.74	3.46	2.48	1.94	2.27	3.11	4.28	5.45	6.15	6.80	
	RadStd	0.44	0.38	0.36	0.26	0.13	0.15	0.14	0.18	0.30	0.33	0.44	0.47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	-87	+126	+47

Nomenclature: See separate page