

MOUNT GININI, Australia

WMO: 959250

Lat: 35.5292S

Lon: 148.7722E

Elev: 5774

StdP: 11.88

Time Zone: 10.00 (AUS)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.3	23.9	-0.7	6.6	36.4	6.2	9.3	37.4	31.5	33.3	25.9	34.8	11.2	250	0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.4	77.2	58.4	73.3	56.9	70.0	55.6	62.0	70.1	60.0	67.6	58.3	65.7	9.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.4	94.0	63.5	57.5	87.7	61.9	55.8	82.3	60.3	30.9	70.9	29.3	67.3	28.0	66.0	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	21.0	18.8	19.3	83.9	1.2	3.5	18.4	86.4	17.8	88.5	17.1	90.4	16.2	93.0
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.1	58.9	56.2	52.0	46.6	39.1	34.7	32.0	33.3	39.1	45.4	50.0	54.4	
	DBStd	10.84	7.58	6.25	6.07	5.56	5.01	4.40	4.04	4.72	6.04	7.20	7.26	7.33	
	HDD50	2712	15	12	49	129	338	460	558	517	330	178	88	38	
	HDD65	7319	216	255	405	553	803	910	1023	982	778	607	450	337	
	CDD50	916	292	186	110	26	0	0	0	0	2	36	90	174	
	CDD65	48	29	9	1	0	0	0	0	0	0	0	2	7	
	CDH74	265	161	48	1	0	0	0	0	0	0	0	8	47	
	CDH80	29	19	6	0	0	0	0	0	0	0	0	0	4	
Wind	WSAvg	9.7	9.1	8.4	9.0	8.2	10.7	9.5	11.0	10.8	10.8	10.0	9.6	9.2	
Precipitation	PrecAvg	35.7	3.0	3.2	2.4	1.8	2.2	3.8	3.1	3.1	3.5	3.0	3.3	3.0	
	PrecMax	52.0	8.9	8.2	6.6	6.8	8.2	9.9	6.6	6.3	7.5	7.5	8.7	7.0	
	PrecMin	19.5	0.1	0.4	0.4	0.0	0.3	1.4	1.1	0.5	0.6	0.6	0.9	0.8	
	PrecStd	7.1	1.9	2.2	1.5	1.5	1.5	2.0	1.3	1.6	1.7	1.6	1.9	1.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.4	80.1	72.4	64.6	54.4	47.7	45.4	49.0	59.2	67.5	74.4	79.6	
		MCWB	60.1	58.8	56.1	51.1	45.0	37.0	40.8	40.2	45.0	49.5	56.0	57.4	
	2%	DB	78.5	73.6	68.0	60.5	50.6	45.0	42.5	45.0	55.0	63.4	68.3	73.8	
		MCWB	59.0	56.7	53.9	49.7	43.1	37.5	37.6	38.1	43.5	49.1	52.6	56.6	
	5%	DB	74.8	69.8	64.6	57.0	48.3	42.6	40.2	42.7	51.7	60.1	65.3	69.9	
		MCWB	57.7	56.5	53.0	49.2	41.8	36.5	36.2	37.5	41.8	47.3	51.9	54.6	
	10%	DB	71.2	66.3	61.4	54.4	46.2	40.6	38.1	40.2	48.2	56.8	61.8	66.5	
		MCWB	56.6	54.7	52.4	47.1	41.2	35.9	34.4	35.5	40.7	46.2	50.7	53.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.2	64.5	59.9	56.4	49.9	43.5	43.6	43.2	47.6	53.4	59.9	62.0
			MCDB	74.2	71.0	65.5	60.0	51.2	44.4	44.1	44.8	53.9	60.5	65.1	70.9
2%		WB	62.4	61.4	57.9	53.0	46.4	41.1	40.6	40.8	45.8	51.5	56.4	59.0	
		MCDB	71.8	67.0	63.4	57.3	48.3	42.4	41.3	43.9	52.1	57.3	63.2	66.6	
5%		WB	60.7	59.2	56.3	50.5	44.5	39.4	37.9	38.7	43.9	49.9	54.0	57.2	
		MCDB	69.6	66.1	61.3	54.9	47.3	40.7	38.8	41.4	49.1	55.5	62.2	65.3	
10%		WB	58.7	57.3	54.7	48.7	42.5	38.1	35.6	36.7	42.2	48.1	52.0	55.4	
		MCDB	67.4	63.1	59.4	52.9	44.7	39.6	36.7	39.1	47.0	55.0	60.1	63.8	
Mean Daily Temperature Range		5% DB	MDBR	17.4	16.4	14.2	12.2	10.0	7.9	7.5	9.7	13.9	16.3	16.8	17.6
			MCDBR	20.5	18.8	17.4	14.5	12.2	10.7	10.0	12.8	18.3	19.0	19.1	20.8
	MCWBR		11.2	10.4	10.6	9.2	9.8	8.9	8.6	9.9	11.7	11.3	10.5	10.7	
	5% WB	MCDBR	17.8	15.9	14.7	12.2	10.6	8.8	7.7	11.2	15.8	16.2	16.6	17.4	
		MCWBR	11.1	10.7	9.9	8.9	9.0	8.2	7.8	9.5	11.0	11.0	10.4	10.7	
	Clear-Sky Solar Irradiance	taub	0.326	0.292	0.270	0.258	0.251	0.239	0.235	0.243	0.263	0.279	0.286	0.288	
taud		2.493	2.658	2.723	2.722	2.678	2.744	2.769	2.722	2.640	2.607	2.630	2.637		
Ebn at Noon		320	325	322	309	294	292	299	311	319	326	331	334		
Edh at Noon		36	30	26	23	20	18	18	22	27	31	31	32		
All-Sky Solar Radiation	RadAvg	2315	1982	1686	1269	921	703	780	1057	1485	1891	2108	2351		
	RadStd	161	169	141	94	49	62	50	80	136	166	166	141		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207	N/A

Nomenclature: See separate page