

POINT PERPENDICULAR, Australia

WMO: 959400

Lat: 35.0936S

Lon: 150.8050E

Elev: 276

StdP: 14.55

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	46.9	48.1	31.8	26.4	56.6	33.6	28.4	55.1	25.0	55.2	22.8	56.2	7.3	300	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	84.0	67.1	80.4	69.0	78.1	68.6	73.3	78.0	72.1	76.4	71.1	75.2	12.5	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	119.4	74.7	70.8	114.6	74.0	69.7	110.3	73.3	37.1	78.1	36.1	76.7	35.1	75.4	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	22.6	20.3	DB	44.2	94.6	1.4	5.3	43.2	98.4	42.4	101.5	41.6	104.4	40.6	108.3	(4)
(5)			WB	39.7	74.9	1.0	1.4	39.0	75.8	38.4	76.6	37.9	77.4	37.2	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	70.7	70.2	68.9	65.0	60.5	56.8	55.2	56.1	59.3	62.4	65.3	67.9	(6)	
	DBStd	6.60	3.96	3.66	3.50	3.59	3.37	2.93	3.08	3.44	4.38	5.00	4.57	4.08	(7)	
	HDD50	1	0	0	0	0	0	0	1	0	0	0	0	0	(8)	
	HDD65	1387	3	3	7	40	146	247	304	277	182	111	51	16	(9)	
	CDD50	4799	640	566	585	450	324	204	162	189	279	386	458	556	(10)	
	CDD65	710	178	149	127	40	6	0	0	1	11	32	59	107	(11)	
	CDH74	2001	557	381	248	79	5	0	1	1	45	173	207	304	(12)	
	CDH80	380	111	52	25	11	0	0	0	0	5	53	55	68	(13)	
(14) Wind	WSAvg	9.5	10.9	10.4	10.1	8.3	8.1	8.4	8.2	9.1	9.9	9.7	10.1	11.1	(14)	
(15) Precipitation	PrecAvg	52.3	4.0	4.1	5.2	5.4	5.3	5.4	3.6	3.5	3.4	3.5	4.2	3.1	(15)	
	PrecMax	98.2	10.9	14.0	21.3	22.3	14.1	16.7	9.5	17.0	13.0	16.6	26.3	8.7	(16)	
	PrecMin	23.9	0.8	0.1	0.5	0.2	0.1	0.2	0.0	0.0	0.1	0.1	0.7	0.2	(17)	
	PrecStd	18.7	2.6	3.5	4.4	4.9	3.4	4.2	2.6	3.6	2.9	2.9	4.1	2.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.2	86.7	83.0	81.0	74.4	67.7	69.0	71.2	79.1	87.4	86.4	86.9	(19)	
		MCWB	70.7	72.8	68.4	64.6	60.6	57.2	55.6	55.8	58.6	61.0	66.7	67.0	(20)	
	2%	DB	82.0	80.4	78.8	75.6	70.7	65.0	65.0	67.2	73.6	78.2	79.5	80.7	(21)	
		MCWB	71.7	70.9	69.7	64.5	60.3	56.7	54.3	55.0	58.1	61.2	66.3	67.5	(22)	
	5%	DB	79.0	78.1	76.6	72.7	68.1	63.0	62.5	64.5	69.7	73.7	75.1	76.7	(23)	
		MCWB	70.8	70.4	68.8	64.1	59.3	55.8	53.3	54.4	56.9	60.8	65.7	68.0	(24)	
	10%	DB	76.7	76.1	74.5	70.4	66.1	61.5	60.5	62.3	66.6	70.2	72.3	74.4	(25)	
		MCWB	70.1	69.5	68.2	63.5	58.8	54.9	52.6	53.8	57.0	61.4	64.7	67.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.3	74.3	74.0	69.3	65.2	61.7	60.0	60.3	63.1	67.3	70.8	73.0	(27)	
		MCDB	80.3	81.3	76.5	75.0	67.9	63.9	63.7	65.0	69.1	73.6	77.7	78.6	(28)	
	2%	WB	73.5	72.8	72.0	67.5	63.1	58.9	57.5	58.5	61.6	65.7	69.2	71.0	(29)	
		MCDB	78.9	77.1	75.3	71.9	66.9	62.2	61.7	63.2	67.2	70.8	75.3	75.5	(30)	
	5%	WB	72.3	71.7	70.8	66.2	61.5	57.5	55.6	56.8	60.3	64.4	67.5	69.9	(31)	
		MCDB	76.9	76.1	74.3	70.2	66.0	61.2	59.6	62.1	66.2	69.5	72.5	73.7	(32)	
	10%	WB	71.1	70.6	69.6	64.9	60.0	56.3	53.9	55.1	58.8	63.1	66.1	68.7	(33)	
		MCDB	75.1	74.6	73.3	69.0	64.9	60.2	58.4	60.4	64.6	68.1	70.6	72.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	8.7	8.5	9.0	9.3	8.3	9.4	10.2	11.1	11.0	10.4	10.0	(35)	
		MCDBR	14.5	12.8	12.4	13.1	12.9	10.7	12.7	13.8	17.2	18.6	16.8	15.0	(36)	
	5% WB	MCWBR	6.8	6.1	6.8	7.4	7.3	6.4	7.1	8.3	8.8	8.8	7.8	6.9	(37)	
		MCWBR	12.6	10.9	10.2	11.2	10.7	8.6	10.1	11.8	13.8	13.8	14.3	11.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.399	0.379	0.355	0.328	0.312	0.301	0.293	0.303	0.333	0.348	0.378	0.384	(40)	
		taud	2.429	2.518	2.567	2.619	2.613	2.639	2.651	2.616	2.527	2.519	2.463	2.462	(41)	
	Ebn at Noon		297	297	292	283	271	266	275	288	294	303	302	303	(42)	
		Edh at Noon	39	34	30	25	23	21	21	25	31	34	37	38	(43)	
(44) All-Sky Solar Radiation	RadAvg		2050	1752	1496	1189	927	721	856	1129	1528	1808	1931	2095	(44)	
	RadStd		158	146	114	99	53	65	70	60	93	130	154	144	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	-2	-153	+329	+169

Nomenclature: See separate page