

POINT PERPENDICULAR, Australia

WMO: 959400

Lat: 35.0936S

Lon: 150.8050E

Elev: 84

StdP: 100.32

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	9.0	-0.1	3.8	13.7	0.9	4.1	12.8	11.2	12.9	10.2	13.4	3.3	300	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.4	28.9	19.5	26.9	20.6	25.6	20.3	22.9	25.6	22.3	24.7	21.7	24.0	5.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	17.1	23.7	21.5	16.4	23.3	20.9	15.8	22.9	68.5	25.6	66.0	24.8	63.8	24.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	10.1	9.1	DB	6.8	34.8	0.8	2.9	6.2	36.9	5.8	38.6	5.3	40.2	4.8	42.4	(4)
			WB	4.3	23.8	0.5	0.8	3.9	24.4	3.6	24.8	3.3	25.2	2.9	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	21.5	21.2	20.5	18.3	15.8	13.8	12.9	13.4	15.2	16.9	18.5	20.0
	DBStd	3.67	2.20	2.03	1.94	1.99	1.87	1.63	1.71	1.91	2.43	2.78	2.54	2.26
	HDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0
	HDD18.3	771	2	2	4	22	81	137	169	154	101	62	28	9
	CDD10.0	2666	356	314	325	250	180	113	90	105	155	214	254	309
	CDD18.3	394	99	83	71	22	3	0	0	1	6	18	33	59
	CDH23.3	1112	309	212	138	44	3	0	1	1	25	96	115	169
	CDH26.7	211	62	29	14	6	0	0	0	3	29	31	38	
Wind	WSAvg	4.3	4.9	4.7	4.5	3.7	3.6	3.8	3.7	4.1	4.4	4.4	4.5	5.0
Precipitation	PrecAvg	1328	101	103	131	138	135	137	92	90	87	89	107	80
	PrecMax	2494	277	355	540	566	359	423	241	433	329	422	667	222
	PrecMin	607	20	2	12	5	2	5	1	1	3	2	17	6
	PrecStd	474	66	88	111	125	86	107	66	92	74	73	105	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.3	30.4	28.3	27.2	23.6	19.8	20.6	21.8	26.2	30.8	30.2	30.5
		MCWB	21.5	22.7	20.2	18.1	15.9	14.0	13.1	13.2	14.8	16.1	19.3	19.5
	2%	DB	27.8	26.9	26.0	24.2	21.5	18.3	18.3	19.6	23.1	25.7	26.4	27.0
		MCWB	22.1	21.6	21.0	18.0	15.7	13.7	12.4	12.8	14.5	16.2	19.1	19.7
	5%	DB	26.1	25.6	24.8	22.6	20.1	17.2	16.9	18.0	20.9	23.2	23.9	24.8
		MCWB	21.6	21.3	20.5	17.8	15.2	13.2	11.8	12.4	13.8	16.0	18.7	20.0
	10%	DB	24.8	24.5	23.6	21.4	18.9	16.4	15.8	16.9	19.2	21.2	22.4	23.5
		MCWB	21.1	20.8	20.1	17.5	14.9	12.7	11.5	12.1	13.9	16.3	18.2	19.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.0	23.5	23.4	20.7	18.4	16.5	15.6	15.7	17.3	19.6	21.5	22.8
		MCDB	26.8	27.4	24.7	23.9	20.0	17.7	17.6	18.3	20.6	23.1	25.4	25.9
	2%	WB	23.1	22.7	22.2	19.7	17.3	14.9	14.2	14.7	16.5	18.7	20.6	21.7
		MCDB	26.0	25.1	24.0	22.2	19.4	16.8	16.5	17.3	19.6	21.5	24.0	24.2
	5%	WB	22.4	22.1	21.6	19.0	16.4	14.2	13.1	13.8	15.7	18.0	19.7	21.1
		MCDB	25.0	24.5	23.5	21.2	18.9	16.2	15.4	16.7	19.0	20.8	22.5	23.2
	10%	WB	21.7	21.4	20.9	18.3	15.5	13.5	12.2	12.8	14.9	17.3	19.0	20.4
		MCDB	24.0	23.7	23.0	20.6	18.3	15.6	14.7	15.8	18.1	20.0	21.4	22.5
Mean Daily Temperature Range	5% DB	MDBR	5.4	4.8	4.7	5.0	5.2	4.6	5.2	5.7	6.1	6.1	5.8	5.5
		MCDBR	8.0	7.1	6.9	7.3	7.1	5.9	7.0	7.7	9.5	10.3	9.3	8.4
		MCWBR	3.8	3.4	3.8	4.1	4.1	3.5	3.9	4.6	4.9	4.9	4.3	3.9
	5% WB	MCDBR	7.0	6.1	5.6	6.2	5.9	4.8	5.6	6.5	7.7	7.6	7.9	6.6
		MCWBR	3.7	3.3	3.6	3.9	4.0	3.4	4.0	4.8	5.0	4.3	4.2	3.7
Clear-Sky Solar Irradiance	taub	0.399	0.379	0.355	0.328	0.312	0.301	0.293	0.303	0.333	0.348	0.378	0.384	
	taud	2.429	2.518	2.567	2.619	2.613	2.639	2.651	2.616	2.527	2.519	2.463	2.462	
	Ebn at Noon	937	935	922	893	854	838	868	908	928	956	952	956	
	Edh at Noon	122	108	95	80	71	65	67	79	97	106	117	119	
All-Sky Solar Radiation	RadAvg	6.46	5.52	4.71	3.75	2.92	2.27	2.70	3.56	4.82	5.70	6.09	6.60	
	RadStd	0.50	0.46	0.36	0.31	0.17	0.20	0.22	0.19	0.29	0.41	0.49	0.45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (31 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-1	-85	+183	+94

Nomenclature: See separate page