

MOUNT READ, Australia

WMO: 959520

Lat: 41.844S

Lon: 145.542E

Elev: 3675

StdP: 12.85

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	26.8	28.0	15.1	13.5	39.4	21.6	18.6	40.0	47.5	36.3	43.8	36.2	15.2	230	0.998

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.5	69.6	56.4	65.6	55.5	62.1	53.7	58.9	65.4	57.1	62.7	55.4	60.6	15.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	78.3	60.3	54.9	73.4	58.5	53.1	68.8	57.0	27.2	65.5	26.0	62.7	24.9	60.8	67.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 42.0	37.3	33.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	24.1	62.0	1.2	2.3	23.2	63.7	22.5	65.0	21.8	66.3	20.9	68.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.7	49.0	49.3	46.9	42.9	39.5	36.8	35.4	35.2	36.6	39.5	43.7	46.2
	DBStd	7.56	7.36	7.00	7.05	5.02	4.27	3.58	2.88	3.79	4.43	5.83	6.68	7.30
	HDD50	3312	109	88	148	220	327	397	453	460	401	329	215	165
	HDD65	8511	499	440	563	664	792	847	918	925	851	789	640	583
	CDD50	284	78	70	51	6	1	0	0	0	0	5	25	48
	CDD65	6	3	1	1	0	0	0	0	0	0	0	0	1
	CDH74	30	17	5	3	0	0	0	0	0	0	0	0	5
	CDH80	3	3	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	17.9	16.9	16.7	17.4	18.0	18.7	18.4	18.1	18.3	19.4	18.7	16.8	17.6
Precipitation	PrecAvg	98.0	4.9	4.6	6.2	7.5	10.2	9.7	11.3	11.2	10.1	8.7	7.1	7.1
	PrecMax	134.6	9.8	11.5	12.2	14.1	24.2	19.1	19.6	22.2	17.6	14.1	12.5	15.4
	PrecMin	84.2	1.5	1.2	3.5	2.1	2.9	3.5	6.3	4.3	3.2	0.0	1.5	1.7
	PrecStd	11.5	2.2	2.5	2.0	2.9	4.5	4.2	3.4	4.8	3.5	3.3	2.9	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.7	72.8	71.0	59.9	53.2	47.4	43.9	48.1	52.5	60.2	67.2	72.8
		MCWB	59.0	58.4	57.3	52.3	46.2	43.9	41.7	43.5	46.6	50.3	54.6	56.8
	2%	DB	69.6	67.4	64.7	55.5	49.3	44.9	41.9	44.8	48.4	55.4	62.0	66.3
		MCWB	56.6	56.9	55.4	50.3	45.8	42.8	40.6	42.7	44.6	47.4	52.2	55.0
	5%	DB	64.5	63.3	60.6	52.5	47.4	43.2	40.7	42.5	45.3	51.8	58.2	61.6
		MCWB	55.3	55.2	53.8	49.3	45.1	41.7	39.9	40.9	43.0	46.7	51.0	52.7
	10%	DB	60.3	60.0	57.2	50.2	45.8	41.8	39.7	40.5	43.0	48.8	54.4	57.6
		MCWB	53.2	53.7	53.1	48.2	44.3	40.6	39.0	39.5	41.7	45.6	49.1	52.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.1	61.4	59.5	54.2	49.3	46.4	42.7	45.4	48.6	52.7	56.6	59.6
		MCDB	71.1	68.4	66.0	56.9	51.4	46.8	43.1	46.8	50.9	57.5	62.3	68.7
	2%	WB	58.5	58.8	57.1	51.8	47.4	44.2	41.1	43.3	45.4	50.1	54.2	56.6
		MCDB	65.7	64.8	61.7	54.2	48.4	44.6	41.3	44.4	47.4	53.4	59.8	62.5
	5%	WB	56.5	56.6	55.1	50.3	45.9	42.5	40.1	41.4	43.6	47.7	52.3	54.6
		MCDB	63.0	61.6	58.7	52.1	46.7	42.8	40.3	42.3	45.1	50.4	57.0	60.4
	10%	WB	54.3	54.8	53.1	48.5	44.6	41.2	39.2	39.9	41.8	45.6	50.1	52.5
		MCDB	59.6	59.4	56.6	50.2	45.5	41.5	39.4	40.5	43.0	48.5	54.0	57.2
Mean Daily Temperature Range	5% DB	MDBR	13.1	12.5	10.5	8.1	6.2	5.4	5.1	6.0	7.6	9.9	11.6	12.4
		MCDBR	19.6	17.3	15.1	11.0	7.7	6.4	6.2	9.0	11.2	15.3	16.8	19.1
		MCWBR	12.5	11.4	9.6	8.3	6.5	5.6	5.8	7.5	9.0	11.0	11.3	12.4
	5% WB	MCDBR	17.6	15.4	13.6	9.9	6.7	5.6	5.8	8.1	10.2	13.4	14.9	16.9
		MCWBR	12.2	11.2	9.8	8.2	6.2	5.4	5.7	7.2	8.7	10.7	11.0	11.7
Clear-Sky Solar Irradiance	taub	0.294	0.288	0.283	0.275	0.269	0.263	0.264	0.279	0.295	0.291	0.291	0.290	
	taud	2.632	2.669	2.681	2.680	2.670	2.672	2.676	2.630	2.569	2.600	2.621	2.643	
	Ebn at Noon	329	323	311	293	273	265	273	287	301	318	327	331	
	Edh at Noon	31	28	25	22	18	17	18	23	28	30	31	31	
All-Sky Solar Radiation	RadAvg	2010	1764	1282	872	525	419	461	682	1001	1470	1836	1959	
	RadStd	145	120	76	67	50	43	37	61	72	107	150	154	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (27 neighbors)		+0.54	N/A	N/A	+1.21	+0.58	+0.74	N/A	-176	+187	+22

Nomenclature: See separate page