

MOUNT READ, Australia

WMO: 959520

Lat: 41.844S

Lon: 145.542E

Elev: 1120

StdP: 88.57

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-2.9	-2.2	-9.4	1.9	4.1	-5.8	2.7	4.5	21.2	2.4	19.6	2.3	6.8	230	0.998

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.9	20.9	13.5	18.7	13.0	16.7	12.0	14.9	18.6	13.9	17.0	13.0	15.9	6.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	11.2	15.7	12.7	10.5	14.7	11.7	9.8	13.9	45.5	18.6	42.5	17.0	39.9	16.0	19.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	16.7	14.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-4.4	16.7	0.7	1.3	-4.9	17.6	-5.3	18.3	-5.6	19.1	-6.1	20.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	9.4	9.6	8.3	6.0	4.1	2.7	1.9	1.8	2.6	4.2	6.5	7.9		
	DBStd	4.20	4.09	3.89	3.92	2.79	2.37	1.99	1.60	2.10	2.46	3.24	3.71	4.06		
	HDD10.0	1840	61	49	82	122	182	221	252	256	223	183	119	92		
	HDD18.3	4728	277	244	313	369	440	471	510	514	473	438	356	324		
	CDD10.0	158	43	39	28	3	1	0	0	0	0	3	14	27		
	CDD18.3	3	2	1	1	0	0	0	0	0	0	0	0	1		
	CDH23.3	17	9	3	2	0	0	0	0	0	0	0	0	3		
	CDH26.7	2	2	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	8.0	7.6	7.5	7.8	8.0	8.4	8.2	8.1	8.2	8.7	8.3	7.5	7.9		
(15) Precipitation	PrecAvg	2490	124	116	157	190	259	246	286	285	257	220	180	181		
	PrecMax	3419	248	291	311	358	615	484	498	564	447	357	317	392		
	PrecMin	2139	37	30	90	54	73	89	159	108	82	0	38	44		
	PrecStd	293	57	63	51	74	115	106	87	122	88	84	73	64		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.3	22.6	21.7	15.5	11.8	8.6	6.6	9.0	11.4	15.6	19.5	22.7		
		MCWB	15.0	14.7	14.0	11.3	7.9	6.6	5.4	6.4	8.1	10.2	12.6	13.8		
	2%	DB	20.9	19.7	18.2	13.1	9.6	7.2	5.5	7.1	9.1	13.0	16.7	19.0		
		MCWB	13.7	13.8	13.0	10.2	7.7	6.0	4.8	6.0	7.0	8.6	11.2	12.8		
	5%	DB	18.1	17.4	15.9	11.4	8.5	6.2	4.9	5.8	7.4	11.0	14.5	16.5		
		MCWB	12.9	12.9	12.1	9.6	7.3	5.4	4.4	5.0	6.1	8.2	10.6	11.5		
	10%	DB	15.7	15.6	14.0	10.1	7.7	5.4	4.3	4.7	6.1	9.3	12.5	14.2		
		MCWB	11.8	12.1	11.7	9.0	6.8	4.8	3.9	4.1	5.4	7.6	9.5	11.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.3	15.3	12.3	9.6	8.0	5.9	7.4	9.2	11.5	13.7	15.3		
		MCDB	21.7	20.2	18.9	13.8	10.8	8.2	6.2	8.2	10.5	14.2	16.8	20.4		
	2%	WB	14.7	14.9	14.0	11.0	8.6	6.8	5.1	6.3	7.4	10.0	12.3	13.7		
		MCDB	18.7	18.2	16.5	12.4	9.1	7.0	5.2	6.9	8.5	11.9	15.5	17.0		
	5%	WB	13.6	13.7	12.8	10.2	7.7	5.8	4.5	5.2	6.5	8.7	11.3	12.6		
		MCDB	17.2	16.4	14.8	11.2	8.2	6.0	4.6	5.7	7.3	10.2	13.9	15.8		
	10%	WB	12.4	12.6	11.7	9.2	7.0	5.1	4.0	4.4	5.5	7.5	10.1	11.4		
		MCDB	15.3	15.2	13.7	10.1	7.5	5.3	4.1	4.7	6.1	9.2	12.2	14.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	6.9	5.8	4.5	3.4	3.0	2.9	3.3	4.2	5.5	6.4	6.9		
		MCDBR	10.9	9.6	8.4	6.1	4.3	3.6	3.5	5.0	6.2	8.5	9.3	10.6		
	5% WB	MCWBR	6.9	6.3	5.4	4.6	3.6	3.1	3.2	4.2	5.0	6.1	6.3	6.9		
		MCWBR	9.8	8.5	7.6	5.5	3.7	3.1	3.2	4.5	5.6	7.5	8.3	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.294	0.288	0.283	0.275	0.269	0.263	0.264	0.279	0.295	0.291	0.291	0.290		
		taud	2.632	2.669	2.681	2.680	2.670	2.672	2.676	2.630	2.569	2.600	2.621	2.643		
	Ebn at Noon		1036	1017	981	923	862	835	860	904	950	1003	1032	1045		
		Edh at Noon	97	89	80	68	58	53	57	71	88	94	98	98		
(44) All-Sky Solar Radiation	RadAvg		6.33	5.56	4.04	2.75	1.66	1.32	1.45	2.15	3.16	4.63	5.79	6.17		
	RadStd		0.46	0.38	0.24	0.21	0.16	0.14	0.12	0.19	0.23	0.34	0.47	0.49		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		+0.30	N/A	N/A	+0.67	+0.32	+0.41	N/A	-98	+104	+12

Nomenclature: See separate page