

LUNCHEON HILL, Australia

WMO: 959560

Lat: 41.149S

Lon: 145.152E

Elev: 1129

StdP: 14.11

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	34.7	36.2	31.9	27.4	38.0	33.3	29.0	38.6	32.0	48.7	28.7	48.6	11.7	190	0.735

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.6	78.1	64.0	74.3	62.5	71.0	61.1	65.7	74.5	64.0	71.5	62.5	68.6	13.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.8	89.2	67.8	61.2	84.2	66.8	59.7	79.7	65.5	31.2	74.6	29.8	71.6	28.7	68.7	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.3	27.3	24.1	DB	32.6	86.4	1.2	4.8	31.7	89.9	31.0	92.7	30.3	95.4	29.4	98.9	(4)
(5)			WB	31.7	70.0	1.2	2.1	30.8	71.5	30.1	72.8	29.5	73.9	28.6	75.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	58.6	59.0	57.1	53.2	49.1	46.5	45.2	45.3	46.9	49.7	53.3	55.6	(6)
(7)		DBStd	6.91	6.21	5.62	5.93	4.78	3.87	3.28	2.96	3.60	3.98	4.87	5.70	5.80	(7)
(8)		HDD50	717	4	1	6	20	64	111	149	150	110	65	24	13	(8)
(9)		HDD65	4950	219	181	255	355	493	555	613	610	544	475	352	298	(9)
(10)		CDD50	1297	270	253	227	116	36	6	1	6	16	55	125	186	(10)
(11)		CDD65	53	20	13	11	0	0	0	0	0	0	0	3	6	(11)
(12)		CDH74	383	173	71	62	1	0	0	0	0	0	3	22	51	(12)
(13)		CDH80	81	47	11	13	0	0	0	0	0	0	0	2	8	(13)
(14)	Wind	WSAvg	13.4	14.0	13.9	13.0	12.9	13.1	12.6	13.2	13.1	14.0	13.8	13.8	13.9	(14)
(15)	Precipitation	PrecAvg	58.5	2.5	2.3	3.4	4.0	5.9	6.3	7.6	7.9	6.2	4.8	3.8	3.5	(15)
(16)		PrecMax	77.4	6.4	6.1	5.6	7.9	11.3	11.7	11.8	16.7	9.5	8.0	5.9	6.5	(16)
(17)		PrecMin	44.5	0.4	0.4	1.1	1.4	2.0	2.6	3.5	3.3	2.0	0.5	0.7	0.8	(17)
(18)		PrecStd	7.2	1.5	1.4	1.3	1.7	2.4	2.2	1.9	3.1	1.8	1.8	1.5	1.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.5	80.2	81.3	70.0	62.4	56.4	54.4	58.0	63.0	71.9	77.3	80.5	(19)
(20)			MCWB	67.7	65.6	65.3	60.9	56.9	53.1	50.9	52.7	55.6	58.4	62.4	64.1	(20)
(21)		2%	DB	78.4	75.6	73.9	65.6	58.2	54.0	52.4	54.4	58.3	65.2	71.4	74.0	(21)
(22)			MCWB	64.3	63.3	63.1	58.6	54.7	51.2	50.1	50.6	52.6	56.0	60.2	61.8	(22)
(23)		5%	DB	73.6	72.1	69.8	62.4	56.0	52.5	50.8	52.2	55.5	61.3	67.1	69.5	(23)
(24)			MCWB	62.3	62.1	61.2	57.0	53.8	50.4	49.1	49.5	50.9	54.1	58.0	59.8	(24)
(25)		10%	DB	69.0	68.7	66.0	59.9	54.7	51.2	49.6	50.5	52.9	58.1	63.2	65.8	(25)
(26)			MCWB	60.2	60.5	59.6	56.1	52.8	49.6	48.2	48.4	49.5	52.5	56.5	58.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.3	68.0	66.4	62.1	57.8	54.4	52.4	53.2	56.5	60.3	64.3	66.6	(27)
(28)			MADB	81.0	78.4	77.0	67.2	60.3	55.5	53.1	56.3	61.2	67.2	74.0	75.4	(28)
(29)		2%	WB	65.7	65.3	64.2	59.8	55.6	52.2	50.8	51.5	53.7	57.3	61.2	63.3	(29)
(30)			MADB	75.4	72.3	71.9	63.7	57.0	53.1	51.6	53.6	57.3	62.4	68.5	70.9	(30)
(31)		5%	WB	63.6	63.4	62.3	58.2	54.4	51.0	49.6	50.1	51.8	55.3	59.4	61.0	(31)
(32)			MADB	71.5	69.4	67.9	61.2	55.8	51.9	50.3	51.7	54.4	60.1	65.7	66.8	(32)
(33)		10%	WB	61.5	61.8	60.3	56.6	53.1	50.0	48.5	48.8	50.1	53.2	57.1	59.1	(33)
(34)			MADB	68.0	67.3	65.2	59.4	54.5	50.9	49.3	50.1	52.4	57.5	62.6	65.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.4	16.6	14.6	11.5	9.0	8.0	7.9	9.6	11.1	14.3	15.3	15.5	(35)
(36)			MCDBR	24.1	21.2	19.9	14.7	10.5	9.0	8.9	11.2	14.8	19.7	21.9	21.9	(36)
(37)			MCWBR	12.1	10.7	10.2	8.9	7.8	7.0	7.2	8.0	9.5	11.6	12.2	11.7	(37)
(38)		5% WB	MCDBR	21.7	18.6	18.0	12.7	9.2	7.3	7.8	9.9	13.0	17.3	19.9	18.9	(38)
(39)			MCWBR	12.1	10.6	10.1	8.6	7.3	6.3	6.8	7.6	9.0	11.0	11.8	11.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.327	0.319	0.315	0.309	0.298	0.299	0.330	0.340	0.331	0.335	0.327	(40)	
(41)		taud	2.531	2.571	2.594	2.582	2.580	2.602	2.603	2.492	2.461	2.502	2.507	2.551	(41)	
(42)		Ebn at Noon	315	310	298	278	258	251	259	267	285	305	313	319	(42)	
(43)		Edh at Noon	34	31	28	24	21	19	20	26	31	33	35	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2087	1826	1352	922	580	462	503	747	1094	1571	1911	2066	(44)	
(45)		RadStd	137	99	69	62	45	41	34	61	70	97	128	148	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		+0.49	N/A	N/A	+1.17	+0.74	+0.81	N/A	-144	+162	+20

Nomenclature: See separate page