

SCOTTS PEAK DAM, Australia

WMO: 959580

Lat: 43.042S

Lon: 146.272E

Elev: 1339

StdP: 14.00

Time Zone: 10.00 (AUS)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 33.1	(c) 34.5	(d) 31.0	(e) 26.4	(f) 36.8	(g) 32.2	(h) 28.0	(i) 36.9	(j) 51.8	(k) 44.3	(l) 47.8	(m) 45.4	(n) 9.9	(o) 290	(p) 0.802

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 18.2	(c) 82.0	(d) 63.3	(e) 77.4	(f) 61.7	(g) 73.2	(h) 60.0	(i) 64.6	(j) 78.0	(k) 62.8	(l) 74.5	(m) 61.0	(n) 70.9	(o) 14.1	(p) 330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.2	81.8	66.5	58.4	76.6	65.7	56.6	71.8	64.3	30.3	77.8	29.0	74.6	27.7	71.0	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.5	40.6	34.6	31.0	92.0	1.3	4.2	30.1	95.0	29.3	97.5	28.6	99.8	27.6	102.9
			30.6	68.8	1.1	2.2	29.8	70.4	29.1	71.7	28.5	72.9	27.7	74.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	57.6	57.6	55.3	51.0	46.8	44.1	42.9	43.5	45.8	48.9	52.5	54.9
	DBStd	7.72	7.09	7.12	6.70	5.25	4.14	3.63	3.22	4.15	4.72	6.00	6.85	7.02
	HDD50	1115	10	9	19	47	116	179	221	207	142	93	45	27
	HDD65	5522	251	225	311	419	564	626	685	666	575	498	380	322
	CDD50	1136	246	223	183	78	18	2	1	6	17	61	121	180
	CDD65	69	22	19	10	0	0	0	0	0	0	1	7	10
	CDH74	818	274	203	98	1	0	0	0	0	0	18	84	140
	CDH80	233	89	60	27	0	0	0	0	0	0	1	21	35
(14) Wind	WSAvg	15.5	15.8	14.0	14.0	14.0	16.1	14.4	15.5	16.1	16.9	17.0	16.1	16.2
(15) Precipitation	PrecAvg	74.5	4.1	3.8	5.0	5.7	7.5	6.9	8.1	9.2	7.7	7.0	4.8	5.6
	PrecMax	87.5	8.8	8.2	10.4	10.4	15.1	14.1	11.7	13.3	13.1	12.6	8.2	10.8
	PrecMin	66.2	0.5	0.7	1.5	2.5	3.5	3.3	3.6	4.1	3.0	3.1	0.7	2.5
	PrecStd	5.8	2.0	1.7	1.8	2.0	3.3	2.6	1.9	2.5	2.6	2.2	1.8	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.9	87.4	82.8	71.0	61.7	56.2	54.5	60.5	66.6	76.4	82.7	85.3
		MCWB	65.1	66.2	64.3	58.7	53.6	51.5	49.5	51.5	54.3	58.5	62.5	63.1
	2%	DB	81.2	80.1	75.5	66.5	57.3	52.7	51.0	55.2	60.4	68.6	75.1	77.5
		MCWB	63.1	63.2	62.0	56.9	51.9	49.3	47.3	48.8	51.3	55.2	59.2	61.0
	5%	DB	75.3	74.6	70.3	62.2	54.7	50.6	49.1	52.0	56.2	63.8	69.5	72.6
		MCWB	61.0	61.3	59.7	55.2	51.0	48.2	46.5	47.3	49.1	53.5	57.5	59.1
	10%	DB	70.0	69.4	65.7	58.5	52.7	49.3	47.6	49.1	52.8	58.8	64.0	67.3
		MCWB	59.1	59.0	58.1	53.7	50.1	47.4	45.7	46.3	48.4	51.7	55.1	57.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.8	66.9	65.8	60.1	55.3	52.8	50.1	52.1	55.0	60.3	64.0	65.2
		MCDB	82.4	83.4	78.9	68.5	60.1	55.2	52.5	58.5	64.1	71.6	76.3	78.1
	2%	WB	64.0	64.1	63.1	57.5	53.0	50.2	48.2	49.5	52.2	56.9	60.9	62.3
		MCDB	77.8	77.8	73.2	64.0	55.5	51.7	49.7	53.7	57.9	65.8	70.5	74.8
	5%	WB	61.9	62.0	60.8	55.9	51.6	48.8	47.0	47.9	50.3	54.1	58.3	60.0
		MCDB	73.7	72.5	68.7	61.2	54.0	50.0	48.4	51.1	55.0	62.1	68.2	70.8
	10%	WB	59.8	59.9	58.5	54.0	50.3	47.6	46.0	46.6	48.5	51.8	55.6	57.6
		MCDB	69.1	68.2	65.2	58.1	52.5	48.9	47.3	48.8	52.2	58.6	63.6	66.6
(35) Mean Daily Temperature Range	5% DB	MDBR	18.2	18.4	15.4	12.3	8.8	7.8	8.2	9.9	12.2	15.1	16.9	17.2
		MCDBR	29.9	28.7	25.0	18.9	12.0	9.6	10.2	14.8	19.2	25.3	27.9	28.9
		MCWBR	13.3	13.5	12.4	10.7	8.2	7.2	7.7	9.5	11.4	13.2	13.7	13.3
	5% WB	MCDBR	27.1	26.4	23.0	16.8	10.5	8.6	9.0	12.8	16.8	23.6	25.7	25.9
		MCWBR	12.9	13.1	12.0	10.1	7.8	7.0	7.6	8.9	10.9	13.1	13.1	13.0
(40) Clear-Sky Solar Irradiance	taub		0.329	0.320	0.318	0.306	0.300	0.288	0.292	0.309	0.330	0.328	0.326	0.326
	taud		2.549	2.588	2.593	2.607	2.602	2.616	2.607	2.563	2.486	2.506	2.532	2.548
	Ebn at Noon		316	311	297	278	256	249	256	272	287	304	315	319
	Edh at Noon		33	30	28	23	19	17	19	24	30	33	34	34
(44) All-Sky Solar Radiation	RadAvg		1975	1709	1234	826	493	392	448	675	1015	1469	1815	1963
(45)	RadStd		143	134	78	50	39	35	31	50	55	87	141	128

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)	+0.58	N/A	N/A	+1.17	N/A	N/A	N/A	-180	+189	+23

Nomenclature: See separate page