

LOW ROCKY POINT, Australia

WMO: 959610

Lat: 42.985S

Lon: 145.502E

Elev: 113

StdP: 14.64

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.1	40.8	33.9	28.7	43.5	35.5	30.6	44.8	47.7	51.3	45.2	51.0	11.1	30	0.753

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.6	75.4	62.6	71.4	62.4	68.5	61.1	65.4	71.9	63.9	69.8	62.7	67.6	16.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.4	87.6	66.8	61.8	82.9	65.6	60.5	78.9	64.9	30.4	72.3	29.3	69.9	28.4	67.7	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.2	37.0	33.2	DB	35.3	85.4	1.9	3.8	33.9	88.1	32.8	90.3	31.7	92.5	30.3	95.2	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	59.3	59.7	58.0	55.0	52.5	50.1	49.1	49.4	50.7	52.5	54.7	57.0
	DBStd	5.20	3.93	4.05	4.05	3.85	3.45	3.14	2.88	3.18	3.52	3.80	4.04	4.06
	HDD50	198	0	0	0	3	13	36	51	50	30	12	3	0
	HDD65	4061	186	158	223	301	387	446	492	485	429	390	312	252
	CDD50	1644	287	271	248	154	91	40	23	30	51	88	143	218
	CDD65	33	9	9	6	1	0	0	0	0	0	1	2	5
	CDH74	181	45	49	34	5	0	0	0	0	1	5	14	28
	CDH80	31	8	11	5	0	0	0	0	0	0	0	1	6
Wind	WSAvg	16.4	14.9	14.1	14.5	16.2	17.9	16.6	17.9	18.4	18.1	17.0	15.2	15.9
Precipitation	PrecAvg	74.1	3.8	3.7	5.0	5.9	7.5	7.0	8.2	8.7	7.8	6.7	4.8	5.5
	PrecMax	89.0	8.9	8.8	7.2	10.8	13.5	13.8	12.8	13.9	13.3	11.0	10.2	11.4
	PrecMin	61.9	0.7	0.6	2.9	1.8	3.3	2.3	4.4	3.9	2.0	2.1	0.5	2.4
	PrecStd	7.4	2.0	1.8	1.1	2.2	2.9	2.9	2.1	2.9	2.9	2.2	2.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.4	80.1	78.8	72.5	65.4	60.8	58.5	62.4	68.1	72.5	75.9	77.6
		MCWB	64.9	66.8	64.4	60.6	56.5	54.1	52.6	53.2	56.2	58.4	61.0	62.8
	2%	DB	73.2	73.0	71.0	66.7	61.8	58.0	56.4	59.0	62.5	66.1	68.9	70.9
		MCWB	63.2	64.2	63.3	59.5	55.8	53.9	52.4	52.6	53.3	56.2	60.3	63.1
	5%	DB	69.1	69.6	67.3	63.5	59.5	56.4	55.1	56.3	58.9	61.7	64.1	66.6
		MCWB	61.8	62.4	61.7	58.2	55.5	53.4	52.0	51.8	53.1	54.9	58.5	60.5
	10%	DB	66.1	66.9	64.5	61.1	58.0	55.2	53.9	54.4	56.3	58.6	61.4	63.8
		MCWB	60.2	60.6	60.0	57.3	54.9	52.7	51.1	50.9	52.4	53.7	56.0	58.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.5	67.2	67.1	63.4	59.3	56.7	54.9	54.7	57.2	60.3	65.2	65.8
		MCDB	73.6	74.8	73.9	69.7	62.1	57.5	55.8	57.9	65.1	70.3	71.3	70.5
	2%	WB	64.6	64.8	64.9	61.5	57.8	55.6	54.0	53.3	55.5	57.9	62.9	63.2
		MCDB	72.2	71.4	70.6	65.9	60.1	56.7	55.3	56.4	59.7	64.1	68.3	68.8
	5%	WB	62.7	63.1	63.3	60.0	56.6	54.5	52.9	52.3	54.2	55.9	59.7	61.2
		MCDB	68.5	68.1	67.9	63.5	58.8	55.7	54.5	54.6	57.6	60.7	65.6	66.4
	10%	WB	61.2	61.7	61.8	58.5	55.4	53.4	51.8	51.3	53.0	54.3	57.1	59.3
		MCDB	66.0	65.9	65.5	61.9	57.8	54.8	53.6	53.4	56.0	58.0	61.7	63.4
Mean Daily Temperature Range	5% DB	MDBR	11.7	11.6	10.7	9.7	7.9	7.9	8.1	8.4	9.5	10.3	10.8	11.1
		MCDBR	18.1	16.7	16.1	14.8	10.3	9.4	9.6	11.6	14.8	16.8	17.3	17.3
		MCWBR	11.1	11.2	9.9	9.4	7.9	7.0	7.5	8.6	8.3	10.6	10.8	11.1
	5% WB	MCDBR	16.2	14.3	13.5	12.9	8.6	5.9	8.0	9.5	11.2	15.2	16.9	15.4
		MCWBR	10.6	10.6	9.7	9.1	7.5	5.9	7.7	7.8	8.0	10.0	11.0	10.9
Clear-Sky Solar Irradiance	taub	0.346	0.337	0.334	0.321	0.318	0.314	0.308	0.334	0.349	0.343	0.338	0.337	
	taud	2.532	2.569	2.580	2.594	2.580	2.563	2.590	2.515	2.464	2.499	2.532	2.554	
	Ebn at Noon	311	305	291	272	249	237	250	262	280	299	311	315	
	Edh at Noon	34	31	28	23	20	19	20	25	31	33	34	34	
All-Sky Solar Radiation	RadAvg	1971	1727	1231	827	487	385	444	669	1009	1475	1845	1986	
	RadStd	131	147	84	55	39	34	38	50	52	92	149	135	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	+0.88	N/A	+0.99	N/A	N/A	N/A	-104	N/A	N/A
(47) Regional (21 neighbors)		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-180	+194	+22

Nomenclature: See separate page