

LOW HEAD, Australia

WMO: 959640

Lat: 41.055S

Lon: 146.787E

Elev: 4

StdP: 101.28

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	4.6	-0.8	3.5	8.8	0.4	3.9	8.7	18.5	11.1	17.4	11.4	4.8	160	0.709

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.5	22.5	19.0	21.6	18.3	20.9	17.7	19.8	21.7	19.1	21.0	18.5	20.4	5.9	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	13.8	21.1	18.3	13.2	20.6	17.6	12.6	20.0	56.8	21.9	54.5	21.1	52.4	20.4	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	15.3	13.9	2.2	24.2	0.7	1.0	1.7	24.9	1.3	25.5	0.9	26.0	0.4	26.7
			1.4	20.4	0.5	0.7	1.0	20.9	0.7	21.4	0.4	21.8	0.1	22.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.5	17.3	17.7	16.6	14.5	12.4	10.5	9.9	10.1	11.0	12.3	14.1	15.6	(6)
	DBStd	3.24	1.78	1.78	1.91	1.82	1.97	1.93	1.84	1.67	1.47	1.55	1.75	1.64	(7)
	HDD10.0	73	0	0	0	0	3	17	24	20	7	2	0	0	(8)
	HDD18.3	1797	43	31	59	114	182	233	260	254	221	188	128	84	(9)
	CDD10.0	1348	225	216	205	137	79	33	23	24	37	72	122	175	(10)
	CDD18.3	29	9	13	6	0	0	0	0	0	0	0	0	1	(11)
	CDH23.3	8	2	4	1	0	0	0	0	0	0	0	0	0	(12)
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	7.2	7.1	6.4	6.7	6.7	7.6	6.9	7.4	7.4	7.4	7.3	7.4	7.6	(14)
(15) Precipitation	PrecAvg	662	37	33	41	60	68	62	85	72	59	51	47	46	(15)
	PrecMax	955	122	168	167	189	186	131	175	157	158	85	87	142	(16)
	PrecMin	450	6	1	2	8	8	15	31	19	5	15	13	1	(17)
	PrecStd	113	23	32	35	44	38	28	36	34	32	20	19	34	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.4	24.1	23.1	20.2	17.6	15.6	14.3	14.5	15.7	18.0	20.6	21.6	(19)
		MCWB	19.5	19.8	19.5	16.7	15.0	13.2	12.1	11.8	12.3	14.2	16.8	17.6	(20)
	2%	DB	22.1	22.7	21.8	19.2	16.8	14.7	13.7	13.7	14.7	16.7	19.1	20.4	(21)
		MCWB	18.6	19.2	18.6	16.2	14.4	12.8	11.6	11.4	11.9	13.8	16.1	16.9	(22)
	5%	DB	21.2	21.8	20.7	18.4	16.2	14.2	13.2	13.2	14.1	15.8	18.1	19.6	(23)
		MCWB	18.0	18.7	17.7	15.7	13.9	12.3	11.3	11.2	11.6	13.0	15.1	16.4	(24)
	10%	DB	20.5	21.0	19.9	17.8	15.6	13.7	12.8	12.7	13.6	15.1	17.2	18.8	(25)
		MCWB	17.4	17.8	16.9	15.1	13.4	11.9	11.0	10.8	11.2	12.5	14.2	15.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.8	20.8	20.2	17.7	15.7	14.2	12.8	12.6	13.2	15.5	17.7	18.9	(27)
		MCDB	22.5	22.7	22.2	19.0	16.6	14.8	13.6	13.5	14.5	17.0	19.5	20.7	(28)
	2%	WB	19.5	20.0	19.3	17.1	15.1	13.4	12.2	12.1	12.7	14.5	16.6	17.9	(29)
		MCDB	21.3	21.9	21.2	18.6	16.3	14.3	13.2	13.1	14.1	16.0	18.5	19.6	(30)
	5%	WB	18.8	19.3	18.5	16.5	14.5	12.8	11.7	11.6	12.2	13.7	15.7	17.1	(31)
		MCDB	20.7	21.2	20.4	18.1	15.9	14.0	12.8	12.8	13.6	15.4	17.5	19.0	(32)
	10%	WB	18.1	18.6	17.6	15.7	13.9	12.2	11.3	11.2	11.7	13.0	14.8	16.2	(33)
		MCDB	20.1	20.6	19.5	17.4	15.3	13.5	12.6	12.5	13.2	14.8	16.7	18.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.5	5.6	5.5	5.0	4.9	4.6	4.7	4.7	5.1	5.1	5.1	(35)
		MCDBR	5.8	5.9	6.0	5.8	4.9	4.5	4.2	4.5	5.1	5.7	5.9	5.8	(36)
	5% WB	MCWBR	4.2	4.3	4.3	4.3	4.0	3.7	3.4	3.6	3.9	4.1	4.1	4.1	(37)
		MCWBR	5.2	5.2	5.2	5.0	4.1	3.9	3.7	4.0	4.4	5.1	5.1	4.9	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.350	0.345	0.331	0.321	0.308	0.308	0.300	0.317	0.337	0.338	0.343	0.338	(40)
		taud	2.513	2.541	2.580	2.585	2.594	2.575	2.606	2.556	2.492	2.502	2.512	2.543	(41)
	Ebn at Noon	Ebn at Noon	978	957	928	870	814	776	815	859	905	953	979	996	(42)
		Edh at Noon	110	102	90	77	65	61	63	78	96	105	110	108	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.08	6.06	4.67	3.17	2.06	1.61	1.78	2.62	3.85	5.39	6.43	7.08	(44)
	RadStd	RadStd	0.45	0.24	0.21	0.16	0.13	0.14	0.08	0.20	0.26	0.27	0.41	0.43	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (25 neighbors)	+0.30	N/A	N/A	+0.68	+0.44	+0.47	N/A	-84	+97	+13

Nomenclature: See separate page