

CAPE BRUNY LH, Australia

WMO: 959670

Lat: 43.4886S

Lon: 147.1444E

Elev: 197

StdP: 14.59

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.1	41.3	31.7	26.2	46.8	33.4	28.2	46.4	45.4	46.6	42.3	45.5	16.7	0	0.749

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.8	76.4	62.4	72.5	61.3	69.5	60.3	65.1	72.7	63.2	69.9	61.6	67.6	14.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.2	84.4	67.5	60.4	79.1	65.9	58.9	74.9	64.7	30.2	73.2	28.8	69.9	27.7	67.7	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.7	38.5	32.9	DB	37.6	89.0	1.1	6.0	36.8	93.3	36.1	96.8	35.5	100.1	34.6	104.5	(4)
(5)			WB	36.0	69.2	0.9	2.4	35.4	70.9	34.9	72.3	34.4	73.6	33.7	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.0	59.7	59.9	58.6	55.5	52.5	49.5	48.5	49.0	50.8	52.7	54.8	57.2
	DBStd	5.77	4.68	4.67	4.71	4.16	3.69	3.24	2.97	3.63	4.05	4.45	4.69	4.66
	HDD50	256	0	0	0	3	15	47	65	64	36	18	6	2
	HDD65	4053	178	157	207	285	389	464	511	496	427	383	308	248
	CDD50	1726	301	277	268	169	91	33	19	32	59	101	151	225
	CDD65	48	14	13	10	1	0	0	0	0	0	1	3	6
	CDH74	264	65	73	49	3	0	0	0	0	0	9	24	41
	CDH80	68	15	25	12	0	0	0	0	0	0	1	2	13
Wind	WSAvg	15.5	15.8	14.8	14.6	14.6	16.0	14.9	14.9	15.6	16.4	16.0	16.4	15.9
Precipitation	PrecAvg	39.6	2.4	2.4	2.6	3.1	3.4	3.5	4.3	4.2	3.5	3.5	3.2	3.1
	PrecMax	51.0	5.9	9.4	5.7	7.8	7.8	8.9	9.6	9.0	7.6	7.6	5.3	6.7
	PrecMin	27.6	0.4	0.6	0.9	0.8	0.9	1.3	2.0	1.7	1.2	0.9	0.9	0.2
	PrecStd	5.2	1.3	1.6	1.1	1.4	1.5	1.6	1.7	1.7	1.5	1.3	1.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.6	83.0	79.1	72.6	66.6	60.2	59.1	63.5	67.6	73.8	77.8	79.0
		MCWB	64.1	64.8	63.6	58.8	55.0	54.4	51.5	52.5	54.6	56.6	60.5	62.5
	2%	DB	74.1	74.5	72.8	68.4	62.7	58.0	56.7	59.5	62.8	67.5	70.0	71.4
		MCWB	62.5	63.5	61.8	57.6	54.9	52.2	50.0	51.0	52.6	56.0	59.1	61.1
	5%	DB	70.1	70.4	68.5	64.3	60.2	56.2	55.0	57.0	59.7	62.9	65.1	67.1
		MCWB	61.5	62.0	60.9	56.7	53.8	50.8	49.4	49.9	51.3	54.0	57.3	59.0
	10%	DB	66.9	67.1	65.3	61.5	58.2	54.7	53.5	54.8	57.0	59.6	61.9	64.3
		MCWB	59.7	60.2	58.9	55.7	52.7	49.9	48.6	48.9	50.4	52.8	55.5	57.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	67.4	66.2	61.7	57.8	56.9	53.1	54.1	56.6	59.8	63.6	65.3
		MCDB	75.4	77.6	72.8	67.9	61.6	59.0	56.1	59.5	64.2	68.1	72.2	74.0
	2%	WB	64.5	64.9	63.4	59.5	56.2	53.1	51.3	52.2	54.0	57.1	61.0	62.0
		MCDB	71.4	72.6	70.3	64.7	60.6	56.1	55.2	57.7	59.5	64.9	67.9	68.9
	5%	WB	62.4	63.0	61.5	57.8	54.7	51.7	50.1	50.6	52.5	55.2	58.3	60.2
		MCDB	68.7	69.2	67.5	63.0	59.4	55.0	54.0	55.8	57.9	61.3	63.9	66.1
	10%	WB	60.5	61.1	59.7	56.2	53.1	50.5	49.0	49.4	51.1	53.5	56.2	58.4
		MCDB	66.0	66.0	64.9	61.1	57.6	54.0	52.8	54.2	56.3	59.0	61.0	63.4
Mean Daily Temperature Range	5% DB	MDBR	11.0	10.8	10.0	9.3	7.8	7.1	7.5	8.7	10.0	10.7	10.3	10.8
		MCDBR	17.7	17.2	16.1	13.8	10.6	8.4	9.3	11.7	14.2	17.4	16.8	16.6
		MCWBR	9.9	9.1	8.6	7.3	7.1	6.0	6.5	7.1	8.4	9.6	9.6	9.9
	5% WB	MCDBR	16.0	15.8	14.5	12.7	9.6	7.6	8.5	10.6	12.3	15.0	15.6	15.4
		MCWBR	10.2	9.3	8.6	7.5	7.3	6.0	6.5	7.1	8.4	9.2	9.7	9.9
Clear-Sky Solar Irradiance	taub	0.344	0.334	0.333	0.320	0.309	0.300	0.300	0.314	0.337	0.337	0.334	0.338	
	taud	2.544	2.587	2.584	2.594	2.599	2.601	2.608	2.579	2.503	2.520	2.549	2.550	
	Ebn at Noon	311	305	291	272	251	242	252	270	284	301	312	315	
	Edh at Noon	34	30	28	23	19	18	19	23	30	32	33	34	
All-Sky Solar Radiation	RadAvg	1963	1675	1216	819	493	394	458	685	1046	1498	1802	1993	
	RadStd	130	119	71	44	36	34	26	49	45	74	136	107	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.74	N/A	N/A	+1.62	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		+0.61	N/A	N/A	N/A	N/A	N/A	-196	+202	+27

Nomenclature: See separate page