

CAPE BRUNY LH, Australia

WMO: 959670

Lat: 43.4886S

Lon: 147.1444E

Elev: 60

StdP: 100.61

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.5	5.2	-0.2	3.7	8.2	0.8	4.0	8.0	20.3	8.1	18.9	7.5	7.5	0	0.749

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.0	24.7	16.9	22.5	16.3	20.8	15.7	18.4	22.6	17.3	21.1	16.5	19.8	6.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.8	12.1	19.7	15.8	11.3	18.8	15.0	10.7	18.2	52.3	22.9	49.0	21.1	46.4	19.9	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.2	14.7	3.1	31.7	0.6	3.3	2.7	34.1	2.3	36.0	1.9	37.8	1.5	40.3		
(5)			2.2	20.7	0.5	1.3	1.9	21.6	1.6	22.4	1.3	23.1	1.0	24.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	15.4	15.5	14.8	13.1	11.4	9.7	9.2	9.4	10.4	11.5	12.7	14.0		
	DBStd	3.21	2.60	2.59	2.62	2.31	2.05	1.80	1.65	2.02	2.25	2.47	2.61	2.59		
	HDD10.0	142	0	0	0	2	8	26	36	36	20	10	3	1		
	HDD18.3	2252	99	87	115	158	216	258	284	276	237	213	171	138		
	CDD10.0	959	167	154	149	94	51	18	11	18	33	56	84	125		
	CDD18.3	27	8	7	6	1	0	0	0	0	0	1	2	3		
	CDH23.3	147	36	41	27	2	0	0	0	0	0	5	13	23		
	CDH26.7	38	8	14	7	0	0	0	0	0	0	1	1	7		
(14) Wind	WSAvg	6.9	7.1	6.6	6.5	6.5	7.1	6.7	6.7	7.0	7.3	7.2	7.3	7.1		
(15) Precipitation	PrecAvg	1006	62	61	67	80	87	88	108	106	88	89	81	79		
	PrecMax	1296	149	239	145	198	198	225	245	228	192	194	135	171		
	PrecMin	700	10	15	24	20	22	33	51	42	30	22	22	4		
	PrecStd	132	32	41	29	36	37	40	43	43	39	34	29	43		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	28.3	26.2	22.6	19.2	15.7	15.1	17.5	19.8	23.2	25.5	26.1		
		MCWB	17.8	18.2	17.6	14.9	12.8	12.4	10.8	11.4	12.5	13.6	15.8	16.9		
	2%	DB	23.4	23.6	22.7	20.2	17.1	14.4	13.7	15.3	17.1	19.7	21.1	21.9		
		MCWB	17.0	17.5	16.5	14.2	12.7	11.2	10.0	10.5	11.4	13.4	15.0	16.1		
	5%	DB	21.2	21.3	20.3	18.0	15.7	13.5	12.8	13.9	15.4	17.2	18.4	19.5		
		MCWB	16.4	16.7	16.0	13.7	12.1	10.5	9.7	9.9	10.7	12.2	14.0	15.0		
	10%	DB	19.4	19.5	18.5	16.4	14.5	12.6	11.9	12.7	13.9	15.3	16.6	17.9		
		MCWB	15.4	15.7	15.0	13.1	11.5	10.0	9.2	9.4	10.2	11.6	13.0	14.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	19.7	19.0	16.5	14.3	13.8	11.7	12.3	13.7	15.5	17.6	18.5		
		MCDB	24.1	25.3	22.7	19.9	16.4	15.0	13.4	15.3	17.9	20.0	22.3	23.3		
	2%	WB	18.1	18.3	17.5	15.3	13.5	11.7	10.7	11.2	12.2	14.0	16.1	16.7		
		MCDB	21.9	22.6	21.3	18.2	15.9	13.4	12.9	14.3	15.3	18.3	19.9	20.5		
	5%	WB	16.9	17.2	16.4	14.3	12.6	10.9	10.0	10.4	11.4	12.9	14.6	15.7		
		MCDB	20.4	20.7	19.7	17.2	15.2	12.8	12.2	13.2	14.4	16.3	17.7	18.9		
	10%	WB	15.8	16.2	15.4	13.4	11.7	10.3	9.4	9.6	10.6	11.9	13.4	14.6		
		MCDB	18.9	18.9	18.3	16.2	14.2	12.2	11.6	12.3	13.5	15.0	16.1	17.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.0	5.6	5.1	4.3	4.0	4.2	4.8	5.5	6.0	5.7	6.0		
		MCDBR	9.8	9.6	8.9	7.7	5.9	4.7	5.1	6.5	7.9	9.7	9.3	9.2		
	5% WB	MCWBR	5.5	5.1	4.8	4.1	4.0	3.3	3.6	3.9	4.7	5.3	5.3	5.5		
		MCWBR	8.9	8.8	8.0	7.0	5.4	4.2	4.7	5.9	6.8	8.3	8.6	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.334	0.333	0.320	0.309	0.300	0.300	0.314	0.337	0.337	0.334	0.338		
		taud	2.544	2.587	2.584	2.594	2.599	2.601	2.608	2.579	2.503	2.520	2.549	2.550		
	Ebn at Noon		981	963	917	856	792	763	794	850	895	949	984	992		
		Edh at Noon	106	96	88	74	61	56	60	73	93	102	105	107		
(44) All-Sky Solar Radiation	RadAvg		6.19	5.28	3.83	2.58	1.55	1.24	1.44	2.16	3.30	4.72	5.68	6.28		
	RadStd		0.41	0.38	0.22	0.14	0.11	0.11	0.08	0.16	0.14	0.23	0.43	0.34		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.41	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		+0.34	N/A	N/A	N/A	N/A	N/A	N/A	-109	+112	+15

Nomenclature: See separate page