

CRESSY, Australia

WMO: 959690

Lat: 41.7256S

Lon: 147.0794E

Elev: 486

StdP: 14.44

Time Zone: 10.00 (AUS)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.4	29.4	25.5	19.9	32.5	27.2	21.5	34.3	31.7	51.2	28.1	51.1	1.8	190	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.2	83.6	64.5	79.9	63.0	76.9	61.7	66.8	77.8	65.3	75.2	63.7	73.2	15.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	89.3	69.4	61.7	83.5	68.5	59.9	78.3	67.3	31.6	78.7	30.4	75.2	29.3	73.2	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.6	24.3	21.7	DB	23.8	91.6	1.7	4.8	22.6	95.1	21.6	97.9	20.6	100.6	19.4	104.0	(4)
(5)			WB	23.5	70.7	1.8	1.5	22.2	71.7	21.2	72.6	20.2	73.4	18.9	74.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	63.3	63.1	59.6	53.3	48.5	44.9	44.4	45.7	48.4	51.7	56.2	59.6	(6)	
	DBStd	8.25	5.57	5.18	5.52	4.87	4.95	4.65	4.15	4.00	3.92	4.52	4.96	5.11	(7)	
	HDD50	711	0	0	2	22	88	162	178	142	76	33	7	1	(8)	
	HDD65	4431	99	89	184	351	511	603	638	598	498	414	267	179	(9)	
	CDD50	1870	412	367	300	122	43	9	4	9	28	85	192	299	(10)	
	CDD65	116	47	36	18	1	0	0	0	0	0	0	2	12	(11)	
	CDH74	1400	594	352	172	3	0	0	0	0	0	4	71	204	(12)	
	CDH80	322	173	66	35	0	0	0	0	0	0	0	8	40	(13)	
(14) Wind	WSAvg	9.7	11.0	10.4	9.4	8.3	8.7	7.6	8.5	9.7	10.3	10.5	10.7	10.9	(14)	
(15) Precipitation	PrecAvg	25.4	1.9	1.3	1.5	1.7	2.1	2.5	2.7	3.0	2.6	2.0	2.1	1.9	(15)	
	PrecMax	36.3	5.8	3.7	4.2	4.0	4.7	6.1	5.7	6.9	5.0	3.9	5.2	3.5	(16)	
	PrecMin	16.5	0.4	0.0	0.4	0.2	0.0	0.2	1.1	0.6	0.5	0.4	0.4	0.2	(17)	
	PrecStd	4.8	1.3	0.8	0.9	0.9	1.3	1.4	1.1	1.8	1.1	0.9	1.1	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	86.6	84.6	72.9	64.3	59.0	57.4	59.8	65.2	73.4	80.5	85.9	(19)	
		MCWB	67.1	66.2	65.8	59.7	56.4	53.2	50.7	52.8	55.7	59.0	62.2	64.6	(20)	
	2%	DB	84.7	81.7	78.5	68.9	61.3	56.6	55.4	57.3	61.5	67.9	75.4	79.2	(21)	
		MCWB	64.7	64.4	63.0	58.8	54.7	51.9	50.3	51.0	53.5	57.2	61.2	62.0	(22)	
	5%	DB	80.2	78.3	74.5	65.9	59.2	54.9	53.7	55.3	59.2	64.6	71.1	75.5	(23)	
		MCWB	63.0	62.8	61.3	56.8	53.3	50.9	49.4	50.0	51.9	55.4	59.1	60.3	(24)	
	10%	DB	76.6	75.2	71.2	63.3	57.3	53.2	52.1	53.5	57.1	62.0	67.7	72.1	(25)	
		MCWB	61.3	61.2	59.2	55.3	52.7	49.7	48.5	48.6	50.6	53.9	57.6	58.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	68.9	67.2	62.9	58.8	55.8	53.5	54.5	57.4	61.5	65.2	67.1	(27)	
		MCDB	85.4	79.8	79.4	68.7	61.2	57.0	55.3	57.9	62.4	67.3	74.0	77.7	(28)	
	2%	WB	67.0	66.5	64.8	60.5	56.5	53.3	51.8	52.3	55.1	58.9	62.7	64.8	(29)	
		MCDB	79.1	77.0	74.1	65.8	59.5	55.3	53.8	55.6	59.5	65.6	72.0	74.3	(30)	
	5%	WB	64.9	64.9	63.2	58.8	55.0	51.7	50.3	50.9	53.4	56.8	60.6	62.7	(31)	
		MCDB	75.5	74.5	71.7	63.6	58.0	54.1	52.6	54.1	57.6	63.0	69.5	72.6	(32)	
	10%	WB	63.0	63.2	61.2	56.9	53.4	50.3	49.0	49.6	51.7	54.9	58.6	60.4	(33)	
		MCDB	73.6	72.2	68.7	61.6	56.4	52.6	51.5	52.8	55.8	60.7	66.2	69.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	24.2	22.8	22.1	20.2	17.5	16.1	15.5	16.2	17.7	19.9	21.4	23.1	(35)	
		MCDBR	30.3	27.0	26.3	23.7	18.3	16.6	16.1	17.6	20.2	23.9	27.6	28.7	(36)	
	5% WB	MCWBR	13.4	12.3	12.6	14.1	12.6	12.4	12.1	12.4	13.4	14.8	15.0	13.7	(37)	
		MCWBR	25.8	23.4	22.7	20.2	15.0	14.5	13.7	15.1	18.1	21.0	24.1	24.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.341	0.333	0.325	0.314	0.302	0.290	0.290	0.306	0.326	0.332	0.338	0.335	(40)	
		taud	2.495	2.535	2.550	2.558	2.567	2.589	2.594	2.548	2.478	2.472	2.480	2.501	(41)	
	Ebn at Noon		313	307	295	277	258	252	261	276	290	304	312	317	(42)	
		Edh at Noon	36	32	29	25	21	18	20	24	31	34	36	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2186	1846	1415	957	613	476	530	782	1160	1627	1953	2159	(44)	
	RadStd		155	80	65	54	39	42	26	61	77	89	146	141	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153	N/A
Regional (36 neighbors)	+0.58	N/A	N/A	+1.22	+0.63	+0.74	N/A	-176	+191	+23

Nomenclature: See separate page